

VENTILATION AUDIT REPORT

SCHOOL:	Moree Public School (2618)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Northern Tablelands
LOCAL GOVERNMENT AREA:	Moree Plains

2618 - Moree Public School
Site Plan (10652)














Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (243.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Movement - (153.9 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Movement - (123.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Canteen - (29.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Movement - (86.76 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Movement - (40.02 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Movement - (18.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Raised Platform - (29.61 SQM)	Not Applicable	Circulation or storage space.
B00A - R1002 - Communal Space - (137.18 SQM)	● Student Space (63)	
B00A - R1005 - Home Base - (67.75 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R1006 - Movement - (51.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R1007 - Entry Vestibule - (17.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R1009 - Clerical Office - (16.26 SQM)	● Office (4)	
B00A - R1011 - Sick Bay - (10.55 SQM)	● Student Space (4)	
B00A - R1012 - Duplicating Workroom - (30.07 SQM)	● Office (7)	
B00A - R1013 - Interview - (12.64 SQM)	● Office (3)	
B00A - R1014 - Deputy Principal - (13.95 SQM)	● Office (3)	
B00A - R1016 - Deputy Principal - (13.38 SQM)	● Office (3)	
B00A - R1018 - Principal - (23.14 SQM)	● Office (5)	
B00A - R1019 - Movement - (7.35 SQM)	Not Applicable	Circulation or storage space.
B00A - R1020 - Movement - (58.11 SQM)	Not Applicable	Circulation or storage space.
B00A - R1023 - Home Base - (51.78 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1024 - Movement - (7.37 SQM)	Not Applicable	Circulation or storage space.
B00A - R1025 - Home Base - (51.67 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1026 - Movement - (7.36 SQM)	Not Applicable	Circulation or storage space.
B00A - R1027 - Home Base - (51.34 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1028 - Movement - (7.33 SQM)	Not Applicable	Circulation or storage space.
B00A - R1029 - Special Programs Room - (19.55 SQM)	● Student Space (9)	
B00A - R1031 - Movement - (76.42 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (101.72 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Staff Room Annexe - (17.79 SQM)	● Office (4)	
B00B - R0008 - Movement - (6.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Home Base - (77.58 SQM) - Teaching Space: 1	● Student Space (35)	
B00B - R0013 - Home Base - (53.42 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0016 - Movement - (7.26 SQM)	Not Applicable	Circulation or storage space.
B00B - R0019 - Home Base - E - (52.18 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0020 - Movement - (13.86 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Staff Room Annexe - (14.06 SQM)	● Office (3)	
B00C - R0005 - Staff Room - (72.06 SQM)	● Office (18)	
B00C - R0007 - Staff Room Annexe - (27.54 SQM)	● Office (6)	
B00C - R0008 - Movement - (36.38 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (34.43 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Home Base - (56.85 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0004 - Practical Activities - 1hb - (10.32 SQM)	● Student Space (4)	
B00D - R0007 - Movement - (149.72 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Home Base - (65.7 SQM)	● Student Space (30)	
B00D - R0011 - Movement - (141.79 SQM)	Not Applicable	Circulation or storage space.
B00D - R0015 - Withdrawal Space - 1hb - (40.03 SQM)	● Student Space (18)	
B00D - R0017 - Movement - (133.07 SQM)	Not Applicable	Circulation or storage space.
B00D - R0029 - Movement - (118.37 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Movement - (8.2 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R1003 - Home Base - (56.23 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R1005 - Practical Activities - 1hb - (10.28 SQM)	Student Space (4)	
B00D - R1006 - Home Base - (57.11 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R1008 - Practical Activities - 1hb - (9.14 SQM)	Student Space (4)	
B00D - R1010 - Practical Activities - 1hb - (8.94 SQM)	Student Space (4)	
B00D - R1012 - Home Base - (57.58 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R1013 - Home Base - (57.26 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R1015 - Practical Activities - 1hb - (9.36 SQM)	Student Space (4)	
B00D - R1016 - Home Base - (57.58 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R1018 - Practical Activities - 1hb - (9.07 SQM)	Student Space (4)	
B00D - R1019 - Home Base - (57.58 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R1021 - Practical Activities - 1hb - (9.04 SQM)	Student Space (4)	
B00D - R1022 - Movement - (9.12 SQM)	Not Applicable	Circulation or storage space.
B00D - R1024 - Movement - (120.2 SQM)	Not Applicable	Circulation or storage space.
B00D - R1026 - Movement - (12.52 SQM)	Not Applicable	Circulation or storage space.
B00D - R1027 - Practical Activities - 1hb - (8.66 SQM)	Student Space (4)	
B00D - R1029 - Home Base - (57.59 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R1030 - Practical Activities - 1hb - (9.04 SQM)	Student Space (4)	
B00D - R1032 - Home Base - (57.59 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R1033 - Practical Activities - 1hb - (9.15 SQM)	Student Space (4)	
B00D - R1035 - Home Base - (57.59 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R1036 - Practical Activities - 1hb - (9.15 SQM)	Student Space (4)	
B00D - R1038 - Home Base - (56.79 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R1039 - Movement - (6.32 SQM)	Not Applicable	Circulation or storage space.
B00D - R1040 - Movement - (14.52 SQM)	Not Applicable	Circulation or storage space.
B00D - R1041 - Practical Activities - 1hb - (7.96 SQM)	Student Space (3)	
B00D - R1043 - Home Base - (57.59 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R1045 - Movement - (93.45 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (78.15 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Home Base - M - (56.72 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0004 - Staff Room Annexe - (13.47 SQM)	Office (3)	
B00E - R0006 - Practical Activities - M - 1hb - (56.7 SQM)	Student Space (26)	
B00E - R0007 - Home Base - M - (58.77 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0009 - Withdrawal - M - (6.73 SQM)	Student Space (3)	
B00F - R0001 - Movement - (42.09 SQM)	Not Applicable	Circulation or storage space.
B00F - R0013 - Interview - (13.83 SQM)	Office (3)	
B00F - R0017 - Interview - (28.81 SQM)	Office (7)	
B00F - R0018 - Interview - (10.02 SQM)	Office (2)	
B00G - R0001 - Movement - (103.45 SQM)	Not Applicable	Circulation or storage space.
B00G - R1001 - Home Base - (57.03 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R1004 - Home Base - (57.41 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R1005 - Movement - (5.33 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Home Base - (53.78 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R0004 - Home Base - (77.64 SQM) - Teaching Space: 1	Student Space (36)	
B00H - R0008 - Movement - (41.6 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Movement - (106.71 SQM)	Not Applicable	Circulation or storage space.
B00J - R0003 - Movement - (156.86 SQM)	Not Applicable	Circulation or storage space.
B00J - R0004 - Movement - (8.86 SQM)	Not Applicable	Circulation or storage space.
B00J - R0009 - Movement - (54.94 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R0010 - Canteen - (43.24 SQM)	Not Applicable	Circulation or storage space.
B00J - R1001 - Reading Area - (273.79 SQM)	 Student Space (127)	
B00J - R1004 - Movement - (41.68 SQM)	Not Applicable	Circulation or storage space.
B00J - R1009 - Darkroom Space - (13.06 SQM)	 Office (3)	
B00J - R1011 - Withdrawal Space - 1hb - (26.24 SQM)	 Student Space (12)	
B00K - R0001 - Movement - (38.58 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Practical Activities - 1hb - (19.44 SQM)	 Student Space (9)	
B00K - R0004 - Home Base - (59.34 SQM) - Teaching Space: 1	 Student Space (27)	
B00K - R0005 - Withdrawal Space - 2hb - (11.38 SQM)	 Student Space (5)	
B00K - R0006 - Home Base - (59.32 SQM) - Teaching Space: 1	 Student Space (27)	
B00K - R0008 - Practical Activities - 1hb - (19.44 SQM)	 Student Space (9)	
B00L - R0001 - Communal Space - (200.75 SQM)	 Student Space (93)	
B00L - R0002 - Raised Platform - (59.15 SQM)	Not Applicable	Circulation or storage space.
B00L - R0015 - Communal Space - (159.62 SQM)	 Student Space (74)	
B00L - R0016 - Movement - (5.69 SQM)	Not Applicable	Circulation or storage space.
B00L - R0018 - Movement - (17.29 SQM)	Not Applicable	Circulation or storage space.
OS 602 10399 - OS 602 10399 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	