


VENTILATION AUDIT REPORT

SCHOOL:	Moree Secondary College Albert Street Campus (8325)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Northern Tablelands
LOCAL GOVERNMENT AREA:	Moree Plains

8325 - Moree Secondary College Albert Street Campus
Site Plan (12779)



1:776





Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Commonroom - (79.93 SQM)	Office (19)	
B00A - R0002 - Staff Study - (24.87 SQM)	Office (6)	
B00A - R0006 - Food/Research Space - (12.67 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Food Technology L.S. - (90.74 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R0011 - Staff Study - (35.78 SQM)	Office (8)	
B00A - R0012 - General Assistants - (16.6 SQM)	Office (4)	
B00A - R0022 - Leading Teacher - (18.38 SQM)	Office (4)	
B00A - R0023 - Clinic - (7.91 SQM)	Office (1)	
B00A - R0027 - Principal Office - (18.53 SQM)	Office (4)	
B00A - R0029 - Duplicating Workroom - (16.05 SQM)	Office (4)	
B00A - R0030 - Administration - Clerical - (33.86 SQM)	Office (8)	
B00A - R0031 - Movement - (50.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0035 - Clinic - Boys - (15.32 SQM)	Office (3)	
B00A - R0036 - Interview/Office - Type 1 - (16.44 SQM)	Office (4)	
B00A - R0038 - Deputy Principal Office - (17.32 SQM)	Office (4)	
B00A - R0040 - Interview/Office - Type 1 - (16.24 SQM)	Office (4)	
B00A - R0041 - Movement - (50.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R0045 - Food/Research Space - (28.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R0048 - Movement - (105.86 SQM)	Not Applicable	Circulation or storage space.
B00A - R0053 - Movement - (13.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R0055 - Movement - (20.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R0059 - Metal Technology Bay - (195.6 SQM)	Not Applicable	Circulation or storage space.
B00A - R0064 - Welding Area - (9.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0065 - Welding Area - (9.93 SQM)	Not Applicable	Circulation or storage space.
B00A - R0066 - Metal Technology Bay - (8.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R0067 - Metal Technology Bay - (27.72 SQM)	Not Applicable	Circulation or storage space.
B00A - R0071 - Food Technology L.S. - (100.51 SQM) - Teaching Space: 1	Student Space (46)	
B00A - R1002 - General Learning Space - (52.34 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1006 - Movement - (7.41 SQM)	Not Applicable	Circulation or storage space.
B00A - R1007 - Laboratory L.S. - (91.46 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R1008 - Preparation - (28.52 SQM)	Not Applicable	Circulation or storage space.
B00A - R1010 - Laboratory L.S. - (92.35 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R1013 - Senior Study - (53.28 SQM)	Office (13)	
B00A - R1014 - General Learning Space - (52.48 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1017 - Movement - (6.73 SQM)	Not Applicable	Circulation or storage space.
B00A - R1019 - Staff Study - (25.89 SQM)	Office (6)	
B00A - R1023 - Art Learning Space - (52.35 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1029 - Workroom - (19.06 SQM)	Office (4)	
B00A - R1030 - Workroom - (19.22 SQM)	Office (4)	
B00A - R1031 - Main Area - (194.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R1033 - Workroom - (6.26 SQM)	Office (1)	
B00A - R1034 - Workroom - (8.1 SQM)	Office (2)	
B00A - R1035 - Movement - (18.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R1038 - Staff Study - (31.97 SQM)	Office (7)	
B00A - R1039 - Computer Learning Space - (84.97 SQM) - Teaching Space: 1	Student Space (39)	
B00A - R1041 - Movement - (7.18 SQM)	Not Applicable	Circulation or storage space.
B00A - R1046 - Movement - (12.68 SQM)	Not Applicable	Circulation or storage space.
B00A - R1048 - Movement - (9.02 SQM)	Not Applicable	Circulation or storage space.
B00A - R1052 - Movement - (12.08 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R1053 - Movement - (12.86 SQM)	Not Applicable	Circulation or storage space.
B00A - R1068 - Workshop Area - (118.98 SQM)	● Student Space (55)	
B00A - R2002 - General Learning Space - (52.63 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R2003 - Staff Study - (25.04 SQM)	○ Office (6)	
B00A - R2006 - Movement - (7.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R2007 - Laboratory L.S. - (91.34 SQM) - Teaching Space: 1	● Student Space (42)	
B00A - R2009 - Preparation - (28.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R2010 - Laboratory L.S. - (92.15 SQM) - Teaching Space: 1	● Student Space (42)	
B00A - R2013 - General Learning Space - (52.7 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R2014 - Computer Learning Space - (52.42 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R2017 - Movement - (6.64 SQM)	Not Applicable	Circulation or storage space.
B00A - R2019 - Staff Study - (33.84 SQM)	○ Office (8)	
B00A - R2022 - Art Learning Space - (72.55 SQM) - Teaching Space: 1	● Student Space (33)	
B00A - R2023 - Art Learning Space - (52.27 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R2025 - General Learning Space - (52.85 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R2030 - General Learning Space - (52.13 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R2031 - General Learning Space - (51.9 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R2033 - General Learning Space - (52.06 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R2034 - General Learning Space - (50.82 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R2038 - Movement - (7.09 SQM)	Not Applicable	Circulation or storage space.
B00A - R2041 - General Learning Space - (52.92 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R2043 - General Learning Space - (58 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R2047 - Movement - (12.32 SQM)	Not Applicable	Circulation or storage space.
B00A - R2049 - Movement - (6.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R2052 - Movement - (10.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R2054 - Movement - (12.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R2055 - Movement - (13.17 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - General Learning Space - (47.55 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R0006 - General Learning Space - (48.79 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R0007 - General Learning Space - (53.87 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0010 - General Learning Space - (47.41 SQM) - Teaching Space: 1	● Student Space (21)	
B00B - R0012 - Staff Study - (32.98 SQM)	○ Office (8)	
B00B - R0013 - Movement - (16.85 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Student Canteen - (37.39 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Movement - (267.35 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Staff Kitchen - (15.03 SQM)	○ Office (3)	
B00D - R0004 - Staff Study - (8.63 SQM)	○ Office (2)	
B00D - R0005 - Staff Study - (8.69 SQM)	○ Office (2)	
B00D - R0010 - Movement - (53.22 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Stage - (64.79 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Multi-Purpose Space - (455.73 SQM)	● Student Space (211)	
B00E - R0002 - General Assistants - (12.19 SQM)	○ Office (3)	
B00F - R0001 - Darkroom Space - (22.27 SQM)	○ Office (5)	
B00F - R0002 - Music Learning Space - (34.99 SQM) - Teaching Space: 1	● Student Space (16)	
B00F - R0004 - Music Learning Space - (53.8 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0005 - Staff Study - (22.2 SQM)	○ Office (5)	
B00F - R0006 - General Learning Space - (53.65 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0007 - General Learning Space - (53.73 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R0002 - Gymnasium - (38 SQM)	● Student Space (17)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00K - R0001 - General Learning Space - (59.78 SQM) - Teaching Space: 1	 Student Space (27)	
B00K - R0002 - Science Laboratory - (59.94 SQM)	 Student Space (27)	
B00K - R0003 - Preparation - (31.06 SQM)	Not Applicable	Circulation or storage space.
B00K - R0006 - Staff Study - (21.04 SQM)	 Office (5)	
B00K - R0007 - Seminar - Type 2 - (21.04 SQM)	 Office (5)	
B00K - R0008 - Movement - (6.38 SQM)	Not Applicable	Circulation or storage space.
B00K - R0011 - Outdoor Learning Space - Type 4 - (41.29 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Outdoor Workshop - (60.1 SQM)	Not Applicable	Circulation or storage space.