

VENTILATION AUDIT REPORT

SCHOOL:	Mortlake Public School (2625)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Drummoyne
LOCAL GOVERNMENT AREA:	Canada Bay

2625 - Mortlake Public School
Site Plan (12995)



1:753

Printed: 24-Dec-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0001 - Sick Bay - (10.09 SQM)	Student Space (4)	
B001 - R0007 - Canteen - (22.38 SQM)	Not Applicable	Circulation or storage space.
B001 - R0009 - Duplicating Workroom - (18.29 SQM)	Office (4)	
B001 - R0010 - Principal - (14.98 SQM)	Office (3)	
B001 - R0011 - Staff Room - (25.83 SQM)	Office (6)	
B001 - R0012 - Special Programs Room - (48.41 SQM)	Student Space (22)	
B001 - R0013 - Home Base - (48.28 SQM) - Teaching Space: 1	Student Space (22)	
B001 - R0014 - Home Base - (48.34 SQM) - Teaching Space: 1	Student Space (22)	
B001 - R0016 - Movement - (25.19 SQM)	Not Applicable	Circulation or storage space.
B001 - R0018 - Deputy Principal - (13.94 SQM)	Office (3)	
B001 - R0022 - Movement - (8.75 SQM)	Not Applicable	Circulation or storage space.
B001 - R0025 - Movement - (38.8 SQM)	Not Applicable	Circulation or storage space.
B001 - R0028 - Entry Vestibule - (8.69 SQM)	Not Applicable	Circulation or storage space.
B001 - R0029 - Clerical Office/Workroom - (11.64 SQM)	Office (2)	
B001 - R0030 - Movement - (32.96 SQM)	Not Applicable	Circulation or storage space.
B001 - R0034 - Practical Activities - 1hb - (12.37 SQM)	Student Space (5)	
B001 - R0035 - Home Base - (65 SQM) - Teaching Space: 1	Student Space (30)	
B001 - R0036 - Special Programs Room - (26.72 SQM)	Student Space (12)	
B001 - R1004 - Home Base - (50.24 SQM) - Teaching Space: 1	Student Space (23)	
B001 - R1005 - Home Base - (49.43 SQM) - Teaching Space: 1	Student Space (22)	
B001 - R1006 - Home Base - (49.37 SQM) - Teaching Space: 1	Student Space (22)	
B001 - R1007 - Home Base - (49.37 SQM) - Teaching Space: 1	Student Space (22)	
B001 - R1008 - Home Base - (50.38 SQM) - Teaching Space: 1	Student Space (23)	
B001 - R1009 - Interview - (12.27 SQM)	Office (3)	
B001 - R1011 - Movement - (7.37 SQM)	Not Applicable	Circulation or storage space.
B001 - R1012 - Movement - (68.04 SQM)	Not Applicable	Circulation or storage space.
B001 - R1013 - Movement - (7.21 SQM)	Not Applicable	Circulation or storage space.
B002 - R0001 - Movement - (13.91 SQM)	Not Applicable	Circulation or storage space.
B002 - R0002 - Reading Area - (159.2 SQM)	Student Space (73)	
B002 - R0005 - Special Programs Room - (42.64 SQM)	Student Space (19)	
B002 - R0009 - Movement - (73.51 SQM)	Not Applicable	Circulation or storage space.
B002 - R0010 - Movement - (13.89 SQM)	Not Applicable	Circulation or storage space.
B003 - R0002 - Home Base - (53.8 SQM) - Teaching Space: 1	Student Space (24)	
B003 - R0003 - Home Base - (53.66 SQM) - Teaching Space: 1	Student Space (24)	
B003 - R0004 - Movement - (22.57 SQM)	Not Applicable	Circulation or storage space.
B004 - R0001 - Movement - (48.13 SQM)	Not Applicable	Circulation or storage space.
B004 - R0002 - Movement - (8.58 SQM)	Not Applicable	Circulation or storage space.
B004 - R0003 - Home Base - (48.13 SQM) - Teaching Space: 1	Student Space (22)	
B004 - R0004 - Home Base - (47.68 SQM) - Teaching Space: 1	Student Space (22)	
B004 - R0005 - Interview - (16.16 SQM)	Office (4)	
B004 - R0007 - Entry Vestibule - (21.21 SQM)	Not Applicable	Circulation or storage space.
B004 - R0012 - Movement - (12.73 SQM)	Not Applicable	Circulation or storage space.
B004 - R0013 - Communal Space - (59.26 SQM)	Student Space (27)	
B004 - R0014 - Practical Activities - 1hb - (14.16 SQM)	Student Space (6)	
B004 - R1001 - Staff Room - (44.69 SQM)	Office (11)	
B004 - R1002 - Home Base - (47.95 SQM) - Teaching Space: 1	Student Space (22)	
B004 - R1003 - Home Base - (48.15 SQM) - Teaching Space: 1	Student Space (22)	
B004 - R1004 - Movement - (24.61 SQM)	Not Applicable	Circulation or storage space.
B004 - R1006 - Movement - (5.29 SQM)	Not Applicable	Circulation or storage space.
B004 - R1008 - Practical Activities - 1hb - (15.96 SQM)	Student Space (7)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B007 - R0001 - Communal Space - (143.24 SQM)	● Student Space (66)	
B007 - R0002 - Raised Platform - (61.76 SQM)	Not Applicable	Circulation or storage space.
B007 - R0016 - Movement - (6.62 SQM)	Not Applicable	Circulation or storage space.
B007 - R0017 - Movement - (14.12 SQM)	Not Applicable	Circulation or storage space.
OS 602 13985 - OS 602 13985 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14461 - OS 602 14461 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 18158 - OS 602 18158 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	