

VENTILATION AUDIT REPORT

SCHOOL:	Moruya High School (8368)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Bega
LOCAL GOVERNMENT AREA:	Eurobodalla

8368 - Moruya High School
Site Plan (12937)



1:1,571

Printed: 19-Dec-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0008 - Laboratory L.S. - (91.74 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R0011 - Laboratory L.S. - (84.37 SQM) - Teaching Space: 1	Student Space (39)	
B00A - R0033 - Commonroom - (45.23 SQM)	Office (11)	
B00A - R0035 - Movement - (28.74 SQM)	Not Applicable	Circulation or storage space.
B00A - R0036 - Deputy Principal Office - (14.09 SQM)	Office (3)	
B00A - R0037 - Interview/Meeting - (14.29 SQM)	Office (3)	
B00A - R0038 - Administration - Executive - (14.13 SQM)	Office (3)	
B00A - R0039 - Interview/Meeting - (14.09 SQM)	Office (3)	
B00A - R0040 - Movement - (52.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R0042 - Administration - Clerical - (41.84 SQM)	Office (10)	
B00A - R0043 - Clinic - Boys - (15.97 SQM)	Office (3)	
B00A - R0044 - Movement - (5.89 SQM)	Not Applicable	Circulation or storage space.
B00A - R0046 - Clinic - Boys - (8.35 SQM)	Office (2)	
B00A - R0047 - Movement - (5.73 SQM)	Not Applicable	Circulation or storage space.
B00A - R0048 - Principal Office - (22.54 SQM)	Office (5)	
B00A - R0052 - Deputy Principal Office - (13.19 SQM)	Office (3)	
B00A - R0053 - Movement - (195.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R0054 - Preparation - Science - (39.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R0055 - Interview/Meeting - (11.26 SQM)	Office (2)	
B00A - R0056 - Interview/Meeting - (11.3 SQM)	Office (2)	
B00A - R0057 - Public Entry - (28.73 SQM)	Not Applicable	Circulation or storage space.
B00A - R0058 - Movement - (11.22 SQM)	Not Applicable	Circulation or storage space.
B00A - R0059 - Administration - Clerical - (11.37 SQM)	Office (2)	
B00A - R1001 - General Learning Space - (57.89 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1004 - Staff Study - (56.55 SQM)	Office (14)	
B00A - R1007 - Staff Study - (25.72 SQM)	Office (6)	
B00A - R1008 - General Learning Space - (51.81 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1009 - General Learning Space - (51.81 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1010 - General Learning Space - (52.03 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1011 - General Learning Space - (57.89 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1014 - General Learning Space - (50.88 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1017 - General Learning Space - (57.98 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1018 - General Learning Space - (52.11 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1019 - General Learning Space - (52.03 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1020 - General Learning Space - (52.1 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1022 - Movement - (165.22 SQM)	Not Applicable	Circulation or storage space.
B00A - R1025 - Staff Study - (16.86 SQM)	Office (4)	
B00B - R0007 - General Learning Space - (51.01 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0011 - Materials Technology L.S. - (98.86 SQM) - Teaching Space: 1	Student Space (45)	
B00B - R0012 - Staff Study - (38.55 SQM)	Office (9)	
B00B - R0013 - Materials Technology L.S. - (97.88 SQM) - Teaching Space: 1	Student Space (45)	
B00B - R0017 - General Learning Space - (51.3 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0033 - Movement - (175.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R0036 - Food Technology L.S. - (108.87 SQM) - Teaching Space: 1	Student Space (50)	
B00B - R0041 - Food Technology L.S. - (122.42 SQM) - Teaching Space: 1	Student Space (56)	
B00B - R0043 - Preparation - Materials - (20.79 SQM)	Not Applicable	Circulation or storage space.
B00B - R0047 - Staff Study - (12.5 SQM)	Office (3)	
B00B - R1001 - Design L.S. - (70.82 SQM) - Teaching Space: 1	Student Space (32)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1004 - Computer Learning Space - (51.01 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1007 - Materials Technology L.S. - (101.71 SQM) - Teaching Space: 1	● Student Space (47)	
B00B - R1014 - Music Learning Space - (51.88 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1015 - Music Learning Space - (57.5 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R1018 - Design L.S. - (50.73 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1019 - Seminar/Technology Space - (25.59 SQM)	● Office (6)	
B00B - R1022 - Art Learning Space - (64.94 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R1025 - Art Learning Space - (65.16 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R1031 - Movement - (149.48 SQM)	Not Applicable	Circulation or storage space.
B00B - R1033 - Staff Study - (25.58 SQM)	● Office (6)	
B00C - R0004 - Student Canteen - (56.93 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Movement - (6.42 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - Movement - (11.6 SQM)	Not Applicable	Circulation or storage space.
B00C - R0017 - Movement - (10.5 SQM)	Not Applicable	Circulation or storage space.
B00C - R0018 - Movement - (394.95 SQM)	Not Applicable	Circulation or storage space.
B00C - R0024 - Movement - (148.3 SQM)	Not Applicable	Circulation or storage space.
B00C - R1003 - Movement - (12.92 SQM)	Not Applicable	Circulation or storage space.
B00C - R1010 - Movement - (12.85 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - General Learning Space - (67.73 SQM) - Teaching Space: 1	● Student Space (31)	
B00D - R0006 - Study Space - (30.27 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Staff Study - (19.84 SQM)	● Office (4)	
B00D - R0008 - General Learning Space - (52.53 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0009 - General Learning Space - (52.4 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0010 - General Learning Space - (52.39 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0015 - Staff Study - (36.76 SQM)	● Office (9)	
B00D - R0020 - Laboratory L.S. - (97.48 SQM) - Teaching Space: 1	● Student Space (45)	
B00D - R0021 - Preparation - (46.22 SQM)	Not Applicable	Circulation or storage space.
B00D - R0022 - Laboratory L.S. - (97.66 SQM) - Teaching Space: 1	● Student Space (45)	
B00D - R0023 - Movement - (172.19 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Computer Learning Space - (71.52 SQM) - Teaching Space: 1	● Student Space (33)	
B00D - R1004 - Darkroom Space - (21.95 SQM)	● Office (5)	
B00D - R1006 - Staff Study - (6.77 SQM)	● Office (1)	
B00D - R1007 - Staff Study - (31.08 SQM)	● Office (7)	
B00D - R1008 - Senior Study - (19.78 SQM)	● Office (4)	
B00D - R1009 - General Learning Space - (52.24 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1010 - General Learning Space - (52.16 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1011 - Commonroom - (110.57 SQM)	● Office (27)	
B00D - R1016 - Main Area - (270.41 SQM)	Not Applicable	Circulation or storage space.
B00D - R1017 - Audio Visual Workroom - (20.36 SQM)	● Student Space (9)	
B00D - R1018 - Workroom - (18.29 SQM)	● Office (4)	
B00D - R1021 - Movement - (174.41 SQM)	Not Applicable	Circulation or storage space.
B00D - R1026 - Seminar - (24.18 SQM)	● Office (6)	
B00D - R1027 - Staff Study - (31.08 SQM)	● Office (7)	
B00F - R0003 - Movement - (12.61 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Staff Study - (9.82 SQM)	● Office (2)	
B00H - R0001 - Multi-Purpose Space - (466.79 SQM)	● Student Space (216)	
B00H - R0002 - Staff Kitchen - (16.02 SQM)	● Office (4)	
B00H - R0008 - Movement - (16.05 SQM)	Not Applicable	Circulation or storage space.
B00H - R0010 - Stage - (90.19 SQM)	Not Applicable	Circulation or storage space.
B00H - R0015 - Movement - (7.96 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0016 - Movement - (8.64 SQM)	Not Applicable	Circulation or storage space.
B00H - R0019 - Movement - (5.29 SQM)	Not Applicable	Circulation or storage space.
B00H - R0020 - Movement - (8.64 SQM)	Not Applicable	Circulation or storage space.
NS 020 10470 - NS 020 10470 - Staff Study/Store - (38 SQM)	Not Applicable	Circulation or storage space.
OS 600 10609 - OS 600 10609 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 601 13355 - OS 601 13355 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13400 - OS 601 13400 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13586 - OS 601 13586 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 720 14599 - OS 720 14599 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.