

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Moruya Public School (2628)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Bega</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Eurobodalla</b>

2628 - Moruya Public School  
Site Plan (12533)


























1:1,127

Printed: 12-Dec-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Clerical Office - (14.26 SQM)	Office (3)	
B00A - R0003 - Deputy Principal - (14.26 SQM)	Office (3)	
B00A - R0004 - Principal - (19.55 SQM)	Office (4)	
B00A - R0012 - Sick Bay - (6.62 SQM)	Student Space (3)	
B00A - R0013 - Clerical Office - (14.33 SQM)	Office (3)	
B00A - R0014 - Duplicating Workroom - (12.56 SQM)	Office (3)	
B00A - R0017 - Clerical Office - (20.41 SQM)	Office (5)	
B00A - R0018 - Movement - (18.99 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Staff Room Annexe - (21.06 SQM)	Office (5)	
B00B - R0005 - Movement - (13.03 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Staff Kitchen - (9.05 SQM)	Office (2)	
B00B - R0009 - Staff Room - (85.13 SQM)	Office (21)	
B00C - R0003 - Canteen - (43.65 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Movement - (5.26 SQM)	Not Applicable	Circulation or storage space.
B00D - R0017 - Movement - (9.72 SQM)	Not Applicable	Circulation or storage space.
B00D - R0021 - Raised Platform - (50.93 SQM)	Not Applicable	Circulation or storage space.
B00D - R0022 - Communal Space - (195.69 SQM)	Student Space (90)	
B00E - R0002 - Practical Activities - 1hb - (42.09 SQM)	Student Space (19)	
B00E - R0006 - Staff Room Annexe - (13.12 SQM)	Office (3)	
B00E - R0007 - Home Base - (59.94 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0009 - Withdrawal Space - 1hb - (11.66 SQM)	Student Space (5)	
B00E - R0011 - Home Base - (59.88 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0002 - Practical Activities - 1hb - (42.02 SQM)	Student Space (19)	
B00F - R0007 - Home Base - (60.01 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0008 - Withdrawal Space - 1hb - (11.61 SQM)	Student Space (5)	
B00F - R0009 - Home Base - (60 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0003 - Reading Area - (235.05 SQM)	Student Space (109)	
B00G - R0006 - Special Programs Room - (44.25 SQM)	Student Space (20)	
B00I - R0002 - Practical Activities - P - 1hb - (9.12 SQM)	Student Space (4)	
B00I - R0005 - Home Base - P - (70.69 SQM) - Teaching Space: 1	Student Space (32)	
B00I - R0006 - Home Base - (70.69 SQM) - Teaching Space: 1	Student Space (32)	
B00I - R0009 - Practical Activities - 1hb - (30.65 SQM)	Student Space (14)	
B00I - R0012 - Home Base - (70.76 SQM) - Teaching Space: 1	Student Space (32)	
B00I - R0013 - Staff Room Annexe - (17.03 SQM)	Office (4)	
B00I - R0014 - Staff Room Annexe - (6.04 SQM)	Office (1)	
B00I - R0016 - Movement - (10.78 SQM)	Not Applicable	Circulation or storage space.
B00I - R0020 - Special Programs Room - (23.3 SQM)	Student Space (10)	
B00I - R0022 - Staff Room Annexe - (18.24 SQM)	Office (4)	
B00I - R0025 - Movement - (7.11 SQM)	Not Applicable	Circulation or storage space.
B00I - R0030 - Home Base - (56.71 SQM) - Teaching Space: 1	Student Space (26)	
B00I - R0031 - Practical Activities - 1hb - (13.5 SQM)	Student Space (6)	
B00I - R0032 - Home Base - (70.23 SQM) - Teaching Space: 1	Student Space (32)	
B00I - R0033 - Practical Activities - 1hb - (18.66 SQM)	Student Space (8)	
B00I - R0037 - Clerical Office - (9.58 SQM)	Office (2)	
B00I - R0038 - Movement - (27.46 SQM)	Not Applicable	Circulation or storage space.
B00I - R0039 - Movement - (5.63 SQM)	Not Applicable	Circulation or storage space.
B00I - R9004 - Special Programs Room - (104.49 SQM)	Student Space (48)	
B00J - R0003 - Practical Activities - 1hb - (32.57 SQM)	Student Space (15)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R0005 - Home Base - (69.94 SQM) - Teaching Space: 1	 Student Space (32)	
B00J - R0008 - Interview - (8.87 SQM)	 Office (2)	
B00J - R0012 - Staff Kitchen - (12.27 SQM)	 Office (3)	
B00J - R0013 - Home Base - (84.76 SQM) - Teaching Space: 1	 Student Space (39)	
B00L - R0005 - Movement - (13.89 SQM)	Not Applicable	Circulation or storage space.
B00L - R0006 - Withdrawal Space - 1hb - (11.97 SQM)	 Student Space (5)	
B00L - R0007 - Movement - (13.89 SQM)	Not Applicable	Circulation or storage space.
B00L - R0009 - Practical Activities - 1hb - (15.3 SQM)	 Student Space (7)	
B00L - R0010 - Home Base - (59.46 SQM) - Teaching Space: 1	 Student Space (27)	
B00L - R0011 - Home Base - (59.59 SQM) - Teaching Space: 1	 Student Space (27)	
B00L - R0012 - Practical Activities - 1hb - (15.16 SQM)	 Student Space (7)	
B00M - R0005 - Movement - (13.84 SQM)	Not Applicable	Circulation or storage space.
B00M - R0006 - Withdrawal Space - 1hb - (11.92 SQM)	 Student Space (5)	
B00M - R0007 - Movement - (13.84 SQM)	Not Applicable	Circulation or storage space.
B00M - R0009 - Practical Activities - 1hb - (15.29 SQM)	 Student Space (7)	
B00M - R0010 - Home Base - (59.46 SQM) - Teaching Space: 1	 Student Space (27)	
B00M - R0011 - Home Base - (59.46 SQM) - Teaching Space: 1	 Student Space (27)	
B00M - R0012 - Practical Activities - 1hb - (15.29 SQM)	 Student Space (7)	
B00O - R0004 - Special Programs Room - (33.77 SQM)	 Student Space (15)	
B00O - R0005 - Movement - (6.32 SQM)	Not Applicable	Circulation or storage space.
B00O - R0006 - Practical Activities - 1hb - (18.91 SQM)	 Student Space (8)	
B00O - R0007 - Home Base - (60.23 SQM) - Teaching Space: 1	 Student Space (27)	
B00O - R0008 - Withdrawal Space - 1hb - (9.12 SQM)	 Student Space (4)	
B00O - R0011 - Practical Activities - 1hb - (19.23 SQM)	 Student Space (8)	
B00O - R0012 - Withdrawal Space - 2hb - (11.87 SQM)	 Student Space (5)	
B00O - R0013 - Home Base - (60.8 SQM) - Teaching Space: 1	 Student Space (28)	
B00O - R0014 - Home Base - (60.8 SQM) - Teaching Space: 1	 Student Space (28)	
B00O - R0016 - Practical Activities - 1hb - (19.23 SQM)	 Student Space (8)	