


VENTILATION AUDIT REPORT

SCHOOL:	Mosman High School (8326)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	North Shore
LOCAL GOVERNMENT AREA:	Mosman

8326 - Mosman High School
Site Plan (12939)



1:618











Printed: 02-Oct-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Staff Study - (25.02 SQM)	Office (6)	
B00A - R0015 - Movement - (79.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Art Learning Space - (68.7 SQM) - Teaching Space: 1	Student Space (31)	
B00A - R0018 - Art Learning Space - (43.9 SQM) - Teaching Space: 1	Student Space (20)	
B00A - R0019 - Art Learning Space - (44.75 SQM) - Teaching Space: 1	Student Space (20)	
B00A - R1012 - Dark Room - (16.55 SQM)	Office (4)	
B00A - R1013 - Art Learning Space - (46.44 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R1014 - Art Learning Space - (63.92 SQM) - Teaching Space: 1	Student Space (29)	
B00A - R1016 - Movement - (80.85 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Principal Office - (25.13 SQM)	Office (6)	
B00B - R0027 - Deputy Principal Office - (14.76 SQM)	Office (3)	
B00B - R0028 - Deputy Principal Office - (9.09 SQM)	Office (2)	
B00B - R0030 - Tea Room - (12.75 SQM)	Not Applicable	Circulation or storage space.
B00B - R0031 - Administration - Clerical - (53.33 SQM)	Office (13)	
B00B - R0034 - Movement - (7.86 SQM)	Not Applicable	Circulation or storage space.
B00B - R0048 - Public Entry - (37.71 SQM)	Not Applicable	Circulation or storage space.
B00B - R0049 - Movement - (74.74 SQM)	Not Applicable	Circulation or storage space.
B00B - R0050 - Student Waiting - (16.82 SQM)	Not Applicable	Circulation or storage space.
B00B - R0054 - Movement - (36.83 SQM)	Not Applicable	Circulation or storage space.
B00B - R0062 - Multi-Purpose Space - (335.91 SQM)	Student Space (155)	
B00B - R0063 - Stage - (57.98 SQM)	Not Applicable	Circulation or storage space.
B00B - R0065 - Practice/Seminar - (23.57 SQM)	Not Applicable	Circulation or storage space.
B00B - R0066 - Tiered Learning Area - (78.07 SQM)	Student Space (36)	
B00B - R0070 - General Learning Space - (51.83 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0071 - General Learning Space - (49.27 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R0074 - Movement - (69.45 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Seminar/Study - (11.26 SQM)	Office (2)	
B00B - R1005 - Audio Visual Workroom - (26.35 SQM)	Student Space (12)	
B00B - R1010 - Main Entry - (46.42 SQM)	Not Applicable	Circulation or storage space.
B00B - R1011 - Main Area - (346.54 SQM)	Not Applicable	Circulation or storage space.
B00B - R1013 - Interview/Meeting - (7.87 SQM)	Office (1)	
B00B - R1017 - Seminar/Study - (11.34 SQM)	Office (2)	
B00B - R1023 - Movement - (24.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R1024 - Clinic - (19.07 SQM)	Office (4)	
B00C - R0005 - Movement - (124.56 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - General Assistants - (17.34 SQM)	Office (4)	
B00C - R0009 - Student Canteen - (61.08 SQM)	Not Applicable	Circulation or storage space.
B00C - R1005 - Music Learning Space - (65.06 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R1006 - Music Learning Space - (55.52 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R1010 - Practice/Seminar - (9.67 SQM)	Not Applicable	Circulation or storage space.
B00C - R1011 - Practice/Seminar - (6.56 SQM)	Not Applicable	Circulation or storage space.
B00C - R1014 - Practice/Seminar - (11.66 SQM)	Not Applicable	Circulation or storage space.
B00C - R1016 - Movement - (26.08 SQM)	Not Applicable	Circulation or storage space.
B00C - R1018 - Movement - (7.94 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - General Learning Space - (47.28 SQM) - Teaching Space: 1	Student Space (21)	
B00D - R0006 - General Learning Space - (47.16 SQM) - Teaching Space: 1	Student Space (21)	
B00D - R0007 - General Learning Space - (47.23 SQM) - Teaching Space: 1	Student Space (21)	
B00D - R0008 - General Learning Space - (47.09 SQM) - Teaching Space: 1	Student Space (21)	
B00D - R0009 - General Learning Space - (47.16 SQM) - Teaching Space: 1	Student Space (21)	
B00D - R0010 - General Learning Space - (47.17 SQM) - Teaching Space: 1	Student Space (21)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0017 - General Learning Space - (47.52 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R0025 - Staff Study - (16.57 SQM)	Office (4)	
B00D - R0027 - Computer Learning Space - (50.61 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0028 - Leading Teacher - (14.86 SQM)	Office (3)	
B00D - R0030 - Movement - (6.55 SQM)	Not Applicable	Circulation or storage space.
B00D - R0066 - Staff Study - (42.94 SQM)	Office (10)	
B00D - R0070 - General Learning Space - (31.04 SQM) - Teaching Space: 1	Student Space (14)	
B00D - R0071 - General Learning Space - (45.87 SQM) - Teaching Space: 1	Student Space (21)	
B00D - R0073 - Staff Study - (25.56 SQM)	Office (6)	
B00D - R0075 - General Learning Space - (47 SQM) - Teaching Space: 1	Student Space (21)	
B00D - R0077 - Commonroom - (23.31 SQM)	Office (5)	
B00D - R0079 - Staff Study - (30.27 SQM)	Office (7)	
B00D - R0081 - Movement - (361.63 SQM)	Not Applicable	Circulation or storage space.
B00D - R1002 - General Learning Space - (50.06 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1003 - General Learning Space - (49.84 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1004 - General Learning Space - (50.52 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1005 - General Learning Space - (49.53 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R1006 - General Learning Space - (49.8 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1007 - General Learning Space - (49.69 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1008 - General Learning Space - (49.65 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1009 - General Learning Space - (49.31 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R1011 - Computer Learning Space - (50.46 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1013 - General Learning Space - (49.66 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1042 - General Learning Space - (48.99 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R1043 - General Learning Space - (48.84 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R1044 - Staff Study - (32.22 SQM)	Office (8)	
B00D - R1046 - Staff Study - (94.38 SQM)	Office (23)	
B00D - R1047 - Tea Room - (6.95 SQM)	Not Applicable	Circulation or storage space.
B00D - R1048 - Staff Study - (45.47 SQM)	Office (11)	
B00D - R1050 - General Learning Space - (33.34 SQM) - Teaching Space: 1	Student Space (15)	
B00D - R1051 - General Learning Space - (49.92 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1052 - Interview/Office - Type 1 - (14.25 SQM)	Office (3)	
B00D - R1053 - Movement - (353.63 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Wood Technology L.S. - (93.38 SQM) - Teaching Space: 1	Student Space (43)	
B00E - R0002 - Wood Technology Bay - (33.52 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Wood Technology L.S. - (92.63 SQM) - Teaching Space: 1	Student Space (42)	
B00E - R0006 - Metal Technology Bay - (43.41 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Staff Study - (31.75 SQM)	Office (7)	
B00E - R0018 - Materials Technology L.S. - (54.95 SQM) - Teaching Space: 1	Student Space (25)	
B00E - R0019 - Computer Learning Space - (61.42 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0023 - Movement - (77.81 SQM)	Not Applicable	Circulation or storage space.
B00E - R0029 - Metal Technology L.S. - (86.87 SQM) - Teaching Space: 1	Student Space (40)	
B00E - R0030 - Welding Area - (5.37 SQM)	Not Applicable	Circulation or storage space.
B00E - R0031 - General Learning Space - (40.93 SQM) - Teaching Space: 1	Student Space (18)	
B00E - R1002 - Laboratory L.S. - (93.34 SQM) - Teaching Space: 1	Student Space (43)	
B00E - R1005 - Laboratory L.S. - (94.94 SQM) - Teaching Space: 1	Student Space (44)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R1006 - Laboratory L.S. - (93.87 SQM) - Teaching Space: 1	 Student Space (43)	
B00E - R1007 - Preparation - Science - (78.1 SQM)	Not Applicable	Circulation or storage space.
B00E - R1009 - Laboratory L.S. - (97.73 SQM) - Teaching Space: 1	 Student Space (45)	
B00E - R1013 - Growing/Breeding - (23.77 SQM)	Not Applicable	Circulation or storage space.
B00E - R1021 - Movement - (7.93 SQM)	Not Applicable	Circulation or storage space.
B00E - R1025 - Laboratory L.S. - (99.67 SQM) - Teaching Space: 1	 Student Space (46)	
B00E - R1028 - Staff Study - (36.84 SQM)	 Office (9)	
B00E - R1030 - Movement - (45.34 SQM)	Not Applicable	Circulation or storage space.
B00E - R2001 - Movement - (6.65 SQM)	Not Applicable	Circulation or storage space.
B00E - R2007 - Textiles Technology L.S. - (82.03 SQM) - Teaching Space: 1	 Student Space (38)	
B00E - R2012 - Food Technology L.S. - (107.53 SQM) - Teaching Space: 1	 Student Space (49)	
B00E - R2013 - Food/Research Space - (14.58 SQM)	Not Applicable	Circulation or storage space.
B00E - R2014 - Preparation - Materials - (21.53 SQM)	Not Applicable	Circulation or storage space.
B00E - R2015 - Food Technology L.S. - (106.51 SQM) - Teaching Space: 1	 Student Space (49)	
B00E - R2016 - Movement - (75.79 SQM)	Not Applicable	Circulation or storage space.
B00E - R2020 - Staff Study - (25.24 SQM)	 Office (6)	
OS 600 19543 - OS 600 19543 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 19544 - OS 600 19544 - Learning Unit - Small - (57 SQM)	 Student Space (26)	