

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Moss Vale Public School (2631)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Goulburn</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Wingecarribee</b>

2631 - Moss Vale Public School  
Site Plan (10747)



1:1,129







Printed: 17-Jun-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - M0001 - Movement - (7.11 SQM)	Not Applicable	Circulation or storage space.
B00A - M0002 - Movement - (6.48 SQM)	Not Applicable	Circulation or storage space.
B00A - M0003 - Movement - (6.57 SQM)	Not Applicable	Circulation or storage space.
B00A - R0001 - Home Base - (62.66 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0003 - Practical Activities - 1hb - (10.47 SQM)	● Student Space (4)	
B00A - R0004 - Practical Activities - 1hb - (10.32 SQM)	● Student Space (4)	
B00A - R0006 - Home Base - (63.08 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0009 - Movement - (46.5 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Movement - (6.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Practical Activities - 1hb - (10.53 SQM)	● Student Space (4)	
B00A - R0016 - Home Base - (63.99 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0017 - Practical Activities - 1hb - (10.32 SQM)	● Student Space (4)	
B00A - R0019 - Home Base - (63.67 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0020 - Staff Room Annexe - (5.32 SQM)	● Office (1)	
B00A - R0022 - Movement - (46.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Withdrawal Space - 1hb - (8.64 SQM)	● Student Space (4)	
B00A - R0026 - Movement - (8.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Practical Activities - 1hb - (9.94 SQM)	● Student Space (4)	
B00A - R0029 - Home Base - (64.39 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0030 - Practical Activities - 1hb - (9.94 SQM)	● Student Space (4)	
B00A - R0032 - Home Base - (64.14 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0033 - Staff Room Annexe - (5.15 SQM)	● Office (1)	
B00A - R0035 - Movement - (45.97 SQM)	Not Applicable	Circulation or storage space.
B00A - R0036 - Withdrawal Space - 1hb - (8.64 SQM)	● Student Space (4)	
B00A - R1005 - Home Base - (62.31 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R1007 - Practical Activities - 1hb - (10.41 SQM)	● Student Space (4)	
B00A - R1008 - Practical Activities - 1hb - (10.42 SQM)	● Student Space (4)	
B00A - R1010 - Home Base - (63.06 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R1012 - Withdrawal Space - 1hb - (12.75 SQM)	● Student Space (5)	
B00A - R1013 - Home Base - (86.43 SQM) - Teaching Space: 1	● Student Space (40)	
B00A - R1016 - Practical Activities - 1hb - (22.07 SQM)	● Student Space (10)	
B00A - R1019 - Home Base - (90.47 SQM) - Teaching Space: 1	● Student Space (41)	
B00A - R1020 - Withdrawal Space - 1hb - (15 SQM)	● Student Space (6)	
B00A - R1022 - Movement - (138.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R1026 - Home Base - (64.16 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R1027 - Practical Activities - 1hb - (10.25 SQM)	● Student Space (4)	
B00A - R1028 - Movement - (12.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R1029 - Practical Activities - 1hb - (10.25 SQM)	● Student Space (4)	
B00A - R1030 - Movement - (12.6 SQM)	Not Applicable	Circulation or storage space.
B00A - R1031 - Special Programs Room - (63.33 SQM)	● Student Space (29)	
B00A - R1038 - Withdrawal Space - 1hb - (15.12 SQM)	● Student Space (7)	
B00A - R1043 - Home Base - (64.71 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R1044 - Movement - (13.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R1045 - Practical Activities - 1hb - (10.2 SQM)	● Student Space (4)	
B00A - R1046 - Practical Activities - 1hb - (10.19 SQM)	● Student Space (4)	
B00A - R1047 - Movement - (12.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R1048 - Home Base - (65.06 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R1051 - Communal Space - (206.44 SQM)	● Student Space (95)	
B00A - R1056 - Raised Platform - (49.89 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R1067 - Home Base - M - (61.92 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R1068 - Practical Activities - M - 1hb - (10.71 SQM)	● Student Space (4)	
B00A - R1074 - Movement - (139.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R1075 - Movement - (174.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R1076 - Movement - (38.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R1078 - Home Base - (66.64 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R1079 - Practical Activities - 1hb - (16.61 SQM)	● Student Space (7)	
B00A - R1081 - Special Programs Room - (34.55 SQM)	● Student Space (16)	
B00A - R1082 - Home Base - (66.64 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R1083 - Withdrawal Space - 1hb - (21.79 SQM)	● Student Space (10)	
B00A - R1084 - Practical Activities - 1hb - (16.17 SQM)	● Student Space (7)	
B00A - R1087 - Canteen - (41.47 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Clerical Office - (10.93 SQM)	● Office (2)	
B00B - R0015 - Deputy Principal - (22.44 SQM)	● Office (5)	
B00B - R0017 - Clerical Office - (21.32 SQM)	● Office (5)	
B00B - R0020 - Staff Kitchen - (6.44 SQM)	● Office (1)	
B00B - R0021 - Entry Vestibule - (23.79 SQM)	Not Applicable	Circulation or storage space.
B00B - R0022 - Movement - (24.52 SQM)	Not Applicable	Circulation or storage space.
B00B - R0024 - Movement - (23.91 SQM)	Not Applicable	Circulation or storage space.
B00B - R0025 - Interview - (20.09 SQM)	● Office (5)	
B00B - R0026 - Principal - (22.42 SQM)	● Office (5)	
B00B - R0027 - Clerical Office - (33.28 SQM)	● Office (8)	
B00B - R0028 - Clerical/Printing - (7.96 SQM)	Not Applicable	Circulation or storage space.
B00B - R0029 - Sick Bay - (15.13 SQM)	● Student Space (7)	
B00C - R0001 - Home Base - (93.21 SQM) - Teaching Space: 1	● Student Space (43)	
B00C - R0002 - Movement - (17.98 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Special Programs Room - (47.15 SQM)	● Student Space (21)	
B00C - R0005 - Special Programs Room - (42.29 SQM)	● Student Space (19)	
B00C - R0010 - Staff Kitchen - (20.63 SQM)	● Office (5)	
B00C - R0011 - Movement - (20.81 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Staff Room Annexe - (15.25 SQM)	● Office (3)	
B00C - R0014 - Practical Activities - E - (13.57 SQM)	● Student Space (6)	
B00C - R0017 - Home Base - E - (32 SQM) - Teaching Space: 1	● Student Space (14)	
B00D - R0001 - Withdrawal Space - 1hb - (16.53 SQM)	● Student Space (7)	
B00D - R0003 - Home Base - (54.03 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0004 - Home Base - (53.73 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0005 - Special Programs Room - (16.38 SQM)	● Student Space (7)	
B00D - R0007 - Home Base - (53.3 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0008 - Home Base - M - (66.81 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R0009 - Staff Kitchen - (9.4 SQM)	● Office (2)	
B00D - R0015 - Movement - (17.57 SQM)	Not Applicable	Circulation or storage space.
B00D - R0016 - Movement - (17.27 SQM)	Not Applicable	Circulation or storage space.
B00D - R0017 - Movement - (8.17 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Movement - (16.8 SQM)	Not Applicable	Circulation or storage space.
B00D - R0019 - Movement - (16.05 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Home Base - (59.74 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0001 - Home Base - (58.83 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0003 - Withdrawal Space - 1hb - (9.03 SQM)	● Student Space (4)	
B00H - R0004 - Practical Activities - 2hb - (37.42 SQM)	● Student Space (17)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0009 - Home Base - (58.74 SQM) - Teaching Space: 1	 Student Space (27)	
B00H - R0010 - Withdrawal Space - 1hb - (9.46 SQM)	 Student Space (4)	
B00I - R0001 - Reading Area - (232.65 SQM)	 Student Space (107)	
NS 100 16304 - NS 100 16304 - Learning Unit - Single Primary/PAA - (76 SQM)	 Student Space (35)	
OS 510 13330 - OS 510 13330 - Staff Common Room - (114 SQM)	 Office (28)	
OS 602 13324 - OS 602 13324 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	