

VENTILATION AUDIT REPORT

SCHOOL:	Mount Annan High School (8286)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Camden
LOCAL GOVERNMENT AREA:	Camden



8286 - Mount Annan High School
Site Plan (13451)



1:1,463

Printed: 27-Apr-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - General Learning Space - Type 1 - (60.04 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0003 - Movement - (30.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - General Learning Space - Type 1 - (60.1 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0006 - Shared Learning Space - (144.11 SQM)	● Student Space (66)	
B00A - R0007 - General Learning Space - Type 2 - (66.7 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0009 - Movement - (17.77 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - General Learning Space - Type 1 - (58.94 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0014 - General Learning Space - Type 1 - (58.4 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0016 - Seminar - Type 1 - (24.28 SQM)	● Office (6)	
B00A - R0017 - General Learning Space - Type 1 - (59.77 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R1001 - General Learning Space - Type 1 - (60.03 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R1002 - Movement - (26.4 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - General Learning Space - Type 1 - (59.96 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R1005 - Shared Learning Space - (148.88 SQM)	● Student Space (69)	
B00A - R1007 - General Learning Space - Type 2 - (66.79 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R1009 - Movement - (10.54 SQM)	Not Applicable	Circulation or storage space.
B00A - R1012 - General Learning Space - Type 1 - (59.19 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R1013 - General Learning Space - Type 1 - (58.87 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R1015 - Seminar - Type 1 - (24.33 SQM)	● Office (6)	
B00A - R1016 - General Learning Space - Type 1 - (59.61 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0001 - Movement - (19.7 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Wood Technology Bay - (6.26 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - General Learning Space - Type 9 - (61.61 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0006 - General Learning Space - Type 8 - (61.45 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0009 - General Learning Space - Type 5 - (61.39 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0010 - General Learning Space - Type 4 - (61.17 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0011 - Movement - (134.41 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Movement - (8.4 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Dark Room - (26.73 SQM)	● Office (6)	
B00B - R0015 - Visual Arts Workshop - (99.87 SQM)	● Student Space (46)	
B00B - R0016 - Movement - (5.04 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Outdoor Workshop - (88.78 SQM)	Not Applicable	Circulation or storage space.
B00B - R0020 - Welding/Hot Metals Area - (11.06 SQM)	Not Applicable	Circulation or storage space.
B00B - R0023 - Materials Workshop - Type 2 - (112.95 SQM)	● Student Space (52)	
B00C - R0002 - Movement - (30.47 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - General Learning Space - Type 1 - (60.19 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0004 - Shared Learning Space - (151.48 SQM)	● Student Space (70)	
B00C - R0005 - General Learning Space - Type 1 - (60.4 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0006 - General Learning Space - Type 1 - (59.62 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0008 - Seminar - Type 1 - (24.28 SQM)	● Office (6)	
B00C - R0009 - General Learning Space - Type 1 - (59.01 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0010 - General Learning Space - Type 1 - (59.17 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0014 - Movement - (17.28 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - General Learning Space - Type 2 - (66.95 SQM) - Teaching Space: 1	● Student Space (31)	
B00C - R0018 - Movement - (67.13 SQM)	Not Applicable	Circulation or storage space.
B00C - R1002 - Movement - (26.78 SQM)	Not Applicable	Circulation or storage space.
B00C - R1003 - General Learning Space - Type 1 - (60.1 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R1005 - Shared Learning Space - (148.92 SQM)	● Student Space (69)	
B00C - R1006 - General Learning Space - Type 1 - (60.11 SQM) - Teaching Space: 1	● Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R1007 - General Learning Space - Type 1 - (59.68 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R1008 - Seminar - Type 1 - (24.36 SQM)	● Office (6)	
B00C - R1010 - General Learning Space - Type 1 - (58.76 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R1011 - General Learning Space - Type 1 - (59.52 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R1014 - Movement - (10.54 SQM)	Not Applicable	Circulation or storage space.
B00C - R1016 - General Learning Space - Type 2 - (66.8 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R0001 - Movement - (111 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - General Learning Space - Type 7 - (59.13 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0004 - Kitchen - Type 1 - (101.24 SQM)	● Student Space (46)	
B00D - R0006 - Preparation - Materials - (34.08 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Kitchen - Type 1 - (100.8 SQM)	● Student Space (46)	
B00D - R0012 - General Learning Space - Type 6 - (59.19 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0013 - General Learning Space - Type 7 - (59.05 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0014 - Seminar - Type 2 - (20.26 SQM)	● Office (5)	
B00D - R0015 - Seminar - Type 2 - (20.32 SQM)	● Office (5)	
B00D - R0016 - General Learning Space - Type 6 - (59.05 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0001 - Science Laboratory - (100.1 SQM)	● Student Space (46)	
B00E - R0002 - General Learning Space - Type 3 - (59.53 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0003 - Movement - (141.25 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Seminar - Type 2 - (22.31 SQM)	● Office (5)	
B00E - R0006 - General Learning Space - Type 3 - (58.52 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0012 - General Learning Space - Type 3 - (59.37 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0013 - General Learning Space - Type 3 - (59.54 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0014 - General Learning Space - Type 3 - (59.12 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0015 - General Learning Space - Type 3 - (59.96 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0016 - Movement - (10.53 SQM)	Not Applicable	Circulation or storage space.
B00E - R0018 - Science Laboratory - (99.74 SQM)	● Student Space (46)	
B00E - R0019 - Science Laboratory - (99.89 SQM)	● Student Space (46)	
B00E - R0020 - Preparation - Science - (49.21 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Staff Study - (199.48 SQM)	● Office (49)	
B00E - R1002 - Movement - (173.32 SQM)	Not Applicable	Circulation or storage space.
B00E - R1010 - Interview/Meeting - (13.5 SQM)	● Office (3)	
B00E - R1011 - Interview/Meeting - (13.46 SQM)	● Office (3)	
B00E - R1014 - Interview/Meeting - (13.42 SQM)	● Office (3)	
B00E - R1015 - Interview/Meeting - (13.45 SQM)	● Office (3)	
B00E - R1017 - Movement - (8.23 SQM)	Not Applicable	Circulation or storage space.
B00E - R1019 - Staff Study - (199.63 SQM)	● Office (49)	
B00E - R1020 - Movement - (37.15 SQM)	Not Applicable	Circulation or storage space.
B00E - R1021 - Staff Lounge - (102.46 SQM)	● Office (25)	
B00E - R1022 - Staff Kitchen - (9.82 SQM)	● Office (2)	
B00F - R0001 - Practice/Seminar - (19.92 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - General Learning Space - Type 1 - (59.63 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0005 - General Learning Space - Type 1 - (59.71 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0008 - Movement - (167.13 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Performance Workshop - (109.69 SQM)	● Student Space (50)	
B00F - R9003 - Movement - (215.01 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - General Learning Space - Type 1 - (57.91 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0003 - Movement - (5.43 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Movement - (29.53 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0010 - General Learning Space - Type 1 - (63.44 SQM) - Teaching Space: 1	● Student Space (29)	
B00G - R0011 - General Learning Space - Type 1 - (63.53 SQM) - Teaching Space: 1	● Student Space (29)	
B00G - R0014 - Movement - (75.56 SQM)	Not Applicable	Circulation or storage space.
B00G - R0016 - Movement - (8.48 SQM)	Not Applicable	Circulation or storage space.
B00G - R0021 - Practice/Seminar - (20.29 SQM)	Not Applicable	Circulation or storage space.
B00G - R0022 - Fitness Laboratory - (101.29 SQM)	● Student Space (46)	
B00G - R0024 - General Learning Space - Type 1 - (58.28 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R1001 - General Learning Space - Type 1 - (59.76 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R1002 - Movement - (5.47 SQM)	Not Applicable	Circulation or storage space.
B00G - R1003 - General Learning Space - Type 2 - (65.68 SQM) - Teaching Space: 1	● Student Space (30)	
B00G - R1004 - Shared Learning Space - (182.9 SQM)	● Student Space (84)	
B00G - R1005 - Movement - (28.78 SQM)	Not Applicable	Circulation or storage space.
B00G - R1006 - General Learning Space - Type 1 - (59.41 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R1010 - Movement - (8.24 SQM)	Not Applicable	Circulation or storage space.
B00G - R1011 - General Learning Space - Type 1 - (59.77 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R1012 - General Learning Space - Type 1 - (59.52 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R1013 - General Learning Space - Type 1 - (58.84 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R1015 - Seminar - Type 1 - (24.62 SQM)	○ Office (6)	
B00G - R1016 - General Learning Space - Type 1 - (59.77 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0002 - Senior Study - (59.34 SQM)	○ Office (14)	
B00H - R0003 - Main Area - (421.11 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Computer Learning Space - (65.62 SQM) - Teaching Space: 1	● Student Space (30)	
B00H - R0009 - Movement - (324.89 SQM)	Not Applicable	Circulation or storage space.
B00H - R0010 - Main Entry - (29.92 SQM)	Not Applicable	Circulation or storage space.
B00H - R0014 - Seminar - Type 3 - (12.87 SQM)	○ Office (3)	
B00H - R0015 - Seminar - Type 3 - (12.87 SQM)	○ Office (3)	
B00H - R0016 - Seminar - Type 3 - (12.87 SQM)	○ Office (3)	
B00H - R0022 - Interview/Office - Type 2 - (17.13 SQM)	○ Office (4)	
B00H - R0023 - Entry - (10.81 SQM)	Not Applicable	Circulation or storage space.
B00H - R9001 - Movement - (133 SQM)	Not Applicable	Circulation or storage space.
B00H - R9005 - Movement - (15.98 SQM)	Not Applicable	Circulation or storage space.
B00I - R0011 - Movement Studio - (158.75 SQM)	Not Applicable	Circulation or storage space.
B00I - R0015 - Gymnasium - (621.93 SQM)	● Student Space (288)	
B00I - R0020 - Movement - (14.85 SQM)	Not Applicable	Circulation or storage space.
B00I - R0026 - Student Canteen - (52.78 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Movement - (232.19 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Interview/Meeting - (12.93 SQM)	○ Office (3)	
B00J - R0003 - Interview/Meeting - (12.91 SQM)	○ Office (3)	
B00J - R0004 - Movement - (20.16 SQM)	Not Applicable	Circulation or storage space.
B00J - R0008 - Principal Office - (19.94 SQM)	○ Office (4)	
B00J - R0009 - Administration - Clerical - (98.25 SQM)	○ Office (24)	
B00J - R0010 - Clinic - Boys - (12.92 SQM)	○ Office (3)	
B00J - R0014 - Clinic - Girls - (12.88 SQM)	○ Office (3)	
B00J - R0015 - Interview/Office - Type 2 - (12.92 SQM)	○ Office (3)	
B00J - R0016 - Deputy Principal Office - (12.96 SQM)	○ Office (3)	
B00J - R0017 - Student Reception - (51.48 SQM)	Not Applicable	Circulation or storage space.
B00J - R0019 - Interview/Office - Type 1 - (12.83 SQM)	○ Office (3)	
B00J - R0020 - Interview/Office - Type 1 - (12.83 SQM)	○ Office (3)	
B00J - R0021 - Visitors Office - (12.88 SQM)	○ Office (3)	
B00J - R0022 - Public Reception - (26.03 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R0024 - Tea Room - (5.25 SQM)	Not Applicable	Circulation or storage space.
OS 600 19771 - OS 600 19771 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 19772 - OS 600 19772 - Learning Unit - Small - (57 SQM)	● Student Space (26)	