


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Mount Brown Public School (4423)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Shellharbour</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Wollongong</b>

4423 - Mount Brown Public School  
Site Plan (10549)












1:1,117

Printed: 14-Sep-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Movement - (29.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Canteen - (33.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Movement - (19.52 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Movement - (22.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Deputy Principal - (13.03 SQM)	Office (3)	
B00A - R0013 - Deputy Principal - (12.81 SQM)	Office (3)	
B00A - R0014 - Principal - (18.83 SQM)	Office (4)	
B00A - R0024 - Movement - (26.35 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Clerical Office - (12.53 SQM)	Office (3)	
B00A - R0028 - Sick Bay - (11.14 SQM)	Student Space (5)	
B00A - R0030 - Movement - (21.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R0031 - Duplicating Workroom - (26.61 SQM)	Office (6)	
B00A - R0032 - Entry Vestibule - (23.86 SQM)	Not Applicable	Circulation or storage space.
B00A - R0033 - Staff Room - (55.97 SQM)	Office (13)	
B00A - R0034 - Staff Kitchen - (7.72 SQM)	Office (1)	
B00A - R0035 - Movement - (7.51 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Movement - (41.17 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Special Programs Room - (74.95 SQM)	Student Space (34)	
B00B - R1001 - Movement - (61.19 SQM)	Not Applicable	Circulation or storage space.
B00B - R1003 - Home Base - (56 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R1004 - Home Base - (57.09 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0001 - Movement - (12.78 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Movement - (75.88 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Home Base - (56.65 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0006 - Practical Activities - 1hb - (17.73 SQM)	Student Space (8)	
B00C - R0007 - Practical Activities - 1hb - (19.13 SQM)	Student Space (8)	
B00C - R0008 - Home Base - (54.16 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R0009 - Home Base - (53.93 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R0010 - Practical Activities - 1hb - (19.21 SQM)	Student Space (8)	
B00C - R0013 - Practical Activities - 1hb - (17.84 SQM)	Student Space (8)	
B00C - R0014 - Home Base - (56.63 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0017 - Movement - (12.78 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Movement - (76.81 SQM)	Not Applicable	Circulation or storage space.
B00C - R1002 - Home Base - (54.18 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R1003 - Practical Activities - 1hb - (19.27 SQM)	Student Space (8)	
B00C - R1004 - Practical Activities - 1hb - (19.37 SQM)	Student Space (8)	
B00C - R1005 - Home Base - (54.59 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R1008 - Home Base - (54.74 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R1009 - Practical Activities - 1hb - (19.65 SQM)	Student Space (9)	
B00C - R1010 - Practical Activities - 1hb - (18.08 SQM)	Student Space (8)	
B00C - R1011 - Home Base - (55.56 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R0001 - Movement - (68.15 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Home Base - (86.07 SQM) - Teaching Space: 1	Student Space (39)	
B00D - R0007 - Home Base - (85.88 SQM) - Teaching Space: 1	Student Space (39)	
B00D - R1001 - Movement - (72.98 SQM)	Not Applicable	Circulation or storage space.
B00D - R1009 - Reading Area - (64.13 SQM)	Student Space (29)	
B00D - R1010 - Reading Area - (99.73 SQM)	Student Space (46)	
B00D - R1011 - Interview - (28.42 SQM)	Office (7)	
B00D - R1012 - Interview - (13.91 SQM)	Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R1013 - Reading Area - (137.29 SQM)	 Student Space (63)	
B00E - R0003 - Home Base - (57.18 SQM) - Teaching Space: 1	 Student Space (26)	
B00E - R0005 - Movement - (28.56 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Movement - (8.23 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Movement - (8.24 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Movement - (5.93 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Staff Room Annexe - (21.77 SQM)	 Office (5)	
B00F - R0005 - Interview - (16.57 SQM)	 Office (4)	
B00F - R0008 - Home Base - (57.4 SQM) - Teaching Space: 1	 Student Space (26)	
B00F - R0009 - Practical Activities - 1hb - (12.19 SQM)	 Student Space (5)	
B00F - R0012 - Home Base - (57.11 SQM) - Teaching Space: 1	 Student Space (26)	
B00F - R0014 - Movement - (89.73 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Communal Space - (145.94 SQM)	 Student Space (67)	
B00G - R0002 - Raised Platform - (61.28 SQM)	Not Applicable	Circulation or storage space.
B00G - R0016 - Movement - (6.09 SQM)	Not Applicable	Circulation or storage space.
B00G - R0017 - Movement - (11.46 SQM)	Not Applicable	Circulation or storage space.
B00G - R0018 - Movement - (11.83 SQM)	Not Applicable	Circulation or storage space.
OS 601 13641 - OS 601 13641 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	