

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Mount Colah Public School (3885)</b>
<b>AMU REGION:</b>	<b>Northern Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Hornsby</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Hornsby</b>

3885 - Mount Colah Public School  
Site Plan (10488)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0005 - Staff Room Annexe - (27.96 SQM)	Office (6)	
B00A - R0028 - Staff Room - (49.42 SQM)	Office (12)	
B00A - R0029 - Staff Kitchen - (6.88 SQM)	Office (1)	
B00A - R0030 - Movement - (38.45 SQM)	Not Applicable	Circulation or storage space.
B00A - R0037 - Principal - (17.4 SQM)	Office (4)	
B00A - R0038 - Clerical Office - (56.33 SQM)	Office (14)	
B00A - R0039 - Movement - (22.24 SQM)	Not Applicable	Circulation or storage space.
B00A - R0040 - Entry Vestibule - (22.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R0041 - Interview - (10.51 SQM)	Office (2)	
B00A - R0042 - Sick Bay - (8.53 SQM)	Student Space (3)	
B00A - R0044 - Deputy Principal - (13.4 SQM)	Office (3)	
B00A - R0045 - Duplicating Workroom - (13.02 SQM)	Office (3)	
B00A - R0046 - Movement - (96.9 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Home Base - (56.81 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0006 - Movement - (6 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Home Base - (56.8 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R9005 - Special Programs Room - (51.01 SQM)	Student Space (23)	
B00C - R0001 - Home Base - (56.2 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0006 - Movement - (5.85 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Home Base - (52.43 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0002 - Home Base - (52.57 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0005 - Movement - (43.79 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Movement - (21.78 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Home Base - (52.29 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0004 - Home Base - (52 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0006 - Movement - (84.77 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Movement - (28.42 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Canteen - (49.2 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Home Base - (57.09 SQM) - Teaching Space: 1	Student Space (26)	
B00H - R0004 - Deputy Principal - (20.83 SQM)	Office (5)	
B00H - R0007 - Home Base - (57.17 SQM) - Teaching Space: 1	Student Space (26)	
B00H - R0010 - Movement - (13.13 SQM)	Not Applicable	Circulation or storage space.
B00I - R0015 - Movement - (20.5 SQM)	Not Applicable	Circulation or storage space.
B00I - R0018 - Outdoor Learning Area - (63.56 SQM)	Not Applicable	Circulation or storage space.
B00I - R0020 - Home Base - (71.51 SQM) - Teaching Space: 1	Student Space (33)	
B00I - R0021 - Home Base - (71.18 SQM) - Teaching Space: 1	Student Space (33)	
B00I - R9004 - Movement - (5.85 SQM)	Not Applicable	Circulation or storage space.
B00L - R0010 - Reading Area - (231.45 SQM)	Student Space (107)	
B00L - R0011 - Movement - (83.81 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Home Base - (60.01 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R0003 - Practical Activities - 1hb - (18.94 SQM)	Student Space (8)	
B00M - R0004 - Withdrawal Space - 2hb - (11.58 SQM)	Student Space (5)	
B00M - R0005 - Home Base - (59.6 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R0007 - Practical Activities - 1hb - (19.07 SQM)	Student Space (8)	
B00M - R0008 - Movement - (49.53 SQM)	Not Applicable	Circulation or storage space.
B00O - R0002 - Staff Kitchen - (10.7 SQM)	Office (2)	
B00O - R0004 - Staff Room Annexe - (5.51 SQM)	Office (1)	
B00P - R0006 - Movement - (6.72 SQM)	Not Applicable	Circulation or storage space.
B00P - R0010 - Movement - (26.64 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00P - R0011 - Raised Platform - (53.15 SQM)	Not Applicable	Circulation or storage space.
B00P - R0012 - Movement - (6.32 SQM)	Not Applicable	Circulation or storage space.
B00P - R0014 - Movement - (8.26 SQM)	Not Applicable	Circulation or storage space.
B00P - R0015 - Movement - (6.77 SQM)	Not Applicable	Circulation or storage space.
B00P - R0018 - Communal Space - (201.13 SQM)	● Student Space (93)	
B00Q - R0001 - Practical Activities - (19.87 SQM)	● Student Space (9)	
B00Q - R0002 - Home Base - (60.27 SQM) - Teaching Space: 1	● Student Space (27)	
B00Q - R0004 - Withdrawal Space - 2hb - (11.61 SQM)	● Student Space (5)	
B00Q - R0005 - Practical Activities - (18.99 SQM)	● Student Space (8)	
B00Q - R0006 - Home Base - (59.26 SQM) - Teaching Space: 1	● Student Space (27)	
B00Q - R0008 - Practical Activities - (18.9 SQM)	● Student Space (8)	
B00Q - R0009 - Home Base - (59.49 SQM) - Teaching Space: 1	● Student Space (27)	
B00Q - R0011 - Withdrawal Space - 2hb - (11.61 SQM)	● Student Space (5)	
B00Q - R0012 - Practical Activities - (19.23 SQM)	● Student Space (8)	
B00Q - R0013 - Home Base - (60.25 SQM) - Teaching Space: 1	● Student Space (27)	
B00Q - R0015 - Special Programs Room - Type 1 - (37.22 SQM)	● Student Space (17)	
B00R - R0001 - Special Programs Room - (11.31 SQM)	● Student Space (5)	
B00R - R0002 - Special Programs Room - (22.92 SQM)	● Student Space (10)	
B00R - R0003 - Special Programs Room - (11.22 SQM)	● Student Space (5)	
OS 602 13031 - OS 602 13031 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	