

VENTILATION AUDIT REPORT

SCHOOL:	Mount Hutton Public School (3939)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Charlestown
LOCAL GOVERNMENT AREA:	Lake Macquarie

3939 - Mount Hutton Public School
Site Plan (11449)



1:877

Printed: 30-Mar-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Staff Room - (24.74 SQM)	Office (6)	
B00A - R0008 - Staff Room Annexe - (14.84 SQM)	Office (3)	
B00A - R0009 - Movement - (69.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Home Base - (53.66 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0011 - Home Base - (53.59 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0012 - Home Base - (53.51 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0013 - Home Base - (58.45 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0014 - Practical Activities - 1hb - (10.08 SQM)	Student Space (4)	
B00A - R0015 - Withdrawal Space - 1hb - (18.71 SQM)	Student Space (8)	
B00A - R0016 - Interview - (16.01 SQM)	Office (4)	
B00A - R0017 - Movement - (16.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Movement - (5.18 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (41.45 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Movement - (9.17 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Home Base - (55.29 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0005 - Home Base - (87.51 SQM) - Teaching Space: 1	Student Space (40)	
B00B - R0007 - Movement - (11.92 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Movement - (7.67 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Movement - (9.48 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Duplicating Workroom - (15.64 SQM)	Office (3)	
B00E - R0003 - Principal - (23.07 SQM)	Office (5)	
B00E - R0004 - Clerical Office - (16.85 SQM)	Office (4)	
B00E - R0006 - Entry Vestibule - (14.28 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Movement - (10.16 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Home Base - (60.34 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0009 - Practical Activities - 1hb - (19.45 SQM)	Student Space (9)	
B00E - R0010 - Staff Kitchen - (9.34 SQM)	Office (2)	
B00E - R0014 - Study Annexe - (10.43 SQM)	Office (2)	
B00E - R0015 - Practical Activities - (8.3 SQM)	Student Space (3)	
B00F - R0001 - Canteen - (27.74 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Movement - (9.69 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Movement - (113.72 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Communal Space - (143.66 SQM)	Student Space (66)	
B00G - R0003 - Movement - (5.6 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Raised Platform - (62.14 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Movement - (13.5 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Reading Area - (91.47 SQM)	Student Space (42)	
OS 602 15433 - OS 602 15433 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 606 10476 - OS 606 10476 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 621 19717 - OS 621 19717 - Learning Unit Single - PWD - (95 SQM)	Student Space (44)	