

VENTILATION AUDIT REPORT

SCHOOL:	Mount Kembla Public School (2643)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Wollongong
LOCAL GOVERNMENT AREA:	Wollongong

2643 - Mount Kembla Public School
Site Plan (10656)



1:885

Printed: 02-Dec-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (54.49 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R0002 - Movement - (11.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Practical Activities - 1hb - (8.04 SQM)	● Student Space (3)	
B00A - R0007 - Home Base - (54.56 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R1005 - Home Base - (56.02 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R1006 - Home Base - (55.88 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R1007 - Movement - (22.61 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Home Base - (58.67 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0003 - Home Base - (59.33 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0009 - Movement - (59.56 SQM)	Not Applicable	Circulation or storage space.
B00B - R1005 - Movement - (8.24 SQM)	Not Applicable	Circulation or storage space.
B00B - R1008 - Home Base - (59.33 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R1011 - Movement - (38.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R1013 - Special Programs Room - (29.33 SQM)	● Student Space (13)	
B00C - R0001 - Movement - (12.87 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Sick Bay - (5.59 SQM)	● Student Space (2)	
B00C - R0005 - Movement - (12.82 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Principal - (18.01 SQM)	● Office (4)	
B00C - R0009 - Movement - (7.17 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - Entry Vestibule - (8.1 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Clerical Office - (14.81 SQM)	● Office (3)	
B00C - R0012 - Staff Room - (20.25 SQM)	● Office (5)	
B00C - R0013 - Staff Kitchen - (13.42 SQM)	● Office (3)	
B00C - R0014 - Duplicating Workroom - (12.92 SQM)	● Office (3)	
B00E - R0010 - Movement - (41.69 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Reading Area - (91.69 SQM)	● Student Space (42)	
OS 801 13261 - OS 801 13261 - FSU - (57 SQM)	Not Applicable	Circulation or storage space.