

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Mount Kuring-gai Public School (4049)</b>
<b>AMU REGION:</b>	<b>Northern Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Hornsby</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Hornsby</b>

4049 - Mount Kuring-gai Public School  
Site Plan (11864)



1:550

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0006 - Home Base - (66.82 SQM) - Teaching Space: 1	● Student Space (31)	
B00B - R0012 - Movement - (82.99 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Reading Area - (92.99 SQM)	● Student Space (43)	
B00B - R0017 - Home Base - (72.58 SQM) - Teaching Space: 1	● Student Space (33)	
B00C - R0001 - Home Base - (57.11 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0004 - Movement - (7.23 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Home Base - (57.11 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0001 - Movement - (23.88 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Home Base - (58.09 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0010 - Practical Activities - (21.76 SQM)	● Student Space (10)	
B00F - R0001 - Canteen - (9.27 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Home Base - (60.3 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0002 - Home Base - (60.36 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0003 - Practical Activities - 1hb - (18.08 SQM)	● Student Space (8)	
B00G - R0004 - Practical Activities - 1hb - (18.23 SQM)	● Student Space (8)	
B00G - R0005 - Withdrawal Space - 2hb - (11.65 SQM)	● Student Space (5)	
B00H - R0001 - Communal Space - (113.54 SQM)	● Student Space (52)	
B00H - R0005 - Canteen - (29.4 SQM)	Not Applicable	Circulation or storage space.
OS 502 15546 - OS 502 15546 - Admin Staff/Principal/Clerk/Dup/Clinic - (152 SQM)	● Office (38)	
OS 606 13154 - OS 606 13154 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	