

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Mount Pritchard East Public School (4210)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Cabramatta</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Fairfield</b>

4210 - Mount Pritchard East Public School  
Site Plan (10547)



1:964

Printed: 14-Jul-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Deputy Principal - (15.43 SQM)	Office (3)	
B00A - R0005 - Movement - (15.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Staff Room Annexe - (19.42 SQM)	Office (4)	
B00A - R0007 - Movement - (11.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Home Base - (44.34 SQM) - Teaching Space: 1	Student Space (20)	
B00A - R0014 - Practical Activities - 1hb - (12.25 SQM)	Student Space (5)	
B00A - R0015 - Practical Activities - 1hb - (12.24 SQM)	Student Space (5)	
B00A - R0016 - Home Base - (44.28 SQM) - Teaching Space: 1	Student Space (20)	
B00A - R0019 - Movement - (6.37 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Home Base - (58.38 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0005 - Special Programs Room - (56.5 SQM)	Student Space (26)	
B00B - R0006 - Staff Room - (56.74 SQM)	Office (14)	
B00B - R0009 - Movement - (6.34 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Home Base - (58.31 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0014 - Canteen - (31.19 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Movement - (18.99 SQM)	Not Applicable	Circulation or storage space.
B00B - R0019 - Movement - (81.53 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Home Base - (58.45 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0004 - Movement - (6.3 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Home Base - (57.03 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0009 - Home Base - (57.19 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0001 - Home Base - (57.78 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0004 - Movement - (6.41 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Home Base - (113.69 SQM) - Teaching Space: 1	Student Space (52)	
B00D - R0011 - Movement - (5.36 SQM)	Not Applicable	Circulation or storage space.
B00D - R0015 - Movement - (5.82 SQM)	Not Applicable	Circulation or storage space.
B00D - R0016 - Deputy Principal - (11.59 SQM)	Office (2)	
B00E - R0001 - Movement - (8.44 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Entry Vestibule - (13.77 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Principal - (17.2 SQM)	Office (4)	
B00E - R0007 - Clerical Office - (33.98 SQM)	Office (8)	
B00E - R0014 - Movement - (6.39 SQM)	Not Applicable	Circulation or storage space.
B00E - R0015 - Movement - (6.48 SQM)	Not Applicable	Circulation or storage space.
B00E - R0019 - Reading Area - (114.73 SQM)	Student Space (53)	
B00E - R0023 - Sick Bay - (10.49 SQM)	Student Space (4)	
B00E - R0024 - Duplicating Workroom - (15.81 SQM)	Office (3)	
B00E - R0025 - Interview - (12.43 SQM)	Office (3)	
B00F - R0001 - Home Base - (57.45 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0003 - Movement - (6.41 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Home Base - (57.45 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R0006 - Movement - (42.13 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Communal Space - (145.65 SQM)	Student Space (67)	
B00I - R0002 - Raised Platform - (61.95 SQM)	Not Applicable	Circulation or storage space.
B00I - R0016 - Movement - (5.74 SQM)	Not Applicable	Circulation or storage space.
B00I - R0018 - Movement - (12.08 SQM)	Not Applicable	Circulation or storage space.