

VENTILATION AUDIT REPORT

SCHOOL:	Mount Pritchard Public School (2648)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Cabramatta
LOCAL GOVERNMENT AREA:	Fairfield

2648 - Mount Pritchard Public School
Site Plan (11751)



1:1,163

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0021 - Staff Room - (22.51 SQM)	Office (5)	
B00A - R0022 - Staff Kitchen - (5.33 SQM)	Office (1)	
B00A - R0024 - Movement - (20.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R0031 - Principal - (18.15 SQM)	Office (4)	
B00A - R0033 - Clerical/Printing - (10.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R0036 - Sick Bay - (6.55 SQM)	Student Space (3)	
B00A - R0037 - Clerical Office - (25.14 SQM)	Office (6)	
B00A - R0038 - Interview - (9.61 SQM)	Office (2)	
B00A - R0040 - Entry Vestibule - (19.08 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Staff Room - (56.91 SQM)	Office (14)	
B00B - R0008 - Staff Kitchen - (11.29 SQM)	Office (2)	
B00B - R0009 - Staff Room Annexe - (28.49 SQM)	Office (7)	
B00B - R0014 - Movement - (6.58 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Movement - (10.92 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Home Base - (55.18 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R0012 - Practical Activities - 1hb - (9.82 SQM)	Student Space (4)	
B00C - R0013 - Practical Activities - 1hb - (9.57 SQM)	Student Space (4)	
B00C - R0014 - Home Base - (54.95 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R1004 - Movement - (11.33 SQM)	Not Applicable	Circulation or storage space.
B00C - R1009 - Home Base - (54.96 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R1010 - Practical Activities - 1hb - (9.68 SQM)	Student Space (4)	
B00C - R1011 - Practical Activities - 1hb - (9.55 SQM)	Student Space (4)	
B00C - R1012 - Home Base - (54.84 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R0005 - Movement - (10.96 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Home Base - (54.69 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R0012 - Practical Activities - 1hb - (9.66 SQM)	Student Space (4)	
B00D - R0013 - Practical Activities - 1hb - (9.75 SQM)	Student Space (4)	
B00D - R0014 - Home Base - (54.76 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R1004 - Movement - (11.23 SQM)	Not Applicable	Circulation or storage space.
B00D - R1009 - Home Base - (54.68 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R1010 - Practical Activities - 1hb - (9.45 SQM)	Student Space (4)	
B00D - R1011 - Practical Activities - 1hb - (9.54 SQM)	Student Space (4)	
B00D - R1012 - Home Base - (54.68 SQM) - Teaching Space: 1	Student Space (25)	
B00E - R0005 - Movement - (12.34 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Home Base - (55.04 SQM) - Teaching Space: 1	Student Space (25)	
B00E - R0012 - Practical Activities - 1hb - (9.41 SQM)	Student Space (4)	
B00E - R0013 - Practical Activities - 1hb - (9.45 SQM)	Student Space (4)	
B00E - R0014 - Home Base - (55.08 SQM) - Teaching Space: 1	Student Space (25)	
B00E - R1004 - Movement - (12.34 SQM)	Not Applicable	Circulation or storage space.
B00E - R1009 - Home Base - (54.79 SQM) - Teaching Space: 1	Student Space (25)	
B00E - R1011 - Practical Activities - 1hb - (9.68 SQM)	Student Space (4)	
B00E - R1013 - Practical Activities - 1hb - (9.69 SQM)	Student Space (4)	
B00E - R1014 - Home Base - (54.87 SQM) - Teaching Space: 1	Student Space (25)	
B00E - R9002 - Movement - (26.1 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Communal Space - (192.98 SQM)	Student Space (89)	
B00F - R0002 - Raised Platform - (21.63 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Movement - (31.07 SQM)	Not Applicable	Circulation or storage space.
B00F - R0011 - Canteen - (49.85 SQM)	Not Applicable	Circulation or storage space.
B00F - R0013 - Movement - (42.17 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0014 - Movement - (14.78 SQM)	Not Applicable	Circulation or storage space.
B00F - R0022 - Seminar/Study - (15.05 SQM)	 Office (3)	
B00F - R0023 - Seminar/Study - (14.08 SQM)	 Office (3)	
B00F - R0024 - Reading Area - (246.03 SQM)	 Student Space (114)	
B00F - R0025 - Outdoor Learning Area - (28.23 SQM)	Not Applicable	Circulation or storage space.
B00F - R9003 - Movement - (12.28 SQM)	Not Applicable	Circulation or storage space.
B00F - R9004 - Movement - (61.82 SQM)	Not Applicable	Circulation or storage space.
B00F - R9005 - Raised Platform - (27.94 SQM)	Not Applicable	Circulation or storage space.
B00F - R9006 - Communal Space - (101.32 SQM)	 Student Space (47)	
B00F - R9007 - Practical Activities - 1hb - (14.93 SQM)	 Student Space (6)	
B00F - R9008 - Home Base - (60.81 SQM) - Teaching Space: 1	 Student Space (28)	
B00F - R9009 - Practical Activities - 1hb - (17.14 SQM)	 Student Space (7)	
B00F - R9010 - Movement - (27.85 SQM)	Not Applicable	Circulation or storage space.
B00F - R9012 - Movement - (14.84 SQM)	Not Applicable	Circulation or storage space.
B00F - R9013 - Home Base - (56.13 SQM) - Teaching Space: 1	 Student Space (26)	
B00F - R9014 - Practical Activities - 1hb - (19.03 SQM)	 Student Space (8)	
B00G - R0017 - Home Base - (58.27 SQM) - Teaching Space: 1	 Student Space (27)	
B00G - R0018 - Movement - (9.1 SQM)	Not Applicable	Circulation or storage space.
B00G - R0019 - Practical Activities - 1hb - (5.1 SQM)	 Student Space (2)	
B00G - R0021 - Practical Activities - 1hb - (5.15 SQM)	 Student Space (2)	
B00G - R0023 - Home Base - (84.77 SQM) - Teaching Space: 1	 Student Space (39)	
B00G - R0024 - Home Base - (84.61 SQM) - Teaching Space: 1	 Student Space (39)	
B00G - R0026 - Practical Activities - 1hb - (10.31 SQM)	 Student Space (4)	
B00I - R0001 - Home Base - (65.73 SQM) - Teaching Space: 1	 Student Space (30)	
B00I - R0026 - Special Programs Room - (16.99 SQM)	 Student Space (7)	
B00I - R0030 - Home Base - (65.29 SQM) - Teaching Space: 1	 Student Space (30)	
B00I - R0031 - Practical Activities - 1hb - (11.52 SQM)	 Student Space (5)	
B00I - R0033 - Movement - (18.41 SQM)	Not Applicable	Circulation or storage space.
B00I - R0034 - Practical Activities - 1hb - (8.05 SQM)	 Student Space (3)	
B00I - R0036 - Home Base - (96.74 SQM) - Teaching Space: 1	 Student Space (44)	
B00I - R0037 - Home Base - (97.49 SQM) - Teaching Space: 1	 Student Space (45)	
B00I - R0039 - Practical Activities - 1hb - (12.34 SQM)	 Student Space (5)	
B00I - R0040 - Movement - (9.25 SQM)	Not Applicable	Circulation or storage space.
B00I - R0041 - Home Base - (64.02 SQM) - Teaching Space: 1	 Student Space (29)	
B00K - R0001 - Home Base - (52.57 SQM) - Teaching Space: 1	 Student Space (24)	
B00K - R0002 - Home Base - (52.57 SQM) - Teaching Space: 1	 Student Space (24)	
B00L - R0001 - Special Programs Room - (8.88 SQM)	 Student Space (4)	
B00L - R0004 - Home Base - (53.61 SQM) - Teaching Space: 1	 Student Space (24)	
B00L - R0005 - Movement - (17.66 SQM)	Not Applicable	Circulation or storage space.