

VENTILATION AUDIT REPORT

SCHOOL:	Mount Riverview Public School (4435)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Blue Mountains
LOCAL GOVERNMENT AREA:	Blue Mountains

4435 - Mount Riverview Public School
Site Plan (10570)



1:1,039

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (12.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Canteen - (22.89 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Home Base - (93.78 SQM) - Teaching Space: 1	● Student Space (43)	
B00A - R0013 - Home Base - (94.19 SQM) - Teaching Space: 1	● Student Space (43)	
B00A - R0017 - Staff Room - (22.53 SQM)	○ Office (5)	
B00A - R0018 - Movement - (6.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Entry Vestibule - (5.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Clerical Office - (7.53 SQM)	○ Office (1)	
B00A - R0023 - Duplicating Workroom - (11.39 SQM)	○ Office (2)	
B00A - R0025 - Staff Room - (14.41 SQM)	○ Office (3)	
B00B - R0001 - Movement - (85.72 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Home Base - (62.27 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0009 - Home Base - (62.17 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0010 - Home Base - (62.01 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0017 - Home Base - (62.25 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R0001 - Movement - (7.85 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Practical Activities - 1hb - (15.78 SQM)	● Student Space (7)	
B00E - R0002 - Home Base - (61.73 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R0004 - Practical Activities - 1hb - (15.69 SQM)	● Student Space (7)	
B00E - R0005 - Home Base - (61.9 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R0006 - Home Base - (61.3 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R0007 - Practical Activities - 1hb - (16.4 SQM)	● Student Space (7)	
B00E - R0008 - Withdrawal Space - 1hb - (15.21 SQM)	● Student Space (7)	
B00E - R0010 - Practical Activities - 1hb - (15.78 SQM)	● Student Space (7)	
B00E - R0011 - Home Base - (62.05 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0010 - Staff Kitchen - (16.94 SQM)	○ Office (4)	
B00G - R0014 - Movement - (14.4 SQM)	Not Applicable	Circulation or storage space.
B00G - R0015 - Raised Platform - (54.94 SQM)	Not Applicable	Circulation or storage space.
B00G - R0016 - Movement - (14.3 SQM)	Not Applicable	Circulation or storage space.
B00G - R0017 - Communal Space - (140.91 SQM)	● Student Space (65)	
B00G - R0019 - Movement - (35 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Movement - (43.26 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Principal - (12.69 SQM)	○ Office (3)	
B00H - R0009 - Interview - (12.87 SQM)	○ Office (3)	
B00H - R0010 - Entry Vestibule - (14.91 SQM)	Not Applicable	Circulation or storage space.
B00H - R0011 - Clerical/Printing - (22.63 SQM)	Not Applicable	Circulation or storage space.
B00H - R0012 - Sick Bay - (8.93 SQM)	● Student Space (4)	
B00H - R0014 - Staff Room - (24.6 SQM)	○ Office (6)	
B00H - R0015 - Staff Room Annexe - (16.03 SQM)	○ Office (4)	
B00I - R0001 - Reading Area - (168.18 SQM)	● Student Space (78)	