


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Mount View High School (8574)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Cessnock</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Cessnock</b>

8574 - Mount View High School  
Site Plan (10491)



1:1,962

Printed: 24-Nov-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Music Learning Space - (77.32 SQM) - Teaching Space: 1	Student Space (35)	
B00A - R0002 - Practice/Seminar - (27.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Laboratory L.S. - (94.59 SQM) - Teaching Space: 1	Student Space (43)	
B00A - R0006 - Practice/Seminar - (24.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Music Learning Space - (59.3 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0009 - Staff Study - (17.55 SQM)	Office (4)	
B00A - R0010 - Movement - (68.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Laboratory L.S. - (92.27 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R0013 - Preparation - (48.72 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Laboratory L.S. - (94.87 SQM) - Teaching Space: 1	Student Space (44)	
B00A - R0016 - Laboratory L.S. - (92.67 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R0017 - Laboratory L.S. - (97.51 SQM) - Teaching Space: 1	Student Space (45)	
B00A - R0018 - Preparation - (36.22 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Laboratory L.S. - (97.53 SQM) - Teaching Space: 1	Student Space (45)	
B00A - R0020 - Movement - (36.3 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Food Technology L.S. - (104.36 SQM) - Teaching Space: 1	Student Space (48)	
B00A - R0022 - Preparation - (21.32 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Food Technology L.S. - (105.25 SQM) - Teaching Space: 1	Student Space (48)	
B00A - R0025 - Materials Technology L.S. - (91.82 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R0026 - Wood Technology Bay - (35.43 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Materials Technology L.S. - (92.52 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R0030 - Materials Technology L.S. - (83.76 SQM) - Teaching Space: 1	Student Space (38)	
B00A - R0031 - Metal Technology Bay - (35.01 SQM)	Not Applicable	Circulation or storage space.
B00A - R0033 - Materials Technology L.S. - (80.77 SQM) - Teaching Space: 1	Student Space (37)	
B00A - R0039 - Design L.S. - (74.93 SQM) - Teaching Space: 1	Student Space (34)	
B00A - R0040 - Staff Study - (22.22 SQM)	Office (5)	
B00A - R0043 - Design L.S. - (75.22 SQM) - Teaching Space: 1	Student Space (34)	
B00A - R0048 - Movement - (77.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R0049 - Movement - (103.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R0051 - Welding Area - (9.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R0052 - Movement - (35.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R0053 - Movement - (76.72 SQM)	Not Applicable	Circulation or storage space.
B00A - R0054 - Movement - (402.89 SQM)	Not Applicable	Circulation or storage space.
B00A - R0055 - Interview/Meeting - (23.83 SQM)	Office (5)	
B00A - R0060 - Music Learning Space - (106.48 SQM) - Teaching Space: 1	Student Space (49)	
B00B - R0004 - Stage - (27.24 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Performance Workspace - (77.82 SQM) - Teaching Space: 1	Student Space (36)	
B00B - R0007 - Interview/Office - Type 1 - (16.8 SQM)	Office (4)	
B00B - R0009 - Movement - (19.8 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Staff Study - (26.44 SQM)	Office (6)	
B00B - R1002 - Design L.S. - (55.57 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R1003 - Computer Learning Space - (40.28 SQM) - Teaching Space: 1	Student Space (18)	
B00B - R1004 - General Learning Space - (47.18 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R1005 - General Learning Space - (46.94 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R1006 - General Learning Space - (46.94 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R1007 - Staff Study - (25.5 SQM)	Office (6)	
B00B - R1009 - Staff Study - (15.63 SQM)	Office (3)	
B00B - R1010 - Movement - (77.88 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Art Learning Space - (61.44 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0002 - Staff Study - (19.15 SQM)	Office (4)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0004 - Art Learning Space - (59.76 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0011 - Darkroom Space - (28.15 SQM)	● Office (7)	
B00C - R0012 - Art Learning Space - (59.37 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0013 - Workshop - (60.95 SQM)	● Student Space (28)	
B00C - R0014 - Movement - (131.73 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - Interview/Office - Type 1 - (15.24 SQM)	● Office (3)	
B00C - R0018 - Staff Study - (42.33 SQM)	● Office (10)	
B00C - R0019 - General Learning Space - (50 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R0021 - Ancillary Staff - (24.09 SQM)	● Office (6)	
B00C - R0022 - Student Reception - (16.6 SQM)	Not Applicable	Circulation or storage space.
B00C - R0023 - Clinic - Girls - (14.91 SQM)	● Office (3)	
B00C - R0026 - Leading Teacher - (14.87 SQM)	● Office (3)	
B00C - R0027 - Administration - Clerical - (13.74 SQM)	● Office (3)	
B00C - R0028 - Duplicating Workroom - (25.93 SQM)	● Office (6)	
B00C - R0029 - Administration - Clerical - (12.03 SQM)	● Office (3)	
B00C - R0030 - Principal Office - (18.14 SQM)	● Office (4)	
B00C - R0031 - Interview/Office - Type 1 - (13.07 SQM)	● Office (3)	
B00C - R0032 - Administration - Clerical - (34.84 SQM)	● Office (8)	
B00C - R0034 - Deputy Principal Office - (18.2 SQM)	● Office (4)	
B00C - R0038 - General Learning Space - (58.84 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0039 - General Learning Space - (58.85 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0040 - General Learning Space - (54.44 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R0041 - General Learning Space - (54.43 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R0042 - General Learning Space - (58.43 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0043 - Movement - (135.84 SQM)	Not Applicable	Circulation or storage space.
B00C - R0055 - Administration - Clerical - (12.88 SQM)	● Office (3)	
B00C - R0056 - Movement - (72.23 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - General Learning Space - (51.91 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1002 - General Learning Space - (49.07 SQM) - Teaching Space: 1	● Student Space (22)	
B00C - R1003 - Staff Study - (24.79 SQM)	● Office (6)	
B00C - R1004 - Interview/Office - Type 1 - (28.18 SQM)	● Office (7)	
B00C - R1005 - Senior Study - (60.99 SQM)	● Office (15)	
B00C - R1006 - Seminar - (13 SQM)	● Office (3)	
B00C - R1008 - Seminar - (16.65 SQM)	● Office (4)	
B00C - R1009 - Seminar - (17 SQM)	● Office (4)	
B00C - R1010 - General Learning Space - (53.65 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1011 - General Learning Space - (53.85 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1012 - Seminar - (18.62 SQM)	● Office (4)	
B00C - R1013 - General Learning Space - (50.08 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R1015 - Movement - (107.09 SQM)	Not Applicable	Circulation or storage space.
B00C - R1016 - Main Area - (365.85 SQM)	Not Applicable	Circulation or storage space.
B00C - R1018 - Workroom - (41.68 SQM)	● Office (10)	
B00C - R1019 - Audio Visual Workroom - (23.49 SQM)	● Student Space (10)	
B00C - R1021 - Movement - (167.44 SQM)	Not Applicable	Circulation or storage space.
B00C - R1027 - General Learning Space - (47.26 SQM) - Teaching Space: 1	● Student Space (21)	
B00C - R1028 - General Learning Space - (47.26 SQM) - Teaching Space: 1	● Student Space (21)	
B00C - R1029 - General Learning Space - (47.26 SQM) - Teaching Space: 1	● Student Space (21)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R1030 - General Learning Space - (47.25 SQM) - Teaching Space: 1	● Student Space (21)	
B00C - R1031 - General Learning Space - (49.59 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R1032 - Seminar - (22.28 SQM)	● Office (5)	
B00C - R1033 - General Learning Space - (48.46 SQM) - Teaching Space: 1	● Student Space (22)	
B00C - R1035 - Staff Study - (14.02 SQM)	● Office (3)	
B00C - R1036 - Staff Study - (44.72 SQM)	● Office (11)	
B00C - R1037 - Commonroom - (95.81 SQM)	● Office (23)	
B00C - R1038 - Computer Learning Space - (66.38 SQM) - Teaching Space: 1	● Student Space (30)	
B00C - R1041 - Computer Learning Space - (66.38 SQM) - Teaching Space: 1	● Student Space (30)	
B00C - R1042 - General Learning Space - (48.43 SQM) - Teaching Space: 1	● Student Space (22)	
B00C - R1043 - Staff Study - (51.07 SQM)	● Office (12)	
B00C - R1044 - Movement - (169.59 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Canteen - (10.37 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Movement - (21.27 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Stage - (92.7 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - General Assistants - (13.78 SQM)	● Office (3)	
B00D - R0011 - Movement - (19.58 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Movement - (29.08 SQM)	Not Applicable	Circulation or storage space.
B00D - R0016 - Multi-Purpose Space - (473.48 SQM)	● Student Space (219)	
B00D - R0021 - Staff Study - (22.58 SQM)	● Office (5)	
B00D - R0024 - Movement - (165.11 SQM)	Not Applicable	Circulation or storage space.
B00D - R0025 - Movement - (174.29 SQM)	Not Applicable	Circulation or storage space.
B00D - R9001 - Gymnasium - (95.06 SQM)	● Student Space (44)	
B00E - R0004 - Student Canteen - (55.48 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Movement - (62.82 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - General Learning Space - (46.43 SQM) - Teaching Space: 1	● Student Space (21)	
B00F - R0005 - Interview/Office - Type 1 - (16.12 SQM)	● Office (4)	
B00F - R0007 - Movement - (8.59 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Movement - (8.59 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - General Assistants - (24.71 SQM)	● Office (6)	
NS 110 16850 - NS 110 16850 - Learning Unit - Single Secondary/Secure - (57 SQM)	● Student Space (26)	
NS 260 13189 - NS 260 13189 - Wood Technics/Storage - (95 SQM)	Not Applicable	Circulation or storage space.
OS 520 19629 - OS 520 19629 - Staff Study - (57 SQM)	● Office (14)	
OS 523 17128 - OS 523 17128 - Staff Study With Toilets - (76 SQM)	● Office (19)	
OS 600 13238 - OS 600 13238 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 601 10602 - OS 601 10602 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13030 - OS 601 13030 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14861 - OS 601 14861 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 19369 - OS 601 19369 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 19490 - OS 601 19490 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 19734 - OS 601 19734 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 19789 - OS 601 19789 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	