

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Mount Warrigal Public School (4395)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Shellharbour</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Shellharbour</b>

4395 - Mount Warrigal Public School  
Site Plan (11973)



1:909

Printed: 27-Mar-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - M0001 - Movement - (8.28 SQM)	Not Applicable	Circulation or storage space.
B00A - R0001 - Staff Room Annexe - (14.42 SQM)	Office (3)	
B00A - R0002 - Deputy Principal - (8.46 SQM)	Office (2)	
B00A - R0008 - Movement - (17.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Entry Vestibule - (17.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Principal - (17.58 SQM)	Office (4)	
B00A - R0013 - Clerical Office - (17.79 SQM)	Office (4)	
B00A - R0014 - Clerical Office/Workroom - (34.32 SQM)	Office (8)	
B00A - R0015 - Movement - (7.77 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Entry Vestibule - (11.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Movement - (22.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Principal - (16.56 SQM)	Office (4)	
B00A - R0023 - Clerical Office - (11.95 SQM)	Office (2)	
B00A - R1001 - Home Base - (56.7 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1004 - Movement - (6.73 SQM)	Not Applicable	Circulation or storage space.
B00A - R1006 - Home Base - (56.78 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1007 - Movement - (34.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R1008 - Movement - (7.19 SQM)	Not Applicable	Circulation or storage space.
B00B - M0001 - Movement - (8.26 SQM)	Not Applicable	Circulation or storage space.
B00B - M1001 - Movement - (7.72 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Home Base - (56.93 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0003 - Movement - (18.38 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Home Base - (57.17 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0007 - Canteen - (20.62 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Movement - (124.95 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Home Base - (56.71 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1005 - Movement - (5.98 SQM)	Not Applicable	Circulation or storage space.
B00B - R1007 - Home Base - (57.1 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1008 - Home Base - (57.02 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1011 - Movement - (5.96 SQM)	Not Applicable	Circulation or storage space.
B00B - R1013 - Home Base - (56.63 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1014 - Movement - (48.59 SQM)	Not Applicable	Circulation or storage space.
B00B - R1015 - Movement - (7.1 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Home Base - (56.77 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0004 - Movement - (6 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Home Base - (57.56 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0007 - Movement - (28.19 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Home Base - (57.16 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0012 - Movement - (5.86 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Communal Space - (115.21 SQM)	Student Space (53)	
B00C - R0016 - Movement - (9.16 SQM)	Not Applicable	Circulation or storage space.
B00C - R0018 - Movement - (98.71 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Reading Area - (90.85 SQM)	Student Space (42)	
B00C - R1003 - Reading Area - (63.52 SQM)	Student Space (29)	
B00C - R1005 - Movement - (22.2 SQM)	Not Applicable	Circulation or storage space.
B00C - R1006 - Movement - (5.46 SQM)	Not Applicable	Circulation or storage space.
B00C - R1007 - Home Base - (57.1 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R1011 - Movement - (5.91 SQM)	Not Applicable	Circulation or storage space.
B00C - R1013 - Home Base - (57.26 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R1014 - Home Base - (57.26 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R1017 - Movement - (56.04 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (104.79 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0004 - Movement - (10.99 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Communal Space - (493.36 SQM)	● Student Space (228)	
B00E - R0001 - Staff Room Annexe - (21.85 SQM)	● Office (5)	
B00E - R0002 - Seminar/Study - (18.45 SQM)	● Office (4)	
B00E - R0004 - Movement - (19.62 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Staff Room Annexe - (17.17 SQM)	● Office (4)	
B00E - R0011 - Staff Room - (56.87 SQM)	● Office (14)	
B00E - R0014 - Movement - (9.16 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Home Base - (56.72 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0017 - Movement - (6.09 SQM)	Not Applicable	Circulation or storage space.
B00E - R0020 - Home Base - (56.72 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0021 - Home Base - (85.87 SQM) - Teaching Space: 1	● Student Space (39)	
B00E - R0024 - Movement - (6.88 SQM)	Not Applicable	Circulation or storage space.
B00E - R0025 - Movement - (97.98 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (5.3 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Home Base - (57.04 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0005 - Home Base - (85.64 SQM) - Teaching Space: 1	● Student Space (39)	
B00F - R0008 - Movement - (6.88 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Movement - (40.97 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Home Base - (56.88 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0004 - Movement - (7.96 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Home Base - (56.88 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0007 - Movement - (34.25 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Home Base - M - (56.88 SQM) - Teaching Space: 1	● Student Space (26)	
B00H - R0003 - Practical Activities - M - 1hb - (10.56 SQM)	● Student Space (4)	
B00H - R0004 - Movement - (8.24 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Home Base - M - (53.08 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R0013 - Movement - (67.57 SQM)	Not Applicable	Circulation or storage space.
B00H - R0017 - Home Base - E - (56.81 SQM) - Teaching Space: 1	● Student Space (26)	
B00H - R0019 - Practical Activities - E - (10.06 SQM)	● Student Space (4)	
B00H - R0020 - Movement - (8.68 SQM)	Not Applicable	Circulation or storage space.
B00H - R0022 - Practical Activities - E - (56.65 SQM)	● Student Space (26)	
B00H - R0023 - Movement - (47.26 SQM)	Not Applicable	Circulation or storage space.
B00H - R0024 - Movement - (67.49 SQM)	Not Applicable	Circulation or storage space.
B00H - R0025 - Movement - (7.22 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Movement - (9.36 SQM)	Not Applicable	Circulation or storage space.
B00J - R0003 - Home Base - Pre - (73.87 SQM) - Teaching Space: 1	● Student Space (34)	
B00J - R0004 - Withdrawal - Pre - (10.47 SQM)	● Student Space (4)	
B00J - R0005 - Movement - (9.7 SQM)	Not Applicable	Circulation or storage space.
B00J - R0006 - Movement - (55.41 SQM)	Not Applicable	Circulation or storage space.
B00J - R0007 - Movement - (9.54 SQM)	Not Applicable	Circulation or storage space.
B00J - R0010 - Home Base - Pre - (74 SQM) - Teaching Space: 1	● Student Space (34)	
B00J - R0011 - Withdrawal - Pre - (10.61 SQM)	● Student Space (4)	
B00J - R0013 - Staff Kitchen - (21.51 SQM)	● Office (5)	
B00J - R0014 - Staff Room - (18.76 SQM)	● Office (4)	
B00J - R0015 - Movement - (24.42 SQM)	Not Applicable	Circulation or storage space.
B00J - R0018 - Staff Room Annexe - (8.75 SQM)	● Office (2)	
B00J - R0024 - Movement - (16.33 SQM)	Not Applicable	Circulation or storage space.
B00J - R0026 - Movement - (16.11 SQM)	Not Applicable	Circulation or storage space.
B00J - R0029 - Withdrawal - Pre - (21.46 SQM)	● Student Space (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00L - R0001 - Communal Space - (238.68 SQM)	 Student Space (110)	
B00L - R0005 - Movement - (6.35 SQM)	Not Applicable	Circulation or storage space.