


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Mowbray Public School (4015)</b>
<b>AMU REGION:</b>	<b>Northern Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Willoughby</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Willoughby</b>

4015 - Mowbray Public School  
Site Plan (12463)



1:1,064

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Practical Activities - 1hb - (19.4 SQM)	Student Space (9)	
B00A - R0004 - Home Base - (59.22 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	Student Space (5)	
B00A - R0006 - Home Base - (59.22 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0008 - Practical Activities - 1hb - (19.41 SQM)	Student Space (9)	
B00O - R0018 - Communal Space - (230 SQM)	Student Space (106)	
B00O - R0019 - Raised Platform - (49.62 SQM)	Not Applicable	Circulation or storage space.
B00O - R0020 - Movement - (11.85 SQM)	Not Applicable	Circulation or storage space.
B00O - R0021 - Movement - (11.82 SQM)	Not Applicable	Circulation or storage space.
B00O - R0034 - Canteen - (42.98 SQM)	Not Applicable	Circulation or storage space.
B00S - R0001 - Home Base - (60.25 SQM) - Teaching Space: 1	Student Space (27)	
B00S - R0002 - Home Base - (60.25 SQM) - Teaching Space: 1	Student Space (27)	
B00S - R0004 - Practical Activities - 1hb - (18.94 SQM)	Student Space (8)	
B00S - R0005 - Withdrawal Space - 2hb - (11.55 SQM)	Student Space (5)	
B00S - R0006 - Practical Activities - 1hb - (18.94 SQM)	Student Space (8)	
B00U - R0002 - Movement - (8.44 SQM)	Not Applicable	Circulation or storage space.
B00U - R0003 - Entry Vestibule - (8.88 SQM)	Not Applicable	Circulation or storage space.
B00V - R0003 - Reading Area - (269.33 SQM)	Student Space (124)	
B00V - R0011 - Home Base - (58.84 SQM) - Teaching Space: 1	Student Space (27)	
B00V - R0012 - Practical Activities - (20.21 SQM)	Student Space (9)	
B00V - R0013 - Withdrawal Space - 1hb - (8.36 SQM)	Student Space (3)	
B00V - R1001 - Home Base - (58.05 SQM) - Teaching Space: 1	Student Space (26)	
B00V - R1002 - Withdrawal Space - 1hb - (8.3 SQM)	Student Space (3)	
B00V - R1005 - Practical Activities - (19.59 SQM)	Student Space (9)	
B00V - R1006 - Practical Activities - (19.58 SQM)	Student Space (9)	
B00V - R1007 - Home Base - (57.7 SQM) - Teaching Space: 1	Student Space (26)	
B00V - R1008 - Withdrawal Space - 2hb - (17.03 SQM)	Student Space (7)	
B00V - R1009 - Home Base - (58.12 SQM) - Teaching Space: 1	Student Space (26)	
B00V - R1010 - Practical Activities - (19.8 SQM)	Student Space (9)	
B00V - R1013 - Home Base - (57.59 SQM) - Teaching Space: 1	Student Space (26)	
B00V - R1014 - Practical Activities - (19.58 SQM)	Student Space (9)	
B00V - R1015 - Withdrawal Space - 2hb - (17.03 SQM)	Student Space (7)	
B00V - R1016 - Home Base - (57.25 SQM) - Teaching Space: 1	Student Space (26)	
B00V - R1017 - Practical Activities - (19.47 SQM)	Student Space (9)	
B00V - R1020 - Practical Activities - (20.12 SQM)	Student Space (9)	
B00V - R1021 - Withdrawal Space - 1hb - (8.3 SQM)	Student Space (3)	
B00V - R1022 - Home Base - (59.86 SQM) - Teaching Space: 1	Student Space (27)	
B00V - R2001 - Home Base - (58.08 SQM) - Teaching Space: 1	Student Space (26)	
B00V - R2002 - Practical Activities - (8.3 SQM)	Student Space (3)	
B00V - R2005 - Withdrawal Space - 1hb - (19.62 SQM)	Student Space (9)	
B00V - R2006 - Practical Activities - (19.92 SQM)	Student Space (9)	
B00V - R2007 - Home Base - (66.43 SQM) - Teaching Space: 1	Student Space (30)	
B00V - R2008 - Withdrawal Space - 2hb - (17.03 SQM)	Student Space (7)	
B00V - R2009 - Home Base - (66.54 SQM) - Teaching Space: 1	Student Space (30)	
B00V - R2010 - Practical Activities - (19.84 SQM)	Student Space (9)	
B00V - R2013 - Home Base - (57.92 SQM) - Teaching Space: 1	Student Space (26)	
B00V - R2014 - Practical Activities - (19.62 SQM)	Student Space (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00V - R2015 - Withdrawal Space - 2hb - (17.03 SQM)	● Student Space (7)	
B00V - R2016 - Home Base - (57.46 SQM) - Teaching Space: 1	● Student Space (26)	
B00V - R2017 - Practical Activities - (19.5 SQM)	● Student Space (9)	
B00V - R2020 - Practical Activities - (20.17 SQM)	● Student Space (9)	
B00V - R2021 - Withdrawal Space - 1hb - (8.3 SQM)	● Student Space (3)	
B00V - R2022 - Home Base - (59.86 SQM) - Teaching Space: 1	● Student Space (27)	
B00W - R0001 - Entry Vestibule - (21.1 SQM)	Not Applicable	Circulation or storage space.
B00W - R0002 - Interview - (13.07 SQM)	● Office (3)	
B00W - R0003 - Sick Bay - (10.49 SQM)	● Student Space (4)	
B00W - R0006 - Clerical Office/Workroom - (13.63 SQM)	● Office (3)	
B00W - R0007 - Clerical Office/Workroom - (15.07 SQM)	● Office (3)	
B00W - R0008 - Clerical Office - (13.33 SQM)	● Office (3)	
B00W - R0009 - Interview - (12.5 SQM)	● Office (3)	
B00W - R0010 - Clerical Office - (48.57 SQM)	● Office (12)	
B00W - R0011 - Clerical/Printing - (26.75 SQM)	Not Applicable	Circulation or storage space.
B00W - R0012 - Clerical Office/Workroom - (14.94 SQM)	● Office (3)	
B00W - R0013 - Principal - (25.48 SQM)	● Office (6)	
B00W - R0021 - Staff Room - (118.76 SQM)	● Office (29)	
B00W - R0022 - Staff Kitchen - (15.32 SQM)	● Office (3)	
B00W - R0023 - Special Programs Room - (67.69 SQM)	● Student Space (31)	
B00W - R0033 - Practical Activities - (20.06 SQM)	● Student Space (9)	
B00W - R0035 - Movement - (69.09 SQM)	Not Applicable	Circulation or storage space.
B00W - R1001 - Home Base - (58.8 SQM) - Teaching Space: 1	● Student Space (27)	
B00W - R1002 - Withdrawal Space - 1hb - (8.6 SQM)	● Student Space (3)	
B00W - R1003 - Practical Activities - (19.65 SQM)	● Student Space (9)	
B00W - R1005 - Home Base - (57.84 SQM) - Teaching Space: 1	● Student Space (26)	
B00W - R1006 - Practical Activities - (19.71 SQM)	● Student Space (9)	
B00W - R1007 - Withdrawal Space - 2hb - (17.35 SQM)	● Student Space (8)	
B00W - R1008 - Practical Activities - (6.63 SQM)	● Student Space (3)	
B00W - R1009 - Home Base - (57.96 SQM) - Teaching Space: 1	● Student Space (26)	
B00W - R1010 - Practical Activities - (19.92 SQM)	● Student Space (9)	
B00W - R1012 - Home Base - (57.52 SQM) - Teaching Space: 1	● Student Space (26)	
B00W - R1013 - Practical Activities - (19.92 SQM)	● Student Space (9)	
B00W - R1014 - Withdrawal Space - 2hb - (16.57 SQM)	● Student Space (7)	
B00W - R1016 - Home Base - (57.67 SQM) - Teaching Space: 1	● Student Space (26)	
B00W - R1017 - Practical Activities - (19.91 SQM)	● Student Space (9)	
B00W - R1019 - Home Base - (59.33 SQM) - Teaching Space: 1	● Student Space (27)	
B00W - R1020 - Practical Activities - 1hb - (19.84 SQM)	● Student Space (9)	
B00W - R1022 - Withdrawal Space - 1hb - (8.42 SQM)	● Student Space (3)	
B00W - R2001 - Home Base - (57.74 SQM) - Teaching Space: 1	● Student Space (26)	
B00W - R2002 - Withdrawal Space - 1hb - (8.6 SQM)	● Student Space (3)	
B00W - R2003 - Practical Activities - (19.68 SQM)	● Student Space (9)	
B00W - R2005 - Home Base - (66.57 SQM) - Teaching Space: 1	● Student Space (30)	
B00W - R2006 - Practical Activities - (19.75 SQM)	● Student Space (9)	
B00W - R2007 - Withdrawal Space - 2hb - (17.35 SQM)	● Student Space (8)	
B00W - R2008 - Home Base - (65.79 SQM) - Teaching Space: 1	● Student Space (30)	
B00W - R2009 - Practical Activities - (19.95 SQM)	● Student Space (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00W - R2010 - Home Base - (57.22 SQM) - Teaching Space: 1	● Student Space (26)	
B00W - R2011 - Practical Activities - (19.95 SQM)	● Student Space (9)	
B00W - R2012 - Withdrawal Space - 2hb - (16.57 SQM)	● Student Space (7)	
B00W - R2014 - Home Base - (56.85 SQM) - Teaching Space: 1	● Student Space (26)	
B00W - R2015 - Practical Activities - (19.68 SQM)	● Student Space (9)	
B00W - R2017 - Home Base - (59.12 SQM) - Teaching Space: 1	● Student Space (27)	
B00W - R2018 - Practical Activities - (19.79 SQM)	● Student Space (9)	
B00W - R2019 - Withdrawal Space - 1hb - (8.42 SQM)	● Student Space (3)	
B00W - R9001 - Special Programs Room - (62.81 SQM)	● Student Space (29)	
B00X - R0001 - Withdrawal Space - 1hb - (8.5 SQM)	● Student Space (3)	
B00X - R0002 - Home Base - (58.59 SQM) - Teaching Space: 1	● Student Space (27)	
B00X - R0003 - Practical Activities - 1hb - (20.58 SQM)	● Student Space (9)	
B00X - R0006 - Practical Activities - (20.1 SQM)	● Student Space (9)	
B00X - R0007 - Home Base - (58.81 SQM) - Teaching Space: 1	● Student Space (27)	
B00X - R0008 - Withdrawal Space - 2hb - (17.68 SQM)	● Student Space (8)	
B00X - R0009 - Practical Activities - (19.44 SQM)	● Student Space (9)	
B00X - R0010 - Home Base - (59.74 SQM) - Teaching Space: 1	● Student Space (27)	
B00X - R0016 - Movement - (24.98 SQM)	Not Applicable	Circulation or storage space.
B00X - R1001 - Withdrawal Space - 1hb - (8.69 SQM)	● Student Space (4)	
B00X - R1002 - Home Base - (60.29 SQM) - Teaching Space: 1	● Student Space (27)	
B00X - R1003 - Practical Activities - 1hb - (19.92 SQM)	● Student Space (9)	
B00X - R1006 - Practical Activities - (19.88 SQM)	● Student Space (9)	
B00X - R1007 - Home Base - (57.79 SQM) - Teaching Space: 1	● Student Space (26)	
B00X - R1008 - Withdrawal Space - 2hb - (16.89 SQM)	● Student Space (7)	
B00X - R1009 - Practical Activities - 2hb - (19.54 SQM)	● Student Space (9)	
B00X - R1010 - Home Base - (58.24 SQM) - Teaching Space: 1	● Student Space (27)	
B00X - R2001 - Practical Activities - 1hb - (8.69 SQM)	● Student Space (4)	
B00X - R2002 - Home Base - (60.29 SQM) - Teaching Space: 1	● Student Space (27)	
B00X - R2003 - Withdrawal Space - 1hb - (19.92 SQM)	● Student Space (9)	
B00X - R2006 - Practical Activities - (19.4 SQM)	● Student Space (9)	
B00X - R2007 - Home Base - (58.15 SQM) - Teaching Space: 1	● Student Space (26)	
B00X - R2008 - Withdrawal Space - 2hb - (16.89 SQM)	● Student Space (7)	
B00X - R2009 - Practical Activities - 1hb - (19.54 SQM)	● Student Space (9)	
B00X - R2010 - Home Base - (58.14 SQM) - Teaching Space: 1	● Student Space (26)	
B00X - R9006 - Movement - (36.79 SQM)	Not Applicable	Circulation or storage space.
B00X - R9008 - Movement - (25.74 SQM)	Not Applicable	Circulation or storage space.
B00X - R9009 - Special Programs Room - Type 1 - (74.55 SQM)	● Student Space (34)	