

VENTILATION AUDIT REPORT

SCHOOL:	Mudgee High School (8128)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Dubbo
LOCAL GOVERNMENT AREA:	Mid-Western

8128 - Mudgee High School
Site Plan (13098)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - General Learning Space - (47.29 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0005 - Movement - (5.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - General Learning Space - (48.07 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0008 - Main Area - (48.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Main Area - (48.09 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - General Learning Space - (48.18 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0011 - Movement - (7.24 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Audio Visual Workroom - (22.31 SQM)	● Student Space (10)	
B00A - R0025 - Workroom - (47.66 SQM)	● Office (11)	
B00A - R0027 - Seminar - (22.83 SQM)	● Office (5)	
B00A - R0028 - Seminar - (24.73 SQM)	● Office (6)	
B00A - R0030 - Staff Study - (13.4 SQM)	● Office (3)	
B00A - R0031 - Staff Study - (13.36 SQM)	● Office (3)	
B00A - R0032 - Entry - (50.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R0033 - Entry - (35.58 SQM)	Not Applicable	Circulation or storage space.
B00A - R0034 - Main Area - (266.01 SQM)	Not Applicable	Circulation or storage space.
B00A - R0037 - Movement - (5.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R0040 - Staff Study - (17.24 SQM)	● Office (4)	
B00A - R0041 - General Learning Space - (48.13 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R0011 - Laboratory L.S. - (92.28 SQM) - Teaching Space: 1	● Student Space (42)	
B00B - R0013 - Preparation - (28.11 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Laboratory L.S. - (93.68 SQM) - Teaching Space: 1	● Student Space (43)	
B00B - R0019 - Art Learning Space - (65.76 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0023 - Staff Study - (24.74 SQM)	● Office (6)	
B00B - R0029 - Staff Study - (16.86 SQM)	● Office (4)	
B00B - R0033 - Special Learning Space - (52.76 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0034 - Serviced Learning Space - (52.68 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0035 - Movement - (131.71 SQM)	Not Applicable	Circulation or storage space.
B00B - R0037 - General Learning Space - (48.14 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R0041 - Movement - (314.23 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Staff Study - (25.08 SQM)	● Office (6)	
B00B - R1002 - Computer Learning Space - (51.16 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1003 - General Learning Space - (51.16 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1004 - General Learning Space - (51.16 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1007 - Commonroom - (79.07 SQM)	● Office (19)	
B00B - R1011 - General Learning Space - (51.87 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1012 - General Learning Space - (54.07 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R1014 - Staff Study - (38.58 SQM)	● Office (9)	
B00B - R1016 - General Learning Space - (52.61 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1017 - General Learning Space - (52.61 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1018 - General Learning Space - (51.61 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1020 - General Learning Space - (51.17 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1021 - General Learning Space - (51.17 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1022 - Computer Learning Space - (51.17 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1027 - Movement - (210.55 SQM)	Not Applicable	Circulation or storage space.
B00B - R1028 - General Learning Space - (52.4 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0001 - Laboratory L.S. - (82.33 SQM) - Teaching Space: 1	● Student Space (38)	
B00C - R0002 - Laboratory L.S. - (81.97 SQM) - Teaching Space: 1	● Student Space (38)	
B00C - R0003 - Staff Study - (57.65 SQM)	● Office (14)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0010 - Movement - (14.07 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Movement - (8.27 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - Preparation - (32.53 SQM)	Not Applicable	Circulation or storage space.
B00C - R0020 - Movement - (51.98 SQM)	Not Applicable	Circulation or storage space.
B00C - R1012 - Movement - (14.01 SQM)	Not Applicable	Circulation or storage space.
B00C - R1013 - Movement - (7.33 SQM)	Not Applicable	Circulation or storage space.
B00C - R1015 - Movement - (40.19 SQM)	Not Applicable	Circulation or storage space.
B00C - R1017 - Laboratory L.S. - (91.85 SQM) - Teaching Space: 1	● Student Space (42)	
B00C - R1018 - Laboratory L.S. - (92.06 SQM) - Teaching Space: 1	● Student Space (42)	
B00C - R1021 - Movement - (7.29 SQM)	Not Applicable	Circulation or storage space.
B00C - R1027 - Preparation - Science - (37.11 SQM)	Not Applicable	Circulation or storage space.
B00D - R0014 - Principal Office - (21.29 SQM)	● Office (5)	
B00D - R0029 - General Learning Space - (66.31 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R0030 - General Learning Space - (66 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R0031 - General Learning Space - (65.65 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R0032 - Senior Study - (32.79 SQM)	● Office (8)	
B00D - R0033 - General Learning Space - (65.77 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R0036 - Movement - (120.66 SQM)	Not Applicable	Circulation or storage space.
B00D - R0041 - Deputy Principal Office - (17.87 SQM)	● Office (4)	
B00D - R0048 - Movement - (26.95 SQM)	Not Applicable	Circulation or storage space.
B00D - R0051 - Interview/Meeting - (13.78 SQM)	● Office (3)	
B00D - R0052 - Movement - (5.57 SQM)	Not Applicable	Circulation or storage space.
B00D - R0053 - Public Reception - (24.34 SQM)	Not Applicable	Circulation or storage space.
B00D - R0054 - Administration - Clerical - (53.81 SQM)	● Office (13)	
B00D - R0057 - Student Reception - (23.24 SQM)	Not Applicable	Circulation or storage space.
B00D - R0058 - Interview/Meeting - (14.51 SQM)	● Office (3)	
B00D - R0059 - Deputy Principal Office - (21.53 SQM)	● Office (5)	
B00D - R0060 - Clinic - (16.69 SQM)	● Office (4)	
B00D - R0061 - Movement - (6.17 SQM)	Not Applicable	Circulation or storage space.
B00D - R1010 - Design L.S. - (66.58 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R1019 - Design L.S. - (52.62 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1020 - General Learning Space - (52.62 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1021 - Interview/Office - Type 1 - (26.6 SQM)	● Office (6)	
B00D - R1022 - General Learning Space - (65.85 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R1023 - General Learning Space - (66.13 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R1024 - General Learning Space - (65.67 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R1025 - Staff Study - (32.83 SQM)	● Office (8)	
B00D - R1026 - Movement - (103.45 SQM)	Not Applicable	Circulation or storage space.
B00D - R1027 - Movement - (6.98 SQM)	Not Applicable	Circulation or storage space.
B00D - R1030 - Movement - (27.36 SQM)	Not Applicable	Circulation or storage space.
B00D - R1033 - Movement - (25.5 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Staff Study - (22.21 SQM)	● Office (5)	
B00G - R0005 - Gymnasium - (565.31 SQM)	● Student Space (262)	
B00G - R0024 - Performance Workspace - (128.39 SQM) - Teaching Space: 1	● Student Space (59)	
B00G - R0025 - Stage - (27.24 SQM)	Not Applicable	Circulation or storage space.
B00G - R0028 - Movement - (7.26 SQM)	Not Applicable	Circulation or storage space.
B00G - R0029 - Movement - (7.25 SQM)	Not Applicable	Circulation or storage space.
B00G - R0030 - Movement - (7.24 SQM)	Not Applicable	Circulation or storage space.
B00G - R0031 - Movement - (7.06 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Student Canteen - (49.8 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R0001 - Materials Technology L.S. - (98.06 SQM) - Teaching Space: 1	● Student Space (45)	
B00J - R0003 - Wood Technology Bay - (33.88 SQM)	Not Applicable	Circulation or storage space.
B00J - R0010 - Design/Technology L.S. - (99.84 SQM) - Teaching Space: 1	● Student Space (46)	
B00J - R0011 - Food Technology L.S. - (74.73 SQM) - Teaching Space: 1	● Student Space (34)	
B00J - R0012 - Interview/Office - Type 1 - (15.23 SQM)	● Office (3)	
B00J - R0013 - Movement - (6.08 SQM)	Not Applicable	Circulation or storage space.
B00J - R0018 - Food Technology L.S. - (74.89 SQM) - Teaching Space: 1	● Student Space (34)	
B00J - R0019 - Food/Research Space - (40.34 SQM)	Not Applicable	Circulation or storage space.
B00J - R0020 - Movement - (224.76 SQM)	Not Applicable	Circulation or storage space.
B00J - R0023 - Wood Technology L.S. - (109.66 SQM) - Teaching Space: 1	● Student Space (50)	
B00J - R0024 - Metal Technology L.S. - (128.67 SQM) - Teaching Space: 1	● Student Space (59)	
B00J - R0025 - Welding Area - (10.74 SQM)	Not Applicable	Circulation or storage space.
B00J - R0026 - Outdoor Learning Area - (79.35 SQM)	Not Applicable	Circulation or storage space.
B00J - R0027 - Materials Workshop - Type 2 - (33.84 SQM)	● Student Space (15)	
B00J - R9001 - General Assistants - (13.34 SQM)	● Office (3)	
B00K - R0003 - Computer Learning Space - (77.02 SQM) - Teaching Space: 1	● Student Space (35)	
B00K - R0006 - Computer Learning Space - (76.54 SQM) - Teaching Space: 1	● Student Space (35)	
B00K - R0008 - Staff Study - (11.48 SQM)	● Office (2)	
B00K - R0009 - Duplicating Workroom - (11.41 SQM)	● Office (2)	
B00K - R0012 - Staff Study - (43.23 SQM)	● Office (10)	
B00K - R0013 - Movement - (68.09 SQM)	Not Applicable	Circulation or storage space.
B00K - R1001 - Design L.S. - (76.81 SQM) - Teaching Space: 1	● Student Space (35)	
B00K - R1002 - General Learning Space - (52.55 SQM) - Teaching Space: 1	● Student Space (24)	
B00K - R1003 - General Learning Space - (51.98 SQM) - Teaching Space: 1	● Student Space (24)	
B00K - R1004 - General Learning Space - (52.21 SQM) - Teaching Space: 1	● Student Space (24)	
B00K - R1005 - Staff Study - (51.99 SQM)	● Office (12)	
B00K - R1008 - Interview/Office - Type 1 - (12.76 SQM)	● Office (3)	
B00K - R1010 - Movement - (53.23 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Outdoor Learning Area - (59.65 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Food Technology L.S. - (105.63 SQM) - Teaching Space: 1	● Student Space (49)	
B00L - R0003 - Food/Research Space - (15.22 SQM)	Not Applicable	Circulation or storage space.
B00L - R0005 - Food/Research Space - (18.2 SQM)	Not Applicable	Circulation or storage space.
B0AG - R0001 - Movement - (16.01 SQM)	Not Applicable	Circulation or storage space.
B0FF - R0001 - Art Learning Space - (60.49 SQM) - Teaching Space: 1	● Student Space (28)	
B0FF - R0002 - Art Learning Space - (60.41 SQM) - Teaching Space: 1	● Student Space (28)	
B0FF - R0003 - Workshop - (49.47 SQM)	● Student Space (22)	
B0FF - R0006 - Art Learning Space - (60.49 SQM) - Teaching Space: 1	● Student Space (28)	
B0FF - R0007 - Staff Study - (33.35 SQM)	● Office (8)	
B0FF - R0008 - Art Learning Space - (61.75 SQM) - Teaching Space: 1	● Student Space (28)	
B0FF - R0011 - Interview/Office - Type 1 - (13.68 SQM)	● Office (3)	
B0FF - R0013 - Darkroom Space - (27.53 SQM)	● Office (6)	
B0FF - R0017 - Music Learning Space - (60.54 SQM) - Teaching Space: 1	● Student Space (28)	
B0FF - R0018 - Practice/Seminar - (24.59 SQM)	Not Applicable	Circulation or storage space.
B0FF - R0021 - Music Learning Space - (78.23 SQM) - Teaching Space: 1	● Student Space (36)	
OS 522 17721 - OS 522 17721 - Staff Study - (38 SQM)	● Office (9)	
OS 600 18141 - OS 600 18141 - Learning Unit - Small - (57 SQM)	● Student Space (26)	