

VENTILATION AUDIT REPORT

SCHOOL:	Mudgee Public School (2656)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Dubbo
LOCAL GOVERNMENT AREA:	Mid-Western

2656 - Mudgee Public School
Site Plan (13097)



1:995

Printed: 01-May-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0001 - Interview - (12.9 SQM)	Office (3)	
B001 - R0003 - Withdrawal Space - 1hb - (12.85 SQM)	Student Space (5)	
B001 - R0006 - Movement - (30.82 SQM)	Not Applicable	Circulation or storage space.
B001 - R0007 - Movement - (42.87 SQM)	Not Applicable	Circulation or storage space.
B001 - R0008 - Staff Room Annexe - (24.52 SQM)	Office (6)	
B001 - R0009 - Staff Room - (60.3 SQM)	Office (15)	
B001 - R0012 - Clerical Office - (16.51 SQM)	Office (4)	
B001 - R0013 - Sick Bay - (7.28 SQM)	Student Space (3)	
B001 - R0014 - Duplicating Workroom - (34.81 SQM)	Office (8)	
B001 - R0016 - Principal - (23.87 SQM)	Office (5)	
B001 - R0017 - Deputy Principal - (11.72 SQM)	Office (2)	
B001 - R0023 - Movement - (7.23 SQM)	Not Applicable	Circulation or storage space.
B001 - R0025 - Special Programs Room - (35.15 SQM)	Student Space (16)	
B001 - R0031 - Home Base - (54.63 SQM) - Teaching Space: 1	Student Space (25)	
B001 - R0033 - Withdrawal Space - 1hb - (11.7 SQM)	Student Space (5)	
B001 - R0037 - Practical Activities - 1hb - (32.72 SQM)	Student Space (15)	
B001 - R0039 - Home Base - (58.11 SQM) - Teaching Space: 1	Student Space (26)	
B002 - R0001 - Deputy Principal - (21.84 SQM)	Office (5)	
B002 - R0005 - Movement - (16.71 SQM)	Not Applicable	Circulation or storage space.
B002 - R0008 - Home Base - (47.46 SQM) - Teaching Space: 1	Student Space (22)	
B002 - R0009 - Practical Activities - 1hb - (137.34 SQM)	Student Space (63)	
B002 - R0010 - Movement - (18.14 SQM)	Not Applicable	Circulation or storage space.
B002 - R0012 - Home Base - (47.59 SQM) - Teaching Space: 1	Student Space (22)	
B002 - R0013 - Practical Activities - 4hb - (47.51 SQM)	Student Space (22)	
B002 - R0014 - Home Base - (60.85 SQM) - Teaching Space: 1	Student Space (28)	
B002 - R0015 - Home Base - (47.52 SQM) - Teaching Space: 1	Student Space (22)	
B002 - R0016 - Interview - (13.03 SQM)	Office (3)	
B002 - R0017 - Movement - (16.37 SQM)	Not Applicable	Circulation or storage space.
B003 - R0001 - Practical Activities - 1hb - (16.12 SQM)	Student Space (7)	
B003 - R0002 - Home Base - (69.85 SQM) - Teaching Space: 1	Student Space (32)	
B003 - R0005 - Movement - (7.43 SQM)	Not Applicable	Circulation or storage space.
B004 - R0002 - Movement - (6.8 SQM)	Not Applicable	Circulation or storage space.
B004 - R0005 - Home Base - (77.36 SQM) - Teaching Space: 1	Student Space (35)	
B004 - R0006 - Practical Activities - 1hb - (8.55 SQM)	Student Space (3)	
B004 - R0007 - Practical Activities - 1hb - (8.45 SQM)	Student Space (3)	
B004 - R0008 - Home Base - (77.61 SQM) - Teaching Space: 1	Student Space (36)	
B004 - R0013 - Practical Activities - 1hb - (15.97 SQM)	Student Space (7)	
B004 - R0014 - Home Base - (57.07 SQM) - Teaching Space: 1	Student Space (26)	
B006 - R0003 - Reading Area - (240.35 SQM)	Student Space (111)	
B007 - R0001 - Home Base - (57.73 SQM) - Teaching Space: 1	Student Space (26)	
B007 - R0004 - Practical Activities - 1hb - (16.44 SQM)	Student Space (7)	
B007 - R0007 - Home Base - (57.73 SQM) - Teaching Space: 1	Student Space (26)	
B008 - R0001 - Home Base - (53.2 SQM) - Teaching Space: 1	Student Space (24)	
B008 - R0003 - Practical Activities - 1hb - (6.78 SQM)	Student Space (3)	
B008 - R0006 - Practical Activities - 1hb - (12.95 SQM)	Student Space (6)	
B008 - R0007 - Home Base - (54.52 SQM) - Teaching Space: 1	Student Space (25)	
B009 - R0004 - Movement - (6.6 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B009 - R0008 - Raised Platform - (52.78 SQM)	Not Applicable	Circulation or storage space.
B009 - R0009 - Movement - (6.33 SQM)	Not Applicable	Circulation or storage space.
B009 - R0024 - Canteen - (37.92 SQM)	Not Applicable	Circulation or storage space.
B009 - R0033 - Communal Space - (287.38 SQM)	● Student Space (133)	
B009 - R0035 - Movement - (19.74 SQM)	Not Applicable	Circulation or storage space.
B010 - R0008 - Communal Space - (139.87 SQM)	● Student Space (64)	
B011 - R0004 - Practical Activities - 1hb - (13.47 SQM)	● Student Space (6)	
B011 - R0005 - Home Base - (78.82 SQM) - Teaching Space: 1	● Student Space (36)	
B012 - R0002 - Home Base - (57.23 SQM) - Teaching Space: 1	● Student Space (26)	
B012 - R0005 - Home Base - (57.16 SQM) - Teaching Space: 1	● Student Space (26)	
B012 - R0006 - Practical Activities - 1hb - (16.02 SQM)	● Student Space (7)	
B013 - R0001 - Home Base - (56.79 SQM) - Teaching Space: 1	● Student Space (26)	
B013 - R0002 - Practical Activities - 1hb - (9.25 SQM)	● Student Space (4)	
B013 - R0004 - Staff Kitchen - (16.83 SQM)	● Office (4)	
B013 - R0005 - Home Base - M - (54.92 SQM) - Teaching Space: 1	● Student Space (25)	
B013 - R0006 - Home Base - M - (75.32 SQM) - Teaching Space: 1	● Student Space (34)	
B013 - R0007 - Clerical Office - (11.9 SQM)	● Office (2)	
B016 - R0001 - Special Programs Room - Type 1 - (32.47 SQM)	● Student Space (15)	
B017 - R0001 - Practical Activities - 1hb - (21.38 SQM)	● Student Space (9)	
B017 - R0002 - Home Base - (58.11 SQM) - Teaching Space: 1	● Student Space (26)	
B017 - R0004 - Withdrawal Space - 1hb - (9.05 SQM)	● Student Space (4)	
NS 100 10129 - NS 100 10129 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
NS 100 12186 - NS 100 12186 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
OS 601 13859 - OS 601 13859 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 11205 - OS 602 11205 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12664 - OS 602 12664 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13711 - OS 602 13711 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15907 - OS 602 15907 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 18345 - OS 602 18345 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 14168 - OS 603 14168 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 606 18247 - OS 606 18247 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	