


# VENTILATION AUDIT REPORT
















<b>SCHOOL:</b>	<b>Mulbring Public School (2658)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Cessnock</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Cessnock</b>

2658 - Mulbring Public School  
Site Plan (10657)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Clerical Office - (14.16 SQM)	 Office (3)	
B00A - R0003 - Entry Vestibule - (10.6 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Movement - (6.28 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Duplicating Workroom - (10.67 SQM)	 Office (2)	
B00A - R0007 - Principal - (14.53 SQM)	 Office (3)	
B00A - R0009 - Staff Room - (22.68 SQM)	 Office (5)	
B00A - R0010 - Staff Kitchen - (10.27 SQM)	 Office (2)	
B00B - R0004 - Practical Activities - 1hb - (33.16 SQM)	 Student Space (15)	
B00B - R0005 - Withdrawal Space - 1hb - (44.64 SQM)	 Student Space (20)	
B00B - R0006 - Home Base - (44.85 SQM) - Teaching Space: 1	 Student Space (20)	
B00B - R0008 - Interview - (13.13 SQM)	 Office (3)	
B00B - R0009 - Sick Bay - (7.45 SQM)	 Student Space (3)	
B00E - R0001 - Movement - (9.67 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Movement - (37.63 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Practical Activities - 1hb - (21.63 SQM)	 Student Space (10)	
B00H - R0004 - Home Base - (63.39 SQM) - Teaching Space: 1	 Student Space (29)	
B00H - R0005 - Withdrawal Space - 2hb - (10.84 SQM)	 Student Space (5)	
B00H - R0006 - Home Base - (63.39 SQM) - Teaching Space: 1	 Student Space (29)	
B00H - R0008 - Practical Activities - 1hb - (21.63 SQM)	 Student Space (10)	