


VENTILATION AUDIT REPORT

SCHOOL:	Mullumbimby High School (8193)
AMU REGION:	North Coast
STATE ELECTORATE:	Ballina
LOCAL GOVERNMENT AREA:	Byron

8193 - Mullumbimby High School
Site Plan (13341)



1:835

Printed: 21-Aug-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0017 - Interview/Office - Type 1 - (11.3 SQM)	Office (2)	
B00A - R0018 - Interview/Office - Type 1 - (11.16 SQM)	Office (2)	
B00A - R0019 - Staff Study - (111.16 SQM)	Office (27)	
B00A - R0020 - Staff Study - (182.57 SQM)	Office (45)	
B00A - R0026 - Staff Study - (106.45 SQM)	Office (26)	
B00A - R0027 - Duplicating Workroom - (36.6 SQM)	Office (9)	
B00A - R0028 - Interview/Office - Type 1 - (16.44 SQM)	Office (4)	
B00A - R0029 - Movement - (15.89 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Movement - (21.16 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Movement - (14.71 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - General Learning Space - Type 1 - (52.49 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0017 - General Learning Space - Type 1 - (61.48 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0019 - Music Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0020 - General Learning Space - Type 1 - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1001 - Computer Learning Space - (53.21 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1002 - General Learning Space - (53 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1006 - General Learning Space - (52.79 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1007 - General Learning Space - (52.78 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1011 - Seminar - Type 1 - (25.73 SQM)	Office (6)	
B00D - R0002 - Movement - (19.15 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Art Learning Space - (59.82 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0009 - General Learning Space - (53 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0010 - General Learning Space - (53.15 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0011 - General Learning Space - (52.93 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0017 - Movement - (45.42 SQM)	Not Applicable	Circulation or storage space.
B00D - R0032 - Staff Study - (32.63 SQM)	Office (8)	
B00D - R0039 - Movement - (16.91 SQM)	Not Applicable	Circulation or storage space.
B00D - R0044 - Practical Activity Area - (65.72 SQM)	Student Space (30)	
B00D - R0045 - Special Learning Space - (67.39 SQM) - Teaching Space: 1	Student Space (31)	
B00D - R0047 - General Learning Space - Type 1 - (59.72 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0048 - General Learning Space - Type 1 - (57.67 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R1003 - Movement - (30.98 SQM)	Not Applicable	Circulation or storage space.
B00D - R1005 - Staff Study - (52.78 SQM)	Office (13)	
B00D - R1006 - Senior Study - (66.11 SQM)	Office (16)	
B00D - R1007 - Seminar - (53.14 SQM)	Office (13)	
B00D - R1008 - General Learning Space - (52.63 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1009 - General Learning Space - (52.85 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1013 - Movement - (36.79 SQM)	Not Applicable	Circulation or storage space.
B00D - R1014 - Audio Visual Workroom - (26.13 SQM)	Student Space (12)	
B00D - R1020 - Staff Study - (66.36 SQM)	Office (16)	
B00D - R1021 - General Learning Space - (53.15 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1023 - Music Learning Space - (52.78 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1025 - Music Learning Space - (66.36 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1027 - Movement - (10.48 SQM)	Not Applicable	Circulation or storage space.
B00D - R1035 - Staff Study - (12.75 SQM)	Office (3)	
B00E - R0001 - Commonroom - (114.29 SQM)	Office (28)	
B00G - R0002 - Materials Workshop - Type 2 - (116.73 SQM)	Student Space (54)	
B00G - R0004 - Outdoor Workshop - (94.36 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0007 - Welding/Hot Metals Area - (12.28 SQM)	Not Applicable	Circulation or storage space.
B00G - R0008 - Materials Workshop - Type 2 - (117.35 SQM)	● Student Space (54)	
B00G - R0014 - Student Canteen - (5.08 SQM)	Not Applicable	Circulation or storage space.
B00G - R0015 - Student Canteen - (57.73 SQM)	Not Applicable	Circulation or storage space.
B00G - R0020 - General Learning Space - (58 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0021 - General Learning Space - (57.95 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0022 - General Learning Space - (57.8 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0023 - General Learning Space - (58 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0031 - Movement - (20.6 SQM)	Not Applicable	Circulation or storage space.
B00G - R0032 - Movement - (21.69 SQM)	Not Applicable	Circulation or storage space.
B00G - R1003 - Visual Arts Workshop - (100.56 SQM)	● Student Space (46)	
B00G - R1007 - Visual Arts Workshop - (100.56 SQM)	● Student Space (46)	
B00G - R1009 - Computer Learning Space - (64.05 SQM) - Teaching Space: 1	● Student Space (29)	
B00G - R1010 - Art Learning Space - (60.01 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R1011 - Senior Study - (60.17 SQM)	○ Office (15)	
B00G - R1013 - Workshop - (20.94 SQM)	● Student Space (9)	
B00G - R1014 - Movement - (16.54 SQM)	Not Applicable	Circulation or storage space.
B00G - R1016 - Art Learning Space - (57.14 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R1017 - Art Learning Space - (58.05 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R1018 - Movement - (29.37 SQM)	Not Applicable	Circulation or storage space.
B00G - R1019 - Darkroom Space - (30.53 SQM)	○ Office (7)	
B00G - R1020 - Art Learning Space - (60.15 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R1021 - Art Learning Space - (58.38 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R1024 - Art Learning Space - (116.46 SQM) - Teaching Space: 1	● Student Space (54)	
B00G - R1029 - Movement - (8.24 SQM)	Not Applicable	Circulation or storage space.
B00G - R1030 - Movement - (8.24 SQM)	Not Applicable	Circulation or storage space.
B00G - R2001 - General Learning Space - (59.59 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R2002 - Science Laboratory - (97.45 SQM)	● Student Space (45)	
B00G - R2003 - Study Space - (23.93 SQM)	Not Applicable	Circulation or storage space.
B00G - R2004 - Science Laboratory - (103.96 SQM)	● Student Space (48)	
B00G - R2005 - Preparation - (59.63 SQM)	Not Applicable	Circulation or storage space.
B00G - R2008 - Science Laboratory - (103.63 SQM)	● Student Space (48)	
B00G - R2009 - General Learning Space - (58.54 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R2010 - General Learning Space - (58.38 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R2013 - Movement - (12.42 SQM)	Not Applicable	Circulation or storage space.
B00G - R2015 - General Learning Space - (61.97 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R2016 - General Learning Space - (59.22 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R2017 - Movement - (16.51 SQM)	Not Applicable	Circulation or storage space.
B00G - R2018 - General Learning Space - (57.34 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R2024 - Movement - (8.24 SQM)	Not Applicable	Circulation or storage space.
B00G - R2025 - Movement - (8.24 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Clinic - Boys - (13.26 SQM)	○ Office (3)	
B00H - R0003 - Clinic - Girls - (13.58 SQM)	○ Office (3)	
B00H - R0004 - Interview/Office - Type 1 - (13.71 SQM)	○ Office (3)	
B00H - R0005 - Public Reception - (19.03 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Interview/Meeting - (13.17 SQM)	○ Office (3)	
B00H - R0007 - Interview/Meeting - (13.32 SQM)	○ Office (3)	
B00H - R0008 - Movement - (23.84 SQM)	Not Applicable	Circulation or storage space.
B00H - R0012 - Interview/Meeting - (14.09 SQM)	○ Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0013 - Principal Office - (23.93 SQM)	Office (5)	
B00H - R0015 - Tea Room - (5.51 SQM)	Not Applicable	Circulation or storage space.
B00H - R0018 - Administration - Clerical - (56.79 SQM)	Office (14)	
B00H - R0019 - Administration - Executive - (15.45 SQM)	Office (3)	
B00H - R0020 - Deputy Principal Office - (13.03 SQM)	Office (3)	
B00H - R0021 - Movement - (21.15 SQM)	Not Applicable	Circulation or storage space.
B00H - R0022 - Deputy Principal Office - (14.45 SQM)	Office (3)	
B00H - R0023 - Public Entry - (19.83 SQM)	Not Applicable	Circulation or storage space.
B00H - R0024 - Interview/Office - Type 1 - (13.33 SQM)	Office (3)	
B00H - R0025 - Interview/Office - Type 1 - (13.71 SQM)	Office (3)	
B00H - R0026 - Student Reception - (27.6 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Multi-Purpose Space - (518.35 SQM)	Student Space (240)	
B00J - R0002 - Preparation - (15.23 SQM)	Not Applicable	Circulation or storage space.
B00J - R0003 - Staff Study - (18.74 SQM)	Office (4)	
B00J - R0010 - Stage - (67.41 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Main Area - (389.95 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Workroom - (49 SQM)	Office (12)	
B00L - R0003 - Audio Visual Workroom - (26.86 SQM)	Student Space (12)	
B00L - R0004 - Seminar - (14.35 SQM)	Office (3)	
B00L - R0005 - Seminar - (13.11 SQM)	Office (3)	
B00L - R0006 - Seminar - (14.4 SQM)	Office (3)	
B00L - R0011 - Seminar - (7.99 SQM)	Office (1)	
B0AD - R0017 - General Learning Space - Type 1 - (66.86 SQM) - Teaching Space: 1	Student Space (31)	
B0AD - R0018 - Performance Workshop - (100.52 SQM)	Student Space (46)	
B0AD - R0019 - Practice/Seminar - (18.37 SQM)	Not Applicable	Circulation or storage space.
B0AG - R0005 - Movement - (25.5 SQM)	Not Applicable	Circulation or storage space.
B0DT - R0024 - Fitness Laboratory - (99.4 SQM)	Student Space (46)	
B0DT - R0027 - General Learning Space - Type 7 - (66.48 SQM) - Teaching Space: 1	Student Space (30)	
B0DT - R0028 - General Learning Space - Type 1 - (53.43 SQM) - Teaching Space: 1	Student Space (24)	
B0G2 - R0002 - Study Space - (24.36 SQM)	Not Applicable	Circulation or storage space.
B0TF - R0008 - Preparation - (17.25 SQM)	Not Applicable	Circulation or storage space.
B0TF - R0009 - Food Technology L.S. - (72.72 SQM) - Teaching Space: 1	Student Space (33)	
B0TF - R0021 - Movement - (6.99 SQM)	Not Applicable	Circulation or storage space.
B0TF - R0022 - Seminar/Technology Space - (26.72 SQM)	Office (6)	
B0TF - R0023 - Food Technology L.S. - (111.97 SQM) - Teaching Space: 1	Student Space (51)	
BWW1 - R0005 - Music Learning Space - (43.2 SQM) - Teaching Space: 1	Student Space (20)	
BWW1 - R0006 - Practice/Seminar - (34.11 SQM)	Not Applicable	Circulation or storage space.
OS 600 17426 - OS 600 17426 - Learning Unit - Small - (57 SQM)	Student Space (26)	