

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Murray High School (8505)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Albury</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Albury</b>

8505 - Murray High School  
Site Plan (10572)



1:1,677

Printed: 06-Jul-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Ancillary Staff - (22.86 SQM)	Office (5)	
B00A - R0002 - Deputy Principal Office - (16.15 SQM)	Office (4)	
B00A - R0008 - Principal Office - (26.59 SQM)	Office (6)	
B00A - R0010 - Leading Teacher - (13.41 SQM)	Office (3)	
B00A - R0020 - Staff Study - (12.63 SQM)	Office (3)	
B00A - R0025 - Interview/Office - Type 1 - (13.1 SQM)	Office (3)	
B00A - R0026 - Clinic - Boys - (12.58 SQM)	Office (3)	
B00A - R0027 - Interview/Office - Type 1 - (13.09 SQM)	Office (3)	
B00A - R0028 - Clinic - Girls - (12.74 SQM)	Office (3)	
B00A - R0030 - Laboratory L.S. - (90.71 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R0033 - Laboratory L.S. - (90.8 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R0034 - Staff Study - (32.2 SQM)	Office (8)	
B00A - R0036 - Movement - (111.6 SQM)	Not Applicable	Circulation or storage space.
B00A - R0041 - Movement - (14.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R0043 - Movement - (32.5 SQM)	Not Applicable	Circulation or storage space.
B00A - R0046 - Staff Study - (12.28 SQM)	Office (3)	
B00A - R0051 - Movement - (10.75 SQM)	Not Applicable	Circulation or storage space.
B00A - R0052 - Movement - (8.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0054 - Movement - (30 SQM)	Not Applicable	Circulation or storage space.
B00A - R0055 - Commonroom - (107.45 SQM)	Office (26)	
B00A - R0056 - Staff Kitchen - (17.68 SQM)	Office (4)	
B00A - R0057 - Staff Kitchen - (6.65 SQM)	Office (1)	
B00A - R0058 - Commonroom - (86.77 SQM)	Office (21)	
B00A - R0059 - Movement - (18.9 SQM)	Not Applicable	Circulation or storage space.
B00A - R0060 - Movement - (20.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R0061 - Movement - (37.6 SQM)	Not Applicable	Circulation or storage space.
B00A - R0062 - Interview/Meeting - (12.61 SQM)	Office (3)	
B00A - R0063 - Administration - Clerical - (52.07 SQM)	Office (13)	
B00A - R0065 - Movement - (26.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R0067 - Student Reception - (13.9 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - General Learning Space - (52.82 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1002 - General Learning Space - (52.82 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1003 - General Learning Space - (52.74 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1004 - General Learning Space - (52.08 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1009 - Laboratory L.S. - (90.71 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R1013 - Laboratory L.S. - (90.79 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R1014 - Administration - Clerical - (23.24 SQM)	Office (5)	
B00A - R1016 - General Learning Space - (52.45 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1017 - General Learning Space - (52.45 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1019 - Staff Study - (21.69 SQM)	Office (5)	
B00A - R1020 - Staff Study - (30.93 SQM)	Office (7)	
B00A - R1021 - General Learning Space - (52.68 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1023 - Movement - (7.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R1026 - Movement - (17.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R1034 - Computer Room - (12.2 SQM)	Student Space (5)	
B00A - R1035 - Computer Room - (70.41 SQM)	Student Space (32)	
B00A - R1036 - Movement - (5.11 SQM)	Not Applicable	Circulation or storage space.
B00A - R1037 - Movement - (114.14 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R1038 - Movement - (137.32 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Gymnasium - (452.88 SQM)	● Student Space (210)	
B00B - R0008 - Staff Study - (9.27 SQM)	○ Office (2)	
B00B - R0009 - Staff Study - (9.21 SQM)	○ Office (2)	
B00B - R0010 - Pupil Entry - (14.2 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Pupil Entry - (5.38 SQM)	Not Applicable	Circulation or storage space.
B00B - R0020 - Student Canteen - (9.44 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Materials Technology L.S. - (184.63 SQM) - Teaching Space: 1	● Student Space (85)	
B00B - R0022 - Metal Technology Bay - (9.25 SQM)	Not Applicable	Circulation or storage space.
B00B - R0025 - Art Learning Space - (65.12 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0026 - Art Learning Space - (66.2 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0031 - Art Learning Space - (63.02 SQM) - Teaching Space: 1	● Student Space (29)	
B00B - R0039 - Staff Study - (35.33 SQM)	○ Office (8)	
B00B - R0052 - Student Canteen - (64.41 SQM)	Not Applicable	Circulation or storage space.
B00B - R0057 - Movement - (317.92 SQM)	Not Applicable	Circulation or storage space.
B00B - R0058 - Movement - (29.29 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Food Technology L.S. - (100.28 SQM) - Teaching Space: 1	● Student Space (46)	
B00B - R1006 - Design L.S. - (66.37 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R1009 - Computer Learning Space - (66.35 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R1010 - Darkroom Space - (26.12 SQM)	○ Office (6)	
B00B - R1012 - Staff Study - (40.07 SQM)	○ Office (10)	
B00B - R1013 - Design L.S. - (52.96 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1015 - Design L.S. - (52.67 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1016 - Music Learning Space - (78.83 SQM) - Teaching Space: 1	● Student Space (36)	
B00B - R1017 - Computer Learning Space - (80.35 SQM) - Teaching Space: 1	● Student Space (37)	
B00B - R1021 - Food Technology L.S. - (99.52 SQM) - Teaching Space: 1	● Student Space (46)	
B00B - R1022 - Food/Research Space - (15.97 SQM)	Not Applicable	Circulation or storage space.
B00B - R1024 - Food/Research Space - (10.34 SQM)	Not Applicable	Circulation or storage space.
B00B - R1026 - Movement - (247.58 SQM)	Not Applicable	Circulation or storage space.
B00B - R1034 - Movement - (31.88 SQM)	Not Applicable	Circulation or storage space.
B00B - R1035 - Movement - (22.41 SQM)	Not Applicable	Circulation or storage space.
B00B - R1038 - Wood Technology Bay - (87.73 SQM)	Not Applicable	Circulation or storage space.
B00B - R1039 - Wood Technology Bay - (89.75 SQM)	Not Applicable	Circulation or storage space.
B00B - R1040 - Food/Research Space - (14.32 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Seminar - (9.18 SQM)	○ Office (2)	
B00C - R0002 - Main Area - (252.63 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Audio Visual Workroom - (24.71 SQM)	● Student Space (11)	
B00C - R0005 - Workroom - (22.22 SQM)	○ Office (5)	
B00C - R0013 - Seminar - (9.26 SQM)	○ Office (2)	
B00C - R0014 - Seminar - (12.34 SQM)	○ Office (3)	
B00C - R0015 - Seminar - (11.08 SQM)	○ Office (2)	
B00C - R1001 - Main Area - (233.35 SQM)	Not Applicable	Circulation or storage space.
B00C - R1002 - Staff Study - (14.98 SQM)	○ Office (3)	
B00D - R0001 - Staff Study - (12.77 SQM)	○ Office (3)	
B00D - R0002 - Staff Study - (12.92 SQM)	○ Office (3)	
B00D - R0003 - Movement - (79.4 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - General Learning Space - (52.89 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0007 - General Learning Space - (52.52 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0008 - General Learning Space - (52.89 SQM) - Teaching Space: 1	● Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0009 - General Learning Space - (52.6 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0010 - General Learning Space - (52.74 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0013 - Multi-Purpose Space - (49.69 SQM)	● Student Space (23)	
B00D - R0015 - General Learning Space - (52.81 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0016 - General Learning Space - (52.82 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0017 - General Learning Space - (52.67 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0018 - Staff Study - (26.11 SQM)	● Office (6)	
B00D - R0019 - Movement - (42.27 SQM)	Not Applicable	Circulation or storage space.
B00D - R0020 - Movement - (18.16 SQM)	Not Applicable	Circulation or storage space.
B00D - R0021 - Movement - (56.59 SQM)	Not Applicable	Circulation or storage space.
B00D - R0022 - Movement - (20.74 SQM)	Not Applicable	Circulation or storage space.
B00D - R1005 - Computer Learning Space - (52.74 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1006 - General Learning Space - (52.88 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1007 - General Learning Space - (53.1 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1008 - General Learning Space - (52.74 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1009 - General Learning Space - (52.67 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1010 - Staff Study - (9.47 SQM)	● Office (2)	
B00D - R1011 - Staff Study - (20.19 SQM)	● Office (5)	
B00D - R1012 - Movement - (18.96 SQM)	Not Applicable	Circulation or storage space.
B00D - R1014 - Movement - (26.94 SQM)	Not Applicable	Circulation or storage space.
B00D - R1015 - Movement - (32.19 SQM)	Not Applicable	Circulation or storage space.
B00D - R1016 - Movement - (39.82 SQM)	Not Applicable	Circulation or storage space.
B00D - R1017 - Movement - (18.42 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Pupil Entry - (8.52 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Preparation - (38.04 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Laboratory L.S. - (98.45 SQM) - Teaching Space: 1	● Student Space (45)	
B00E - R1001 - Pupil Entry - (9.14 SQM)	Not Applicable	Circulation or storage space.
B00E - R1002 - Preparation - (38.54 SQM)	Not Applicable	Circulation or storage space.
B00E - R1003 - Laboratory L.S. - (98.67 SQM) - Teaching Space: 1	● Student Space (45)	
B00G - R0001 - Preparation - Materials - (52.75 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Performance Workspace - (104.8 SQM) - Teaching Space: 1	● Student Space (48)	
B0AG - R0001 - Commonroom - (7.55 SQM)	● Office (1)	
OS 601 11360 - OS 601 11360 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 13538 - OS 602 13538 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 606 19038 - OS 606 19038 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19038 - OS 606 19038 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19038 - OS 606 19038 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19038 - OS 606 19038 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	