


VENTILATION AUDIT REPORT

SCHOOL:	Murrumbidgee Regional High School (8917)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Murray
LOCAL GOVERNMENT AREA:	Griffith

8917 - Murrumbidgee Regional High School
Site Plan (11365)



1:1,529

Printed: 06-Jul-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.
















Entity Location	Audit Condition Classification (Capacity)	Comment
BOGA - R0002 - Pupil Entry - (28.48 SQM)	Not Applicable	Circulation or storage space.
BOGA - R0008 - Multi-Purpose Space - (277.2 SQM)	● Student Space (128)	
BOGA - R0011 - Movement - (10.53 SQM)	Not Applicable	Circulation or storage space.
BOGA - R0015 - Principal Office - (20.96 SQM)	○ Office (5)	
BOGA - R0016 - Administration - Clerical - (16.26 SQM)	○ Office (4)	
BOGA - R0017 - Deputy Principal Office - (19.55 SQM)	○ Office (4)	
BOGA - R0018 - General Learning Space - (52.56 SQM)	● Student Space (24)	
BOGA - R0019 - General Learning Space - (52.56 SQM) - Teaching Space: 1	● Student Space (24)	
BOGA - R0020 - General Learning Space - (52.84 SQM) - Teaching Space: 1	● Student Space (24)	
BOGA - R0021 - General Learning Space - (52.91 SQM) - Teaching Space: 1	● Student Space (24)	
BOGA - R0023 - General Learning Space - (66.31 SQM)	● Student Space (30)	
BOGA - R0024 - General Learning Space - (66.31 SQM) - Teaching Space: 1	● Student Space (30)	
BOGA - R0025 - Special Learning Space - (72.7 SQM) - Teaching Space: 1	● Student Space (33)	
BOGA - R0026 - Pupil Entry - (11.6 SQM)	Not Applicable	Circulation or storage space.
BOGA - R0033 - Movement - (10.2 SQM)	Not Applicable	Circulation or storage space.
BOGA - R0038 - Interview/Office - Type 2 - (12.01 SQM)	○ Office (3)	
BOGA - R0041 - General Assistants - (11.94 SQM)	○ Office (2)	
BOGA - R0042 - Movement - (12.02 SQM)	Not Applicable	Circulation or storage space.
BOGA - R0043 - Staff Study - (14.89 SQM)	○ Office (3)	
BOGA - R0044 - Clinic - Girls - (11.41 SQM)	○ Office (2)	
BOGA - R0048 - Commonroom - (121.52 SQM)	○ Office (30)	
BOGA - R0049 - Kitchen - Type 1 - (10.39 SQM)	● Student Space (4)	
BOGA - R0050 - Clinic - Boys - (15.12 SQM)	○ Office (3)	
BOGA - R0051 - Staff Study - (14.61 SQM)	○ Office (3)	
BOGA - R0052 - General Assistants - (14.49 SQM)	○ Office (3)	
BOGA - R0055 - General Learning Space - (51.41 SQM)	● Student Space (23)	
BOGA - R0056 - General Learning Space - (51.06 SQM)	● Student Space (23)	
BOGA - R0058 - General Learning Space - (51.26 SQM) - Teaching Space: 1	● Student Space (23)	
BOGA - R0059 - General Learning Space - (51.26 SQM) - Teaching Space: 1	● Student Space (23)	
BOGA - R0073 - Stage - (72.81 SQM)	Not Applicable	Circulation or storage space.
BOGA - R0075 - Staff Study - (8.03 SQM)	○ Office (2)	
BOGA - R0079 - Public Entry - (90.52 SQM)	Not Applicable	Circulation or storage space.
BOGA - R0082 - Movement - (5.63 SQM)	Not Applicable	Circulation or storage space.
BOGA - R0083 - Movement - (110.2 SQM)	Not Applicable	Circulation or storage space.
BOGA - R0085 - Administration - Clerical - (60.61 SQM)	○ Office (15)	
BOGA - R0086 - Movement - (16.97 SQM)	Not Applicable	Circulation or storage space.
BOGA - R0087 - Movement - (115.15 SQM)	Not Applicable	Circulation or storage space.
BOGA - R1002 - General Learning Space - (86.16 SQM)	● Student Space (39)	
BOGA - R1003 - Senior Study - (21.28 SQM)	○ Office (5)	
BOGA - R1004 - Staff Study - (16.8 SQM)	○ Office (4)	
BOGA - R1006 - Special Learning Space - (52.48 SQM) - Teaching Space: 1	● Student Space (24)	
BOGA - R1007 - General Learning Space - (53.33 SQM) - Teaching Space: 1	● Student Space (24)	
BOGA - R1008 - Movement - (87.13 SQM)	Not Applicable	Circulation or storage space.
BOGA - R1010 - Administration - Clerical - (18.99 SQM)	○ Office (4)	
BOGA - R1011 - Movement - (161.53 SQM)	Not Applicable	Circulation or storage space.
BOGA - R1014 - Staff Study - (33.53 SQM)	○ Office (8)	
BOGA - R1016 - Materials Technology L.S. - (66.76 SQM) - Teaching Space: 1	● Student Space (30)	
BOGA - R1020 - General Learning Space - (66.82 SQM) - Teaching Space: 1	● Student Space (31)	
BOGA - R1021 - Computer Learning Space - (71.2 SQM) - Teaching Space: 1	● Student Space (33)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BOGA - R1024 - General Learning Space - (67.3 SQM) - Teaching Space: 1	Student Space (31)	
BOGA - R1025 - General Learning Space - (65.98 SQM) - Teaching Space: 1	Student Space (30)	
BOGA - R1026 - Computer Learning Space - (72.7 SQM) - Teaching Space: 1	Student Space (33)	
BOGA - R1027 - Interview/Office - Type 2 - (7.02 SQM)	Office (1)	
BOGA - R1041 - Staff Study - (11.99 SQM)	Office (2)	
BOGA - R1047 - Staff Study - (37.8 SQM)	Office (9)	
BOGA - R9002 - General Assistants - (56.05 SQM)	Office (14)	
BOGB - R0006 - Art Learning Space - (64.75 SQM) - Teaching Space: 1	Student Space (30)	
BOGB - R0017 - Movement - (7.13 SQM)	Not Applicable	Circulation or storage space.
BOGB - R0019 - Movement - (8.85 SQM)	Not Applicable	Circulation or storage space.
BOGB - R1001 - Laboratory L.S. - (91.68 SQM) - Teaching Space: 1	Student Space (42)	
BOGB - R1007 - General Learning Space - (52.08 SQM) - Teaching Space: 1	Student Space (24)	
BOGB - R1009 - Welding Area - (19.93 SQM)	Not Applicable	Circulation or storage space.
BOGB - R1010 - Metal Technology Bay - (91.61 SQM)	Not Applicable	Circulation or storage space.
BOGB - R1012 - General Learning Space - (58.43 SQM) - Teaching Space: 1	Student Space (27)	
BOGB - R1017 - Laboratory L.S. - (91.6 SQM) - Teaching Space: 1	Student Space (42)	
BOGB - R1018 - Preparation - (28.52 SQM)	Not Applicable	Circulation or storage space.
BOGB - R1026 - Staff Study - (39.23 SQM)	Office (9)	
BOGB - R1027 - Preparation - Materials - (26.37 SQM)	Not Applicable	Circulation or storage space.
BOGB - R1029 - Laboratory L.S. - (100.05 SQM) - Teaching Space: 1	Student Space (46)	
BOGB - R2007 - General Learning Space - (52.36 SQM) - Teaching Space: 1	Student Space (24)	
BOGB - R2008 - Music Learning Space - (70.9 SQM) - Teaching Space: 1	Student Space (32)	
BOGB - R2011 - Computer Learning Space - (38.88 SQM) - Teaching Space: 1	Student Space (18)	
BOGB - R2014 - General Learning Space - (58.38 SQM) - Teaching Space: 1	Student Space (27)	
BOGB - R2015 - General Learning Space - (51.85 SQM) - Teaching Space: 1	Student Space (24)	
BOGB - R2020 - Design L.S. - (67.71 SQM) - Teaching Space: 1	Student Space (31)	
BOGB - R2021 - Design L.S. - (29.07 SQM) - Teaching Space: 1	Student Space (13)	
BOGB - R2024 - Art Learning Space - (51.95 SQM) - Teaching Space: 1	Student Space (24)	
BOGB - R2025 - Art Learning Space - (65.4 SQM) - Teaching Space: 1	Student Space (30)	
BOGB - R2032 - Dark Room - (32.41 SQM)	Office (8)	
BOGB - R2033 - Staff Study - (39.32 SQM)	Office (9)	
BOGC - M2001 - Main Area - (141.46 SQM)	Not Applicable	Circulation or storage space.
BOGC - M2002 - Interview/Office - Type 2 - (19.43 SQM)	Office (4)	
BOGC - M2003 - Interview/Office - Type 2 - (19.49 SQM)	Office (4)	
BOGC - R0003 - General Learning Space - (53.66 SQM) - Teaching Space: 1	Student Space (24)	
BOGC - R0004 - General Learning Space - (59.08 SQM) - Teaching Space: 1	Student Space (27)	
BOGC - R0005 - General Learning Space - (46.56 SQM) - Teaching Space: 1	Student Space (21)	
BOGC - R0009 - Movement - (21.97 SQM)	Not Applicable	Circulation or storage space.
BOGC - R0013 - Staff Study - (33.3 SQM)	Office (8)	
BOGC - R0015 - General Learning Space - (40.78 SQM) - Teaching Space: 1	Student Space (18)	
BOGC - R0018 - General Learning Space - (59.29 SQM) - Teaching Space: 1	Student Space (27)	
BOGC - R0019 - General Learning Space - (53.73 SQM) - Teaching Space: 1	Student Space (24)	
BOGC - R0021 - Movement - (83.03 SQM)	Not Applicable	Circulation or storage space.
BOGC - R0025 - Movement - (22.16 SQM)	Not Applicable	Circulation or storage space.
BOGC - R0026 - Movement - (5.03 SQM)	Not Applicable	Circulation or storage space.
BOGC - R1002 - Laboratory L.S. - (91.02 SQM) - Teaching Space: 1	Student Space (42)	
BOGC - R1006 - Laboratory L.S. - (90.92 SQM) - Teaching Space: 1	Student Space (42)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B0GC - R1009 - Laboratory L.S. - (90.64 SQM) - Teaching Space: 1	● Student Space (42)	
B0GC - R1010 - Staff Study - (45.5 SQM)	● Office (11)	
B0GC - R1012 - Laboratory L.S. - (90.92 SQM) - Teaching Space: 1	● Student Space (42)	
B0GC - R1013 - Movement - (56.7 SQM)	Not Applicable	Circulation or storage space.
B0GC - R1016 - Movement - (36.95 SQM)	Not Applicable	Circulation or storage space.
B0GC - R1020 - Preparation - Science - (48.11 SQM)	Not Applicable	Circulation or storage space.
B0GC - R1022 - Movement - (21.58 SQM)	Not Applicable	Circulation or storage space.
B0GC - R2003 - Main Area - (384.54 SQM)	Not Applicable	Circulation or storage space.
B0GC - R2008 - Movement - (36.81 SQM)	Not Applicable	Circulation or storage space.
B0GC - R2013 - Audio Visual Workroom - (28.24 SQM)	● Student Space (13)	
B0GC - R2014 - Workroom - (9.36 SQM)	● Office (2)	
B0GC - R2016 - Workroom - (18.86 SQM)	● Office (4)	
B0GC - R2022 - Movement - (36.72 SQM)	Not Applicable	Circulation or storage space.
B0GC - R2024 - Seminar - (24.88 SQM)	● Office (6)	
B0GC - R2025 - Seminar - (24.81 SQM)	● Office (6)	
B0GD - R0001 - Food Technology L.S. - (71.61 SQM)	● Student Space (33)	
B0GD - R0005 - Movement - (15.36 SQM)	Not Applicable	Circulation or storage space.
B0GD - R0013 - Food Technology L.S. - (73.93 SQM)	● Student Space (34)	
B0GD - R0014 - Staff Study - (26.65 SQM)	● Office (6)	
B0GD - R0015 - Movement - (8.06 SQM)	Not Applicable	Circulation or storage space.
B0GF - R0002 - Welding Area - (10.61 SQM)	Not Applicable	Circulation or storage space.
B0GF - R0003 - Metal Technology Bay - (11.17 SQM)	Not Applicable	Circulation or storage space.
B0GF - R0004 - Materials Technology L.S. - (83.32 SQM) - Teaching Space: 1	● Student Space (38)	
B0GF - R0005 - Computer Learning Space - (17.41 SQM) - Teaching Space: 1	● Student Space (8)	
B0GI - R0002 - Staff Study - (22.09 SQM)	● Office (5)	
B0GJ - R0001 - Audio Visual Workroom - (76.93 SQM)	● Student Space (35)	
B0GJ - R0005 - Practice/Seminar - (11.29 SQM)	Not Applicable	Circulation or storage space.
B0GJ - R0006 - Practice/Seminar - (11.35 SQM)	Not Applicable	Circulation or storage space.
B0GJ - R0007 - Audio Visual Workroom - (79.64 SQM)	● Student Space (36)	
B0GK - R0004 - Movement - (11.38 SQM)	Not Applicable	Circulation or storage space.
B0GL - R0002 - Movement - (16.85 SQM)	Not Applicable	Circulation or storage space.
B0WA - R0003 - Leading Teacher - (11.66 SQM)	● Office (2)	
B0WA - R0004 - Leading Teacher - (11.66 SQM)	● Office (2)	
B0WA - R0005 - Deputy Principal Office - (16.69 SQM)	● Office (4)	
B0WA - R0009 - Staff Study - (13.43 SQM)	● Office (3)	
B0WA - R0016 - Principal Office - (20.15 SQM)	● Office (5)	
B0WA - R0018 - General Assistants - (28.55 SQM)	● Office (7)	
B0WA - R0019 - Movement - (15.65 SQM)	Not Applicable	Circulation or storage space.
B0WA - R0022 - Staff Study - (13.74 SQM)	● Office (3)	
B0WA - R0023 - Staff Study - (16.29 SQM)	● Office (4)	
B0WA - R0027 - Student Waiting - (23.9 SQM)	Not Applicable	Circulation or storage space.
B0WA - R0028 - Interview/Office - Type 1 - (9.56 SQM)	● Office (2)	
B0WA - R0029 - Interview/Office - Type 2 - (12.3 SQM)	● Office (3)	
B0WA - R0030 - Administration - Clerical - (56.1 SQM)	● Office (14)	
B0WA - R0031 - Student Reception - (18.16 SQM)	Not Applicable	Circulation or storage space.
B0WA - R0032 - Movement - (59.48 SQM)	Not Applicable	Circulation or storage space.
B0WD - R0001 - Food Technology L.S. - (82.09 SQM) - Teaching Space: 1	● Student Space (38)	
B0WD - R0002 - Movement - (86.74 SQM)	Not Applicable	Circulation or storage space.
B0WD - R0008 - Staff Study - (31.91 SQM)	● Office (7)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BOWD - R0009 - Commonroom - (82.08 SQM)	Office (20)	
BOWD - R0021 - Food Technology L.S. - (104.52 SQM) - Teaching Space: 1	Student Space (48)	
BOWD - R0022 - Food/Research Space - (31.92 SQM)	Not Applicable	Circulation or storage space.
BOWD - R1001 - Art Learning Space - (65.9 SQM) - Teaching Space: 1	Student Space (30)	
BOWD - R1004 - Materials Technology L.S. - (65.83 SQM) - Teaching Space: 1	Student Space (30)	
BOWD - R1005 - Movement - (59.5 SQM)	Not Applicable	Circulation or storage space.
BOWD - R1009 - Art Learning Space - (65.75 SQM) - Teaching Space: 1	Student Space (30)	
BOWD - R1014 - Staff Study - (32.45 SQM)	Office (8)	
BOWD - R1016 - Computer Room - (23.79 SQM)	Student Space (11)	
BOWD - R1017 - Art Learning Space - (40.35 SQM) - Teaching Space: 1	Student Space (18)	
BOWD - R1019 - Music Learning Space - (131.79 SQM) - Teaching Space: 1	Student Space (61)	
BOWG - R0001 - General Assistants - (33.68 SQM)	Office (8)	
BOWG - R0002 - General Assistants - (13.67 SQM)	Office (3)	
BOWM - R0005 - Metal Technology Bay - (83.46 SQM)	Not Applicable	Circulation or storage space.
BOWM - R0006 - Welding Area - (9.45 SQM)	Not Applicable	Circulation or storage space.
BOWM - R0008 - Metal Technology Bay - (83.28 SQM)	Not Applicable	Circulation or storage space.
BOWM - R0009 - Computer Learning Space - (17.42 SQM) - Teaching Space: 1	Student Space (8)	
BOWM - R0010 - Design L.S. - (66.73 SQM) - Teaching Space: 1	Student Space (30)	
BOWM - R0014 - Movement - (37.88 SQM)	Not Applicable	Circulation or storage space.
BOWM - R0016 - Music Learning Space - (10.79 SQM) - Teaching Space: 1	Student Space (5)	
BOWM - R0017 - Music Learning Space - (72.5 SQM) - Teaching Space: 1	Student Space (33)	
BOWM - R0018 - Music Learning Space - (10.85 SQM) - Teaching Space: 1	Student Space (5)	
BOWM - R0020 - Staff Study - (28.39 SQM)	Office (7)	
BOWM - R0022 - Music Learning Space - (10.89 SQM) - Teaching Space: 1	Student Space (5)	
BOWM - R0023 - Music Learning Space - (10.83 SQM) - Teaching Space: 1	Student Space (5)	
BOWM - R0024 - Music Learning Space - (72.5 SQM) - Teaching Space: 1	Student Space (33)	
BOWM - R1001 - Design L.S. - (52.86 SQM) - Teaching Space: 1	Student Space (24)	
BOWM - R1003 - Wood Technology Bay - (83.28 SQM)	Not Applicable	Circulation or storage space.
BOWM - R1008 - Wood Technology Bay - (83.28 SQM)	Not Applicable	Circulation or storage space.
BOWM - R1010 - Design L.S. - (52.72 SQM) - Teaching Space: 1	Student Space (24)	
BOWM - R1011 - Staff Study - (25.81 SQM)	Office (6)	
BOWM - R1014 - Movement - (46.04 SQM)	Not Applicable	Circulation or storage space.
BOWS - R0001 - Multi-Purpose Space - (309.18 SQM)	Student Space (143)	
BOWS - R0002 - Movement - (78.39 SQM)	Not Applicable	Circulation or storage space.
BOWS - R0013 - Student Canteen - (54.53 SQM)	Not Applicable	Circulation or storage space.
BOWS - R1002 - Movement - (66.35 SQM)	Not Applicable	Circulation or storage space.
BOWS - R1005 - Darkroom Space - (9.24 SQM)	Office (2)	
BOWS - R1011 - Darkroom Space - (9.32 SQM)	Office (2)	
BOWV - R0002 - General Learning Space - (46.37 SQM)	Student Space (21)	
BOWV - R0003 - General Learning Space - (46.23 SQM) - Teaching Space: 1	Student Space (21)	
BGA1 - R0001 - Student Canteen - (41.69 SQM)	Not Applicable	Circulation or storage space.
BGA1 - R0002 - Student Canteen - (38.93 SQM)	Not Applicable	Circulation or storage space.
BGA1 - R0005 - General Learning Space - (62.26 SQM) - Teaching Space: 1	Student Space (28)	
BGA1 - R0007 - Movement - (19.34 SQM)	Not Applicable	Circulation or storage space.
BGA1 - R0008 - Movement - (23.19 SQM)	Not Applicable	Circulation or storage space.
BGG1 - R0001 - Materials Technology L.S. - (112.09 SQM) - Teaching Space: 1	Student Space (52)	
BGG1 - R0004 - Wood Technology Bay - (6.57 SQM)	Not Applicable	Circulation or storage space.
BWC2 - R0001 - General Learning Space - (52.21 SQM) - Teaching Space: 1	Student Space (24)	
BWC2 - R0002 - General Learning Space - (53.38 SQM) - Teaching Space: 1	Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BWC2 - R0005 - Computer Learning Space - (52.64 SQM) - Teaching Space: 1	● Student Space (24)	
BWC2 - R0009 - General Learning Space - (52.5 SQM) - Teaching Space: 1	● Student Space (24)	
BWC2 - R0010 - Computer Learning Space - (53.08 SQM) - Teaching Space: 1	● Student Space (24)	
BWC2 - R0020 - Staff Study - (43.5 SQM)	○ Office (10)	
BWC2 - R0021 - Staff Study - (16.48 SQM)	○ Office (4)	
BWC2 - R0023 - Movement - (86.18 SQM)	Not Applicable	Circulation or storage space.
BWC2 - R0030 - Staff Lounge - (39.41 SQM)	○ Office (9)	
BWC2 - R1001 - General Learning Space - (53.23 SQM) - Teaching Space: 1	● Student Space (24)	
BWC2 - R1002 - General Learning Space - (53.09 SQM) - Teaching Space: 1	● Student Space (24)	
BWC2 - R1003 - Special Learning Space - (17.14 SQM) - Teaching Space: 1	● Student Space (7)	
BWC2 - R1009 - General Learning Space - (52.94 SQM) - Teaching Space: 1	● Student Space (24)	
BWC2 - R1020 - Movement - (70.08 SQM)	Not Applicable	Circulation or storage space.
BWC2 - R1021 - General Learning Space - (46.99 SQM) - Teaching Space: 1	● Student Space (21)	
BWC2 - R1022 - General Learning Space - (46.48 SQM) - Teaching Space: 1	● Student Space (21)	
BWC2 - R1024 - Staff Study - (45.41 SQM)	○ Office (11)	
BWC2 - R1027 - General Learning Space - (46.29 SQM) - Teaching Space: 1	● Student Space (21)	
BWC2 - R1028 - General Learning Space - (47.85 SQM) - Teaching Space: 1	● Student Space (22)	
BWC3 - R0001 - Workroom - (13.07 SQM)	○ Office (3)	
BWC3 - R0002 - Study Space - (55.11 SQM)	Not Applicable	Circulation or storage space.
BWC3 - R0003 - Clinic - Boys - (12.96 SQM)	○ Office (3)	
BWC3 - R0004 - Senior Study - (13.04 SQM)	○ Office (3)	
BWC3 - R0005 - Movement - (69.5 SQM)	Not Applicable	Circulation or storage space.
BWC3 - R0014 - Study Space - (19.1 SQM)	Not Applicable	Circulation or storage space.
BWC3 - R0017 - Main Area - (224.21 SQM)	Not Applicable	Circulation or storage space.
BWC3 - R0022 - Interview/Office - Type 1 - (6.69 SQM)	○ Office (1)	
BWC3 - R1001 - General Learning Space - (53.52 SQM) - Teaching Space: 1	● Student Space (24)	
BWC3 - R1002 - General Learning Space - (53.6 SQM) - Teaching Space: 1	● Student Space (24)	
BWC3 - R1003 - Movement - (18.91 SQM)	Not Applicable	Circulation or storage space.
BWC3 - R1005 - General Learning Space - (53.6 SQM) - Teaching Space: 1	● Student Space (24)	
BWC3 - R1006 - General Learning Space - (52.49 SQM) - Teaching Space: 1	● Student Space (24)	
BWC3 - R1009 - Staff Study - (39.21 SQM)	○ Office (9)	
BWC3 - R1010 - Movement - (20.27 SQM)	Not Applicable	Circulation or storage space.
BWC3 - R1012 - General Learning Space - (53.08 SQM) - Teaching Space: 1	● Student Space (24)	
BWC3 - R1013 - General Learning Space - (59.8 SQM) - Teaching Space: 1	● Student Space (27)	
BWC3 - R1014 - General Learning Space - (59.6 SQM) - Teaching Space: 1	● Student Space (27)	
BWC3 - R1017 - Staff Study - (19.82 SQM)	○ Office (4)	
BWL1 - R0002 - Movement - (91.43 SQM)	Not Applicable	Circulation or storage space.
BWL1 - R0016 - Computer Room - (74.74 SQM)	● Student Space (34)	
BWL1 - R0017 - Staff Lounge - (16.03 SQM)	○ Office (4)	
BWL1 - R1002 - Laboratory L.S. - (91.5 SQM) - Teaching Space: 1	● Student Space (42)	
BWL1 - R1005 - Preparation - (31 SQM)	Not Applicable	Circulation or storage space.
BWL1 - R1008 - Laboratory L.S. - (91.51 SQM) - Teaching Space: 1	● Student Space (42)	
BWL2 - R0006 - Laboratory L.S. - (87.85 SQM) - Teaching Space: 1	● Student Space (40)	
BWL2 - R0013 - Laboratory L.S. - (87.21 SQM) - Teaching Space: 1	● Student Space (40)	
BWL2 - R0015 - Preparation - (42.54 SQM)	Not Applicable	Circulation or storage space.
BWL2 - R1002 - Pupil Entry - (5.41 SQM)	Not Applicable	Circulation or storage space.
BWL2 - R1006 - Laboratory L.S. - (87.94 SQM) - Teaching Space: 1	● Student Space (40)	
BWL2 - R1012 - Laboratory L.S. - (88.49 SQM) - Teaching Space: 1	● Student Space (41)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BWL2 - R1016 - Preparation - (44.09 SQM)	Not Applicable	Circulation or storage space.
OS 502 14368 - OS 502 14368 - Admin Staff/Principal/Clerk/Dup/Clinic - (152 SQM)	 Office (38)	
OS 505 12429 - OS 505 12429 - Admin Staff/Principal/Secure Store - (76 SQM)	 Office (19)	
OS 521 16342 - OS 521 16342 - Staff Study - (76 SQM)	 Office (19)	
OS 531 12473 - OS 531 12473 - Library - (76 SQM)	 Student Space (35)	
OS 600 19619 - OS 600 19619 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 19621 - OS 600 19621 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 19645 - OS 600 19645 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 19646 - OS 600 19646 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 19647 - OS 600 19647 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 19648 - OS 600 19648 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 601 11003 - OS 601 11003 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 12148 - OS 601 12148 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 12430 - OS 601 12430 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 15374 - OS 601 15374 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 750 12433 - OS 750 12433 - Learning Unit - ESL - (38 SQM)	 Student Space (17)	
OS 801 11131 - OS 801 11131 - FSU - (57 SQM)	Not Applicable	Circulation or storage space.