


VENTILATION AUDIT REPORT

SCHOOL:	Murrumburrah High School (8328)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Cootamundra
LOCAL GOVERNMENT AREA:	Hilltops

8328 - Murrumburrah High School
Site Plan (10099)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - M0001 - Senior Study - (20.15 SQM)	Office (5)	
B00A - M1001 - General Learning Space - (42.27 SQM) - Teaching Space: 1	Student Space (19)	
B00A - R0004 - Student Canteen - (11.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - General Learning Space - (64.22 SQM) - Teaching Space: 1	Student Space (29)	
B00A - R0009 - General Learning Space - (85.23 SQM) - Teaching Space: 1	Student Space (39)	
B00A - R0011 - Art Learning Space - (58.86 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0016 - Movement - (71.77 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Entry - (15.54 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Movement - (76.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Administration - Clerical - (24.51 SQM)	Office (6)	
B00A - R0020 - Clinic - Boys - (12.32 SQM)	Office (3)	
B00A - R0023 - Clinic - Girls - (13.4 SQM)	Office (3)	
B00A - R0026 - Interview/Office - Type 1 - (13.32 SQM)	Office (3)	
B00A - R0028 - Seminar - (24.75 SQM)	Office (6)	
B00A - R0029 - Commonroom - (74.47 SQM)	Office (18)	
B00A - R0030 - Movement - (72.45 SQM)	Not Applicable	Circulation or storage space.
B00A - R0031 - Commonroom - (19.25 SQM)	Office (4)	
B00A - R0032 - Interview/Office - Type 1 - (13.44 SQM)	Office (3)	
B00A - R0033 - Interview/Office - Type 1 - (13.43 SQM)	Office (3)	
B00A - R0034 - Deputy Principal Office - (18.18 SQM)	Office (4)	
B00A - R0035 - Principal Office - (23.93 SQM)	Office (5)	
B00A - R0036 - Duplicating Workroom - (24.25 SQM)	Office (6)	
B00A - R0039 - Movement - (117.89 SQM)	Not Applicable	Circulation or storage space.
B00A - R0040 - Movement - (131.36 SQM)	Not Applicable	Circulation or storage space.
B00A - R0043 - Staff Study - (30.7 SQM)	Office (7)	
B00A - R0044 - Laboratory L.S. - (90.73 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R0045 - Preparation - (46.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R0047 - Laboratory L.S. - (90.73 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R0048 - Laboratory L.S. - (91.09 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R0050 - Interview/Office - Type 1 - (27.89 SQM)	Office (6)	
B00A - R0054 - Movement - (67.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R0055 - Movement - (117.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R0056 - Movement - (48.37 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Movement - (86.94 SQM)	Not Applicable	Circulation or storage space.
B00A - R1005 - General Learning Space - (50.03 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1006 - General Learning Space - (51.91 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1007 - General Learning Space - (50.91 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1009 - Staff Study - (35.86 SQM)	Office (8)	
B00A - R1009 - Staff Study - (35.86 SQM)	Office (8)	
B00A - R1013 - Movement - (81.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R1014 - Computer Learning Space - (56.94 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1017 - Computer Learning Space - (46.31 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R1020 - Duplicating Workroom - (14.95 SQM)	Office (3)	
B00A - R1021 - Main Area - (190.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R1022 - Seminar - (13.26 SQM)	Office (3)	
B00A - R1023 - Audio Visual Workroom - (12.97 SQM)	Student Space (6)	
B00A - R1025 - Workroom - (20.9 SQM)	Office (5)	
B00A - R1038 - Staff Study - (20.4 SQM)	Office (5)	
B00A - R1039 - General Learning Space - (50.67 SQM) - Teaching Space: 1	Student Space (23)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R1041 - General Learning Space - (51.19 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1042 - Tiered Learning Area - (105.9 SQM)	● Student Space (49)	
B00A - R1057 - Movement - (244.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R1059 - Food Technology L.S. - (32.06 SQM) - Teaching Space: 1	● Student Space (14)	
B00A - R1060 - Kitchen - Type 1 - (102.82 SQM)	● Student Space (47)	
B00A - R1064 - Preparation - Materials - (14.37 SQM)	Not Applicable	Circulation or storage space.
B00A - R1066 - General Learning Space - (43.09 SQM) - Teaching Space: 1	● Student Space (19)	
B00A - R1067 - Movement - (7.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R1068 - Hospitality Space - (8.53 SQM)	● Student Space (3)	
B00B - R0001 - Wood Technology Bay - (85.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Staff Study - (14.75 SQM)	● Office (3)	
B00B - R0003 - Movement - (37 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Welding Area - (9.54 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Metal Technology Bay - (82.53 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Staff Study - (33.79 SQM)	● Office (8)	
B00B - R0009 - Movement - (39.67 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Movement - (31.58 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Movement - (17.27 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Darkroom Space - (16.49 SQM)	● Office (4)	
B00C - R0008 - Multi-Purpose Space - (322.21 SQM)	● Student Space (149)	
B00C - R0012 - Staff Kitchen - (10.67 SQM)	● Office (2)	
B00C - R0017 - Stage - (82.24 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Movement - (5.88 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Movement - (38.17 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Gymnasium - (58.25 SQM)	● Student Space (27)	