


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Murwillumbah East Public School (4101)</b>
<b>AMU REGION:</b>	<b>North Coast</b>
<b>STATE ELECTORATE:</b>	<b>Lismore</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Tweed</b>

4101 - Murwillumbah East Public School  
Site Plan (11209)



1:924

Printed: 15-Aug-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Canteen - (48.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Movement - (78.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Movement - (213.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Principal - (18.94 SQM)	Office (4)	
B00A - R1002 - Interview - (8.98 SQM)	Office (2)	
B00A - R1005 - Entry Vestibule - (19.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R1009 - Home Base - (107.91 SQM) - Teaching Space: 1	Student Space (50)	
B00A - R1010 - Home Base - (67 SQM) - Teaching Space: 1	Student Space (31)	
B00A - R1011 - Movement - (6.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R1012 - Deputy Principal - (9.74 SQM)	Office (2)	
B00A - R1016 - Movement - (8.73 SQM)	Not Applicable	Circulation or storage space.
B00A - R1020 - Sick Bay - (7.83 SQM)	Student Space (3)	
B00A - R1021 - Special Programs Room - (53.51 SQM)	Student Space (24)	
B00A - R1022 - Home Base - (53.44 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1023 - Home Base - (53.44 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1024 - Home Base - (53.44 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1025 - Home Base - (53.51 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1027 - Staff Room Annexe - (14.54 SQM)	Office (3)	
B00A - R1030 - Movement - (17.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R1037 - Staff Room - (40.75 SQM)	Office (10)	
B00A - R1038 - Staff Kitchen - (10.45 SQM)	Office (2)	
B00A - R1039 - Movement - (6.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R1040 - Clerical/Printing - (8.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R1041 - Clerical Office - (21.13 SQM)	Office (5)	
B00A - R1042 - Sick Bay - (7.2 SQM)	Student Space (3)	
B00A - R1043 - Movement - (59.77 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Movement - (43.23 SQM)	Not Applicable	Circulation or storage space.
B00B - R1002 - Home Base - (53.21 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1004 - Home Base - (53.43 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0002 - Practical Activities - 1hb - (15.11 SQM)	Student Space (7)	
B00C - R0003 - Home Base - (58.81 SQM)	Student Space (27)	
B00C - R0005 - Withdrawal Space - 1hb - (11.49 SQM)	Student Space (5)	
B00C - R0009 - Home Base - (58.79 SQM)	Student Space (27)	
B00C - R0010 - Practical Activities - 1hb - (15.03 SQM)	Student Space (6)	
B00C - R0012 - Practical Activities - 1hb - (14.82 SQM)	Student Space (6)	
B00C - R0013 - Home Base - (58.91 SQM)	Student Space (27)	
B00C - R0015 - Withdrawal Space - 1hb - (11.52 SQM)	Student Space (5)	
B00C - R0017 - Home Base - (58.95 SQM)	Student Space (27)	
B00C - R0018 - Practical Activities - 1hb - (14.89 SQM)	Student Space (6)	
B00D - R0003 - Entry Vestibule - (13.22 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Dental Clinic - (9.51 SQM)	Office (2)	
B00D - R0007 - Dental Clinic - (9.9 SQM)	Office (2)	
B00D - R0008 - Movement - (13.93 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Dental Clinic - (5.15 SQM)	Office (1)	
B00D - R0010 - Staff Room - (8.29 SQM)	Office (2)	
B00D - R0011 - Clerical Office - (9.64 SQM)	Office (2)	
B00E - R0004 - Reading Area - (171.59 SQM)	Student Space (79)	
B00H - R0002 - Communal Space - (171.47 SQM)	Student Space (79)	
B00H - R0003 - Raised Platform - (48.48 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0015 - Movement - (9.35 SQM)	Not Applicable	Circulation or storage space.
OS 534 15114 - OS 534 15114 - Library/Group Study/Office/A V Store - (152 SQM)	● Student Space (70)	
OS 600 10246 - OS 600 10246 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 11823 - OS 600 11823 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 12541 - OS 600 12541 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 602 12505 - OS 602 12505 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12614 - OS 602 12614 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 626 10242 - OS 626 10242 - Double Learning Unit - H/Cap - (171 SQM)	● Student Space (79)	