

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Murwillumbah Public School (2687)</b>
<b>AMU REGION:</b>	<b>North Coast</b>
<b>STATE ELECTORATE:</b>	<b>Lismore</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Tweed</b>

2687 - Murwillumbah Public School  
Site Plan (11450)














1:605

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (11.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Staff Room Annexe - (16.42 SQM)	Office (4)	
B00A - R0003 - Interview - (11.76 SQM)	Office (2)	
B00A - R0004 - Movement - (24.06 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Staff Room - (66.31 SQM)	Office (16)	
B00A - R0010 - Clerical Office - (8.07 SQM)	Office (2)	
B00A - R0011 - Sick Bay - (7.92 SQM)	Student Space (3)	
B00A - R0012 - Duplicating Workroom - (13 SQM)	Office (3)	
B00A - R0013 - Clerical Office - (12.6 SQM)	Office (3)	
B00A - R0014 - Entry Vestibule - (7.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Principal - (17.32 SQM)	Office (4)	
B00A - R0016 - Deputy Principal - (11.95 SQM)	Office (2)	
B00A - R0017 - Deputy Principal - (11.95 SQM)	Office (2)	
B00A - R0020 - Movement - (14.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Reading Area - (181.1 SQM)	Student Space (84)	
B00A - R1002 - Seminar/Study - (8.2 SQM)	Office (2)	
B00A - R1005 - Movement - (10.5 SQM)	Not Applicable	Circulation or storage space.
B00A - R1011 - Seminar/Study - (10.54 SQM)	Office (2)	
B00A - R1012 - Movement - (14.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R9001 - Movement - (14.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R9003 - Canteen - (26.11 SQM)	Not Applicable	Circulation or storage space.
B00A - R9007 - Movement - (18.57 SQM)	Not Applicable	Circulation or storage space.
B00A - R9012 - Movement - (25.22 SQM)	Not Applicable	Circulation or storage space.
B00A - R9013 - Movement - (24.79 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (44.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Practical Activities - 1hb - (14.7 SQM)	Student Space (6)	
B00B - R0004 - Home Base - (74.81 SQM) - Teaching Space: 1	Student Space (34)	
B00B - R0005 - Home Base - (75.26 SQM) - Teaching Space: 1	Student Space (34)	
B00B - R0007 - Practical Activities - 1hb - (14.13 SQM)	Student Space (6)	
B00B - R0012 - Movement - (17.91 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (22.7 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Practical Activities - 1hb - (25.06 SQM)	Student Space (11)	
B00C - R0003 - Home Base - (46.5 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0004 - Home Base - (46.81 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0005 - Home Base - (53.44 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0006 - Withdrawal Space - 1hb - (17.34 SQM)	Student Space (8)	
B00C - R0007 - Movement - (44.68 SQM)	Not Applicable	Circulation or storage space.
B00C - R9003 - Movement - (7.36 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Movement - (8.22 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Movement - (23.07 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Home Base - (46.25 SQM) - Teaching Space: 1	Student Space (21)	
B00D - R0007 - Home Base - (46.29 SQM) - Teaching Space: 1	Student Space (21)	
B00D - R0008 - Withdrawal Space - 1hb - (35.61 SQM)	Student Space (16)	
B00D - R0009 - Movement - (17.26 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Home Base - (45.92 SQM) - Teaching Space: 1	Student Space (21)	
B00D - R0012 - Communal Space - (108.14 SQM)	Student Space (50)	
B00D - R0013 - Home Base - (46.68 SQM) - Teaching Space: 1	Student Space (21)	
B00D - R0014 - Home Base - (52.77 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0015 - Home Base - (47.74 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R0017 - Movement - (21.3 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0001 - Home Base - (53.51 SQM) - Teaching Space: 1	 Student Space (24)	
B00E - R0002 - Practical Activities - 1hb - (20.27 SQM)	 Student Space (9)	
B00E - R0003 - Practical Activities - 1hb - (13.85 SQM)	 Student Space (6)	
B00E - R0004 - Home Base - (53.58 SQM) - Teaching Space: 1	 Student Space (24)	
B00F - R0002 - Practical Activities - 1hb - (17.18 SQM)	 Student Space (7)	
B00F - R0003 - Home Base - (44.39 SQM) - Teaching Space: 1	 Student Space (20)	
B00F - R0004 - Practical Activities - 1hb - (15.7 SQM)	 Student Space (7)	
B00F - R0005 - Home Base - (44.44 SQM) - Teaching Space: 1	 Student Space (20)	
B00G - R0001 - Home Base - (53.23 SQM) - Teaching Space: 1	 Student Space (24)	
B00G - R0003 - Practical Activities - 1hb - (12.49 SQM)	 Student Space (5)	
B00H - R0001 - Communal Space - (146.89 SQM)	 Student Space (68)	
B00H - R0002 - Raised Platform - (58.25 SQM)	Not Applicable	Circulation or storage space.
B00H - R0016 - Movement - (7.2 SQM)	Not Applicable	Circulation or storage space.
B00H - R0017 - Movement - (12.23 SQM)	Not Applicable	Circulation or storage space.