

VENTILATION AUDIT REPORT

SCHOOL:	Muswellbrook South Public School (3876)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Upper Hunter
LOCAL GOVERNMENT AREA:	Muswellbrook

3876 - Muswellbrook South Public School
Site Plan (11210)



1:2,043

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0021 - Entry Vestibule - (28.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Interview - (14.28 SQM)	Office (3)	
B00A - R0024 - Sick Bay - (9.91 SQM)	Student Space (4)	
B00A - R0025 - Deputy Principal - (14.65 SQM)	Office (3)	
B00A - R0026 - Staff Room Annexe - (17.72 SQM)	Office (4)	
B00A - R0028 - Staff Room - (65.78 SQM)	Office (16)	
B00A - R0029 - Deputy Principal - (13.66 SQM)	Office (3)	
B00A - R0031 - Principal - (17.7 SQM)	Office (4)	
B00A - R0032 - Clerical Office/Workroom - (57.97 SQM)	Office (14)	
B00A - R0033 - Movement - (28.87 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Home Base - (58.41 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0003 - Practical Activities - 2hb - (16.53 SQM)	Student Space (7)	
B00B - R0005 - Home Base - (59.3 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0007 - Practical Activities - 1hb - (8.51 SQM)	Student Space (3)	
B00B - R0008 - Home Base - (59.06 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0001 - Home Base - (88.47 SQM) - Teaching Space: 1	Student Space (41)	
B00C - R0004 - Movement - (6.8 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Movement - (6.76 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Home Base - (88.5 SQM) - Teaching Space: 1	Student Space (41)	
B00D - R0012 - Canteen - (51.87 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Home Base - (55.35 SQM) - Teaching Space: 1	Student Space (25)	
B00G - R0005 - Movement - (6.14 SQM)	Not Applicable	Circulation or storage space.
B00G - R0007 - Home Base - (55.58 SQM) - Teaching Space: 1	Student Space (25)	
B00G - R0011 - Home Base - (55.34 SQM) - Teaching Space: 1	Student Space (25)	
B00H - R0001 - Home Base - (58.44 SQM) - Teaching Space: 1	Student Space (27)	
B00H - R0003 - Movement - (16.32 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - Home Base - (58.28 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R0002 - Movement - (9.89 SQM)	Not Applicable	Circulation or storage space.
B00I - R0004 - Home Base - (51.68 SQM) - Teaching Space: 1	Student Space (23)	
B00I - R0005 - Home Base - (51.67 SQM) - Teaching Space: 1	Student Space (23)	
B00I - R0007 - Movement - (18.28 SQM)	Not Applicable	Circulation or storage space.
B00I - R0009 - Home Base - (51.6 SQM) - Teaching Space: 1	Student Space (23)	
B00K - R0002 - Home Base - (93.58 SQM) - Teaching Space: 1	Student Space (43)	
B00K - R0003 - Staff Room Annexe - (11.56 SQM)	Office (2)	
B00K - R0004 - Withdrawal Space - 1hb - (11.05 SQM)	Student Space (5)	
B00M - R0002 - Practical Activities - (80.82 SQM)	Student Space (37)	
B00P - R0012 - Movement - (11.94 SQM)	Not Applicable	Circulation or storage space.
B00P - R0013 - Movement - (11.93 SQM)	Not Applicable	Circulation or storage space.
B00P - R0014 - Raised Platform - (68.36 SQM)	Not Applicable	Circulation or storage space.
B00P - R0015 - Communal Space - (203.71 SQM)	Student Space (94)	
B00Q - R0001 - Special Programs Room - (35.89 SQM)	Student Space (16)	
B00Q - R0010 - Reading Area - (240.55 SQM)	Student Space (111)	
B00R - R0001 - Home Base - P - (58.15 SQM) - Teaching Space: 1	Student Space (26)	
B00R - R0004 - Withdrawal - P - (8.08 SQM)	Student Space (3)	
B00R - R0005 - Practical Activities - P - 2hb - (37 SQM)	Student Space (17)	
B00R - R0009 - Home Base - P - (58.06 SQM) - Teaching Space: 1	Student Space (26)	
B00R - R0010 - Withdrawal - P - (8.08 SQM)	Student Space (3)	
B00R - R0012 - Movement - (44.57 SQM)	Not Applicable	Circulation or storage space.
B00S - R0002 - Practical Activities - 1hb - (18.92 SQM)	Student Space (8)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00S - R0004 - Home Base - (60.86 SQM) - Teaching Space: 1	● Student Space (28)	
B00S - R0005 - Withdrawal Space - 2hb - (11.53 SQM)	● Student Space (5)	
B00S - R0006 - Practical Activities - 1hb - (18.92 SQM)	● Student Space (8)	
B00S - R0007 - Home Base - (60.86 SQM) - Teaching Space: 1	● Student Space (28)	
B00S - R0009 - Practical Activities - 1hb - (20.46 SQM)	● Student Space (9)	
B00S - R0010 - Withdrawal Space - 1hb - (9.02 SQM)	● Student Space (4)	
B00S - R0011 - Special Programs Room - (58.57 SQM)	● Student Space (27)	
B00S - R0013 - Practical Activities - 1hb - (18.92 SQM)	● Student Space (8)	
B00S - R0015 - Home Base - (60.86 SQM) - Teaching Space: 1	● Student Space (28)	
B00S - R0016 - Withdrawal Space - 2hb - (11.53 SQM)	● Student Space (5)	
B00S - R0017 - Practical Activities - 1hb - (18.92 SQM)	● Student Space (8)	
B00S - R0018 - Home Base - (60.86 SQM) - Teaching Space: 1	● Student Space (28)	
B00T - R0001 - Movement - (7.79 SQM)	Not Applicable	Circulation or storage space.
OS 602 10598 - OS 602 10598 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12613 - OS 602 12613 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14050 - OS 602 14050 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14829 - OS 602 14829 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 17429 - OS 602 17429 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 19505 - OS 602 19505 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 606 19807 - OS 606 19807 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 621 10048 - OS 621 10048 - Learning Unit Single - PWD - (95 SQM)	● Student Space (44)	