

VENTILATION AUDIT REPORT

SCHOOL:	NSW School of Languages (8588)
AMU REGION:	Sydney
STATE ELECTORATE:	Newtown
LOCAL GOVERNMENT AREA:	Inner West

Siteplan

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0002 - Child Care Centre - (9.3 SQM)	● Student Space (4)	
B00F - R0003 - Child Care Centre - (45.39 SQM)	● Student Space (21)	
B00F - R0004 - Child Care Centre - (8.03 SQM)	● Student Space (3)	
B00F - R0005 - Child Care Centre - (46.03 SQM)	● Student Space (21)	
B00F - R0006 - Child Care Centre - (10.07 SQM)	● Student Space (4)	
B00F - R0009 - Child Care Centre - (10.13 SQM)	● Student Space (4)	
B00F - R0010 - Child Care Centre - (7.93 SQM)	● Student Space (3)	
B00F - R0011 - Child Care Centre - (21 SQM)	● Student Space (9)	
B00F - R003C - Child Care Centre - (13.88 SQM)	● Student Space (6)	
B00F - R003D - Child Care Centre - (6.57 SQM)	● Student Space (3)	
B0AA - R0002 - Movement - (24.17 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0011 - Kitchen - Type 1 - (82.64 SQM)	● Student Space (38)	
B0AA - R0012 - Interview/Meeting - (35.39 SQM)	● Office (8)	
B0AA - R0014 - Study Space - (19.94 SQM)	Not Applicable	Circulation or storage space.
B0AA - R1001 - General Learning Space - (53.45 SQM) - Teaching Space: 1	● Student Space (24)	
B0AA - R1002 - Movement - (8.5 SQM)	Not Applicable	Circulation or storage space.
B0AA - R1004 - Staff Study - (251.25 SQM)	● Office (62)	
B0AA - R1005 - Staff Study - (9.38 SQM)	● Office (2)	
B0AA - R1006 - Staff Study - (9.46 SQM)	● Office (2)	
B0AA - R1007 - Movement - (21.32 SQM)	Not Applicable	Circulation or storage space.
B0AA - R1008 - Kitchen - Type 1 - (45.54 SQM)	● Student Space (21)	
B0AA - R1011 - Staff Study - (170.63 SQM)	● Office (42)	
B0AA - R1012 - Staff Study - (9.4 SQM)	● Office (2)	
B0AA - R1013 - Staff Study - (15.93 SQM)	● Office (3)	
B0AA - R1015 - Movement - (8.48 SQM)	Not Applicable	Circulation or storage space.
B0AA - R2002 - Movement - (8.5 SQM)	Not Applicable	Circulation or storage space.
B0AA - R2003 - Interview/Meeting - (14.65 SQM)	● Office (3)	
B0AA - R2004 - Interview/Meeting - (25.53 SQM)	● Office (6)	
B0AA - R2006 - Staff Study - (202.34 SQM)	● Office (50)	
B0AA - R2007 - Staff Study - (9.57 SQM)	● Office (2)	
B0AA - R2008 - Staff Study - (9.58 SQM)	● Office (2)	
B0AA - R2009 - Movement - (8.5 SQM)	Not Applicable	Circulation or storage space.
B0AA - R2010 - Kitchen - Type 1 - (45.75 SQM)	● Student Space (21)	
B0AA - R2013 - Staff Study - (158.26 SQM)	● Office (39)	
B0AA - R2014 - Staff Study - (8.61 SQM)	● Office (2)	
B0AA - R2015 - Staff Study - (8.59 SQM)	● Office (2)	
B0AA - R2016 - General Learning Space - (25.46 SQM) - Teaching Space: 1	● Student Space (11)	
B0AA - R2017 - Movement - (8.51 SQM)	Not Applicable	Circulation or storage space.
B0AA - R2025 - Movement - (6.03 SQM)	Not Applicable	Circulation or storage space.
B0AA - R3001 - General Learning Space - (53.25 SQM) - Teaching Space: 1	● Student Space (24)	
B0AA - R3002 - Movement - (7.82 SQM)	Not Applicable	Circulation or storage space.
B0AA - R3003 - General Learning Space - (25.63 SQM) - Teaching Space: 1	● Student Space (11)	
B0AA - R3004 - General Learning Space - (26.8 SQM) - Teaching Space: 1	● Student Space (12)	
B0AA - R3006 - Staff Study - (8.7 SQM)	● Office (2)	
B0AA - R3007 - Staff Study - (8.06 SQM)	● Office (2)	
B0AA - R3008 - Staff Study - (198.05 SQM)	● Office (49)	
B0AA - R3009 - Movement - (7.84 SQM)	Not Applicable	Circulation or storage space.
B0AA - R3010 - Kitchen - Type 1 - (42.76 SQM)	● Student Space (19)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BOCC - R0001 - General Learning Space - (89.51 SQM) - Teaching Space: 1	● Student Space (41)	
BOCC - R0003 - Movement - (20.16 SQM)	Not Applicable	Circulation or storage space.
BOCC - R0004 - General Learning Space - (70.02 SQM) - Teaching Space: 1	● Student Space (32)	
BOCC - R1001 - General Learning Space - (89.61 SQM) - Teaching Space: 1	● Student Space (41)	
BOCC - R1003 - Movement - (7 SQM)	Not Applicable	Circulation or storage space.
BOCC - R1004 - General Learning Space - (69.79 SQM) - Teaching Space: 1	● Student Space (32)	
BODD - R0001 - Movement - (8.91 SQM)	Not Applicable	Circulation or storage space.
BODD - R0003 - Movement - (12.51 SQM)	Not Applicable	Circulation or storage space.
BODD - R0004 - Movement - (15.02 SQM)	Not Applicable	Circulation or storage space.
BODD - R0005 - General Learning Space - (58.84 SQM) - Teaching Space: 1	● Student Space (27)	
BODD - R0006 - General Learning Space - (57.96 SQM) - Teaching Space: 1	● Student Space (26)	
BODD - R1002 - Movement - (11.54 SQM)	Not Applicable	Circulation or storage space.
BODD - R1003 - Movement - (14.91 SQM)	Not Applicable	Circulation or storage space.
BODD - R1004 - General Learning Space - (38.21 SQM) - Teaching Space: 1	● Student Space (17)	
BODD - R1005 - General Learning Space - (37.89 SQM) - Teaching Space: 1	● Student Space (17)	
BODD - R1006 - General Learning Space - (37.99 SQM) - Teaching Space: 1	● Student Space (17)	
BOEE - M0001 - Audio Visual Workroom - (22.38 SQM)	● Student Space (10)	
BOEE - R0001 - Administration - Clerical - (22.67 SQM)	● Office (5)	
BOEE - R0002 - Interview/Meeting - (15.18 SQM)	● Office (3)	
BOEE - R0004 - Administration - Clerical - (59.5 SQM)	● Office (14)	
BOEE - R0007 - Multi-Purpose Space - (157.82 SQM)	● Student Space (73)	
BOEE - R0008 - Movement - (10.39 SQM)	Not Applicable	Circulation or storage space.
BOEE - R0009 - Staff Kitchen - (26.81 SQM)	● Office (6)	
BOEE - R0011 - Movement - (34.83 SQM)	Not Applicable	Circulation or storage space.
BOEE - R0012 - Staff Kitchen - (13.93 SQM)	● Office (3)	
BOEE - R0013 - Movement - (10.57 SQM)	Not Applicable	Circulation or storage space.
BOEE - R0014 - Interview/Meeting - (38.51 SQM)	● Office (9)	
BOEE - R0015 - Principal Office - (23.75 SQM)	● Office (5)	
BOEE - R0016 - Movement - (22.05 SQM)	Not Applicable	Circulation or storage space.
BOEE - R0017 - Movement - (9.34 SQM)	Not Applicable	Circulation or storage space.
BOEE - R0018 - Deputy Principal Office - (12.05 SQM)	● Office (3)	
BOEE - R0019 - Deputy Principal Office - (12.44 SQM)	● Office (3)	
BOEE - R0020 - Administration - Clerical - (20.11 SQM)	● Office (5)	
BOEE - R0022 - Multi Media Studio - (12.17 SQM)	Not Applicable	Circulation or storage space.
BOEE - R0023 - Multi Media Studio - (12.7 SQM)	Not Applicable	Circulation or storage space.
BOEE - R0024 - Administration - Clerical - (108.3 SQM)	● Office (27)	
BOEE - R0025 - Visual Arts Workshop - (18.11 SQM)	● Student Space (8)	
BOEE - R0027 - Movement - (5.88 SQM)	Not Applicable	Circulation or storage space.
BOEE - R0031 - Movement - (11.22 SQM)	Not Applicable	Circulation or storage space.