

VENTILATION AUDIT REPORT

SCHOOL:	Nambucca Heads Public School (2696)
AMU REGION:	North Coast
STATE ELECTORATE:	Oxley
LOCAL GOVERNMENT AREA:	Nambucca

2696 - Nambucca Heads Public School
Site Plan (10663)



1:938

Printed: 14-Nov-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Sick Bay - (8.66 SQM)	● Student Space (4)	
B00A - R0004 - Duplicating Workroom - (20.01 SQM)	● Office (5)	
B00A - R0005 - Clerical Office - (12.84 SQM)	● Office (3)	
B00A - R0006 - Staff Room - (49.16 SQM)	● Office (12)	
B00A - R0007 - Interview - (11.22 SQM)	● Office (2)	
B00A - R0009 - Principal - (17.44 SQM)	● Office (4)	
B00A - R0010 - Deputy Principal - (12.84 SQM)	● Office (3)	
B00A - R0012 - Home Base - (42.01 SQM) - Teaching Space: 1	● Student Space (19)	
B00A - R0013 - Practical Activities - 1hb - (16.75 SQM)	● Student Space (7)	
B00A - R0014 - Home Base - (42.04 SQM) - Teaching Space: 1	● Student Space (19)	
B00A - R0015 - Practical Activities - 1hb - (16.75 SQM)	● Student Space (7)	
B00A - R0016 - Withdrawal Space - 1hb - (20.75 SQM)	● Student Space (9)	
B00A - R0019 - Movement - (27.69 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Movement - (7.72 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Movement - (6.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R0035 - Entry Vestibule - (11.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R0036 - Clerical/Printing - (23.37 SQM)	Not Applicable	Circulation or storage space.
B00A - R0037 - Movement - (14.45 SQM)	Not Applicable	Circulation or storage space.
B00A - R9005 - Movement - (24.95 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (38.11 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Withdrawal Space - 1hb - (10.14 SQM)	● Student Space (4)	
B00B - R0006 - Movement - (15.94 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Home Base - (89.06 SQM) - Teaching Space: 1	● Student Space (41)	
B00B - R0012 - Home Base - (71.67 SQM) - Teaching Space: 1	● Student Space (33)	
B00B - R0013 - Movement - (20.29 SQM)	Not Applicable	Circulation or storage space.
B00B - R9001 - Movement - (59.13 SQM)	Not Applicable	Circulation or storage space.
B00B - R9008 - Canteen - (31.01 SQM)	Not Applicable	Circulation or storage space.
B00B - R9011 - Movement - (63.65 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (33.4 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Practical Activities - 1hb - (15.12 SQM)	● Student Space (7)	
B00C - R0004 - Home Base - (58.58 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0005 - Movement - (14.99 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Withdrawal Space - 1hb - (11.53 SQM)	● Student Space (5)	
B00C - R0007 - Movement - (14.99 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Home Base - (58.58 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0009 - Practical Activities - 1hb - (15.13 SQM)	● Student Space (7)	
B00C - R9001 - Practical Activities - (14.42 SQM)	● Student Space (6)	
B00D - R0001 - Home Base - (46.97 SQM) - Teaching Space: 1	● Student Space (21)	
B00D - R0002 - Practical Activities - 1hb - (15 SQM)	● Student Space (6)	
B00D - R0003 - Movement - (13.86 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Home Base - (60.58 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R0003 - Practical Activities - 1hb - (5.83 SQM)	● Student Space (2)	
B00E - R0004 - Movement - (19.28 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (19.82 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Movement - (6.17 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Movement - (6.7 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Communal Space - (145.43 SQM)	● Student Space (67)	
B00H - R0002 - Raised Platform - (61.12 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - Staff Kitchen - (12.89 SQM)	● Office (3)	
B00H - R0016 - Movement - (6.17 SQM)	Not Applicable	Circulation or storage space.
B00H - R0017 - Movement - (11.9 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0001 - Reading Area - (92.7 SQM)	● Student Space (43)	
OS 602 10904 - OS 602 10904 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11388 - OS 602 11388 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12120 - OS 602 12120 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13033 - OS 602 13033 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	