

VENTILATION AUDIT REPORT

SCHOOL:	Nana Glen Public School (2698)
AMU REGION:	North Coast
STATE ELECTORATE:	Coffs Harbour
LOCAL GOVERNMENT AREA:	Coffs Harbour

2698 - Nana Glen Public School
Site Plan (10768)



1:1,110

Printed: 12-Jun-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (46.51 SQM)	Office (11)	
B00A - R0002 - Movement - (9.11 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Sick Bay - (7.88 SQM)	Student Space (3)	
B00A - R0006 - Duplicating Workroom - (38.11 SQM)	Office (9)	
B00A - R0008 - Entry Vestibule - (13.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Principal - (14.32 SQM)	Office (3)	
B00A - R0012 - Reading Area - (72.61 SQM)	Student Space (33)	
B00B - R0005 - Home Base - (61.41 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0006 - Practical Activities - 1hb - (18.24 SQM)	Student Space (8)	
B00B - R0007 - Home Base - (61.4 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0008 - Withdrawal Space - 1hb - (6.03 SQM)	Student Space (2)	
B00B - R0010 - Practical Activities - 1hb - (18.22 SQM)	Student Space (8)	
B00C - R0001 - Home Base - (55.96 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R0002 - Practical Activities - 1hb - (17.23 SQM)	Student Space (7)	
B00C - R0004 - Withdrawal Space - 1hb - (12.22 SQM)	Student Space (5)	
B00C - R0005 - Home Base - (55.94 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R0007 - Practical Activities - 1hb - (17.19 SQM)	Student Space (7)	
B00E - R0002 - Canteen - (18.84 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Practical Activities - 1hb - (19.36 SQM)	Student Space (8)	
B00K - R0004 - Home Base - (59.43 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R0005 - Withdrawal Space - 2hb - (10.67 SQM)	Student Space (4)	
B00K - R0006 - Home Base - (59.28 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R0008 - Practical Activities - 1hb - (19.36 SQM)	Student Space (8)	