

# VENTILATION AUDIT REPORT












<b>SCHOOL:</b>	<b>Narellan Public School (2704)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Camden</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Camden</b>

Siteplan

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (15.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Deputy Principal - (12.85 SQM)	Office (3)	
B00A - R0003 - Interview - (13.51 SQM)	Office (3)	
B00A - R0007 - Principal - (21.03 SQM)	Office (5)	
B00A - R0008 - Staff Room Annexe - (15.13 SQM)	Office (3)	
B00A - R0012 - Movement - (13.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Sick Bay - (7.89 SQM)	Student Space (3)	
B00A - R0017 - Duplicating Workroom - (21.02 SQM)	Office (5)	
B00A - R0018 - Clerical Office - (12.77 SQM)	Office (3)	
B00A - R0019 - Entry Vestibule - (12.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Movement - (10.41 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Movement - (24.34 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Movement - (32.13 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (16.9 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Staff Room - (49.13 SQM)	Office (12)	
B00C - R0009 - Movement - (34.29 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Home Base - (57.69 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0003 - Practical Activities - 1hb - (12.04 SQM)	Student Space (5)	
B00D - R0004 - Movement - (6.57 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Home Base - (57.21 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0008 - Home Base - (85.99 SQM) - Teaching Space: 1	Student Space (39)	
B00D - R0013 - Practical Activities - 1hb - (7.42 SQM)	Student Space (3)	
B00D - R0014 - Movement - (6.59 SQM)	Not Applicable	Circulation or storage space.
B00D - R9001 - Movement - (12.1 SQM)	Not Applicable	Circulation or storage space.
B00D - R9004 - Canteen - (31.9 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Special Programs Room - (31.17 SQM)	Student Space (14)	
B00E - R0005 - Reading Area - (163.34 SQM)	Student Space (75)	
B00E - R0009 - Movement - (74.31 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Movement - (10.53 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Movement - (10.52 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Home Base - (60.22 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0009 - Withdrawal Space - 1hb - (12.17 SQM)	Student Space (5)	
B00F - R0010 - Home Base - (60.23 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0011 - Movement - (13.42 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Movement - (13.34 SQM)	Not Applicable	Circulation or storage space.
B00F - R0015 - Practical Activities - 1hb - (36.38 SQM)	Student Space (16)	
B00F - R0016 - Movement - (64.23 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Practical Activities - 1hb - (29.56 SQM)	Student Space (13)	
B00G - R0005 - Home Base - (60.38 SQM) - Teaching Space: 1	Student Space (28)	
B00G - R0006 - Home Base - (60.39 SQM) - Teaching Space: 1	Student Space (28)	
B00G - R0007 - Withdrawal Space - 1hb - (12.17 SQM)	Student Space (5)	
B00G - R0008 - Movement - (13.34 SQM)	Not Applicable	Circulation or storage space.
B00G - R0009 - Movement - (13.32 SQM)	Not Applicable	Circulation or storage space.
B00G - R0012 - Movement - (58.24 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Staff Room Annexe - (12.31 SQM)	Office (3)	
B00H - R0003 - Special Programs Room - (53.21 SQM)	Student Space (24)	
B00I - R0001 - Movement - (27.27 SQM)	Not Applicable	Circulation or storage space.
B00I - R0003 - Practical Activities - 1hb - (15.91 SQM)	Student Space (7)	
B00I - R0004 - Home Base - (59.84 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R0006 - Movement - (13.49 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00I - R0007 - Withdrawal Space - 1hb - (11.92 SQM)	 Student Space (5)	
B00I - R0008 - Movement - (13.49 SQM)	Not Applicable	Circulation or storage space.
B00I - R0010 - Home Base - (59.71 SQM) - Teaching Space: 1	 Student Space (27)	
B00I - R0011 - Practical Activities - 1hb - (15.73 SQM)	 Student Space (7)	
B00J - R0001 - Home Base - (47.35 SQM) - Teaching Space: 1	 Student Space (21)	
B00J - R0002 - Home Base - (47.08 SQM) - Teaching Space: 1	 Student Space (21)	
B00K - R0002 - Home Base - (47.13 SQM) - Teaching Space: 1	 Student Space (21)	
B00K - R0003 - Home Base - (47.21 SQM) - Teaching Space: 1	 Student Space (21)	
B00L - R0001 - Communal Space - (145.1 SQM)	 Student Space (67)	
B00L - R0002 - Raised Platform - (59.39 SQM)	Not Applicable	Circulation or storage space.
B00L - R0016 - Movement - (8.1 SQM)	Not Applicable	Circulation or storage space.
B00L - R0018 - Movement - (13.13 SQM)	Not Applicable	Circulation or storage space.
OS 602 13869 - OS 602 13869 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14434 - OS 602 14434 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 19357 - OS 602 19357 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	