

VENTILATION AUDIT REPORT

SCHOOL:	Narellan Vale Public School (4621)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Camden
LOCAL GOVERNMENT AREA:	Camden

4621 - Narellan Vale Public School
Site Plan (10540)



1:913










Printed: 29-May-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (25.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Entry Vestibule - (16.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Duplicating Workroom - (17.63 SQM)	Office (4)	
B00A - R0004 - Sick Bay - (8.18 SQM)	Student Space (3)	
B00A - R0008 - Deputy Principal - (13.16 SQM)	Office (3)	
B00A - R0009 - Interview - (13.2 SQM)	Office (3)	
B00A - R0010 - Staff Room Annexe - (24.58 SQM)	Office (6)	
B00A - R0011 - Staff Room - (57.84 SQM)	Office (14)	
B00A - R0017 - Principal - (16.38 SQM)	Office (4)	
B00A - R0018 - Clerical Office - (32.02 SQM)	Office (8)	
B00A - R0019 - Movement - (36.87 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Movement - (7.51 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Communal Space - (209.96 SQM)	Student Space (97)	
B00B - R0010 - Raised Platform - (44.66 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Movement - (9.61 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Special Programs Room - (21.03 SQM)	Student Space (9)	
B00B - R0018 - Movement - (305.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R0019 - Movement - (14.77 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Canteen - (46.77 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Special Programs Room - (41.56 SQM)	Student Space (19)	
B00D - R0006 - Movement - (30.1 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Reading Area - (219.21 SQM)	Student Space (101)	
B00D - R0011 - Movement - (7.5 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Practical Activities - 1hb - (23.53 SQM)	Student Space (10)	
B00E - R0003 - Home Base - (54.09 SQM) - Teaching Space: 1	Student Space (25)	
B00E - R0004 - Withdrawal Space - 1hb - (10.49 SQM)	Student Space (4)	
B00E - R0005 - Home Base - (54.07 SQM) - Teaching Space: 1	Student Space (25)	
B00E - R0006 - Practical Activities - 1hb - (23.53 SQM)	Student Space (10)	
B00E - R0008 - Practical Activities - 1hb - (23.73 SQM)	Student Space (11)	
B00E - R0009 - Home Base - (54.41 SQM) - Teaching Space: 1	Student Space (25)	
B00E - R0011 - Withdrawal Space - 1hb - (10.68 SQM)	Student Space (4)	
B00E - R0012 - Home Base - (54.34 SQM) - Teaching Space: 1	Student Space (25)	
B00E - R0013 - Practical Activities - 1hb - (24.06 SQM)	Student Space (11)	
B00E - R0016 - Movement - (114.41 SQM)	Not Applicable	Circulation or storage space.
B00E - R0022 - Movement - (15.97 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Practical Activities - 1hb - (26.13 SQM)	Student Space (12)	
B00F - R0003 - Home Base - (49.4 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0004 - Withdrawal Space - 1hb - (5.64 SQM)	Student Space (2)	
B00F - R0005 - Special Programs Room - (49.47 SQM)	Student Space (22)	
B00F - R0006 - Practical Activities - 1hb - (26.45 SQM)	Student Space (12)	
B00F - R0008 - Withdrawal Space - 1hb - (6.09 SQM)	Student Space (2)	
B00F - R0009 - Practical Activities - 1hb - (26.57 SQM)	Student Space (12)	
B00F - R0011 - Withdrawal Space - 1hb - (6.09 SQM)	Student Space (2)	
B00F - R0012 - Home Base - (50.21 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R0013 - Practical Activities - 1hb - (26.64 SQM)	Student Space (12)	
B00F - R0014 - Home Base - (50.15 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R0016 - Withdrawal Space - 1hb - (6.06 SQM)	Student Space (2)	
B00F - R0017 - Practical Activities - 1hb - (26.6 SQM)	Student Space (12)	
B00F - R0018 - Home Base - (49.61 SQM) - Teaching Space: 1	Student Space (23)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0020 - Withdrawal Space - 1hb - (5.99 SQM)	Student Space (2)	
B00F - R0021 - Home Base - (49.54 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0022 - Practical Activities - 1hb - (26.12 SQM)	Student Space (12)	
B00F - R0023 - Withdrawal Space - 1hb - (5.68 SQM)	Student Space (2)	
B00F - R0024 - Withdrawal Space - 1hb - (5.68 SQM)	Student Space (2)	
B00F - R0030 - Movement - (21.09 SQM)	Not Applicable	Circulation or storage space.
B00F - R0033 - Movement - (175.38 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Movement - (84.46 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Practical Activities - 1hb - (20.58 SQM)	Student Space (9)	
B00G - R0005 - Home Base - (53.38 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0006 - Withdrawal Space - 1hb - (10.93 SQM)	Student Space (5)	
B00G - R0007 - Home Base - (53.35 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0008 - Practical Activities - 1hb - (20.62 SQM)	Student Space (9)	
B00G - R0012 - Practical Activities - 1hb - (20.42 SQM)	Student Space (9)	
B00G - R0014 - Home Base - (53.46 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0015 - Withdrawal Space - 1hb - (10.89 SQM)	Student Space (5)	
B00G - R0016 - Home Base - (53.29 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0017 - Practical Activities - 1hb - (20.62 SQM)	Student Space (9)	
B00H - R0001 - Movement - (38.49 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Practical Activities - 1hb - (19.4 SQM)	Student Space (9)	
B00H - R0004 - Home Base - (59.22 SQM) - Teaching Space: 1	Student Space (27)	
B00H - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	Student Space (5)	
B00H - R0006 - Home Base - (59.21 SQM) - Teaching Space: 1	Student Space (27)	
B00H - R0008 - Practical Activities - 1hb - (19.41 SQM)	Student Space (9)	
B00I - R0001 - Movement - (38.49 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Practical Activities - 1hb - (19.4 SQM)	Student Space (9)	
B00I - R0004 - Home Base - (59.21 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	Student Space (5)	
B00I - R0006 - Home Base - (59.21 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R0008 - Practical Activities - 1hb - (19.41 SQM)	Student Space (9)	
B00J - R0002 - Practical Activities/Movement - 1hb - (20.06 SQM)	Student Space (9)	
B00J - R0004 - Home Base - (60.48 SQM) - Teaching Space: 1	Student Space (28)	
B00J - R0005 - Withdrawal Space - 2hb - (11.78 SQM)	Student Space (5)	
B00J - R0006 - Home Base - (61.46 SQM) - Teaching Space: 1	Student Space (28)	
B00J - R0008 - Practical Activities/Movement - 1hb - (18.85 SQM)	Student Space (8)	
B00J - R0010 - Practical Activities/Movement - 1hb - (19.33 SQM)	Student Space (8)	
B00J - R0011 - Withdrawal Space - 1hb - (7.64 SQM)	Student Space (3)	
B00J - R0013 - Home Base - (58.42 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R0002 - Practical Activities/Movement - 1hb - (20.06 SQM)	Student Space (9)	
B00K - R0004 - Home Base - (60.48 SQM) - Teaching Space: 1	Student Space (28)	
B00K - R0005 - Withdrawal Space - 2hb - (11.78 SQM)	Student Space (5)	
B00K - R0006 - Home Base - (61.46 SQM) - Teaching Space: 1	Student Space (28)	
B00K - R0008 - Practical Activities/Movement - 1hb - (18.85 SQM)	Student Space (8)	
B00K - R0010 - Practical Activities/Movement - 1hb - (19.33 SQM)	Student Space (8)	
B00K - R0011 - Withdrawal Space - 1hb - (7.64 SQM)	Student Space (3)	
B00K - R0013 - Home Base - (58.42 SQM) - Teaching Space: 1	Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
NS 020 10888 - NS 020 10888 - Staff Study/Store - (38 SQM)	Not Applicable	Circulation or storage space.
NS 100 13155 - NS 100 13155 - Learning Unit - Single Primary/PAA - (76 SQM)	 Student Space (35)	
NS 101 10505 - NS 101 10505 - Learning Unit - Double Primary/PAA - (133 SQM)	 Student Space (61)	
OS 602 10126 - OS 602 10126 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 11462 - OS 602 11462 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 13470 - OS 602 13470 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 13689 - OS 602 13689 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14538 - OS 602 14538 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 16277 - OS 602 16277 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 603 15284 - OS 603 15284 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	