


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Narrabeen North Public School (3906)</b>
<b>AMU REGION:</b>	<b>Northern Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Pittwater</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Northern Beaches</b>

3906 - Narrabeen North Public School  
Site Plan (11998)



1:2,251

Printed: 21-Sep-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (10.54 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Sick Bay - (6.09 SQM)	● Student Space (2)	
B00A - R0003 - Clerical Office - (12.99 SQM)	● Office (3)	
B00A - R0004 - Duplicating Workroom - (13.4 SQM)	● Office (3)	
B00A - R0005 - Principal - (26.21 SQM)	● Office (6)	
B00A - R0006 - Staff Room Annexe - (13.48 SQM)	● Office (3)	
B00A - R0010 - Deputy Principal - (12.99 SQM)	● Office (3)	
B00A - R0011 - Staff Room Annexe - (13.36 SQM)	● Office (3)	
B00A - R0015 - Movement - (44.91 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Reading Area - (228.33 SQM)	● Student Space (105)	
B00B - R0004 - Movement - (43.03 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Seminar/Study - (12.22 SQM)	● Office (3)	
B00B - R0006 - Seminar/Study - (12.93 SQM)	● Office (3)	
B00B - R0011 - Movement - (29.76 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Movement - (47.94 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Special Programs Room - (63.65 SQM)	● Student Space (29)	
B00H - R0004 - Staff Room Annexe - (13.21 SQM)	● Office (3)	
B00H - R0005 - Staff Room - (32.96 SQM)	● Office (8)	
B00H - R0006 - Staff Room - (23.34 SQM)	● Office (5)	
B00H - R0007 - Staff Kitchen - (17.12 SQM)	● Office (4)	
B00J - R0005 - Home Base - (53.46 SQM) - Teaching Space: 1	● Student Space (24)	
B00J - R0006 - Home Base - (53.46 SQM) - Teaching Space: 1	● Student Space (24)	
B00J - R0009 - Home Base - (53.31 SQM) - Teaching Space: 1	● Student Space (24)	
B00J - R0013 - Interview - (12.78 SQM)	● Office (3)	
B00J - R0015 - Movement - (95.9 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Movement - (16.71 SQM)	Not Applicable	Circulation or storage space.
B00K - R0003 - Special Programs Room - (21.86 SQM)	● Student Space (10)	
B00K - R0004 - Special Programs Room - (24.73 SQM)	● Student Space (11)	
B00K - R0008 - Special Programs Room - (47.33 SQM)	● Student Space (21)	
B00N - R0002 - Home Base - (53.3 SQM) - Teaching Space: 1	● Student Space (24)	
B00N - R0003 - Movement - (29.43 SQM)	Not Applicable	Circulation or storage space.
B00P - R0005 - Home Base - (66.6 SQM) - Teaching Space: 1	● Student Space (30)	
B00P - R0006 - Home Base - (66.6 SQM) - Teaching Space: 1	● Student Space (30)	
B00P - R0010 - Movement - (129.35 SQM)	Not Applicable	Circulation or storage space.
B00R - R0002 - Interview - (18.39 SQM)	● Office (4)	
B00R - R0003 - Interview - (14.96 SQM)	● Office (3)	
B00R - R0005 - Home Base - (56.52 SQM) - Teaching Space: 1	● Student Space (26)	
B00R - R0006 - Practical Activities - 1hb - (21.2 SQM)	● Student Space (9)	
B00R - R0007 - Movement - (6.39 SQM)	Not Applicable	Circulation or storage space.
B00R - R0008 - Home Base - (57.32 SQM) - Teaching Space: 1	● Student Space (26)	
B00R - R0012 - Movement - (40.1 SQM)	Not Applicable	Circulation or storage space.
B00S - R0001 - Home Base - (52.3 SQM) - Teaching Space: 1	● Student Space (24)	
B00S - R0002 - Home Base - (52.24 SQM) - Teaching Space: 1	● Student Space (24)	
B00S - R0004 - Movement - (26.86 SQM)	Not Applicable	Circulation or storage space.
B00T - R0002 - Practical Activities - 1hb - (17.53 SQM)	● Student Space (8)	
B00T - R0003 - Home Base - (64.45 SQM) - Teaching Space: 1	● Student Space (29)	
B00T - R0004 - Home Base - (64.19 SQM) - Teaching Space: 1	● Student Space (29)	
B00T - R0005 - Withdrawal Space - 2hb - (9.15 SQM)	● Student Space (4)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00T - R0006 - Practical Activities - 1hb - (17.53 SQM)	● Student Space (8)	
B00T - R0008 - Movement - (40.02 SQM)	Not Applicable	Circulation or storage space.
B00U - R0005 - Canteen - (49.41 SQM)	Not Applicable	Circulation or storage space.
B00V - R0001 - Reading Area - (219.5 SQM)	● Student Space (101)	
B00V - R0003 - Movement - (10.71 SQM)	Not Applicable	Circulation or storage space.
B00V - R0010 - Special Programs Room - (35.94 SQM)	● Student Space (16)	
B00V - R1001 - Home Base - (57.9 SQM) - Teaching Space: 1	● Student Space (26)	
B00V - R1002 - Home Base - (60.27 SQM) - Teaching Space: 1	● Student Space (27)	
B00V - R1003 - Home Base - (60.79 SQM) - Teaching Space: 1	● Student Space (28)	
B00V - R1004 - Practical Activities - 1hb - (20.44 SQM)	● Student Space (9)	
B00V - R1006 - Withdrawal Space - 1hb - (9.14 SQM)	● Student Space (4)	
B00V - R1007 - Practical Activities - 1hb - (19.11 SQM)	● Student Space (8)	
B00V - R1009 - Withdrawal Space - 2hb - (11.75 SQM)	● Student Space (5)	
B00V - R1010 - Practical Activities - 1hb - (18.76 SQM)	● Student Space (8)	
OS 508 13038 - OS 508 13038 - Administration - (114 SQM)	● Office (28)	
OS 601 10723 - OS 601 10723 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13636 - OS 601 13636 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 10589 - OS 602 10589 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11029 - OS 602 11029 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11309 - OS 602 11309 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13140 - OS 602 13140 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13754 - OS 602 13754 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14584 - OS 602 14584 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14673 - OS 602 14673 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14866 - OS 602 14866 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14898 - OS 602 14898 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15160 - OS 602 15160 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15261 - OS 602 15261 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15990 - OS 602 15990 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 11350 - OS 603 11350 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 603 12318 - OS 603 12318 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 603 18183 - OS 603 18183 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	