

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Narrabeen Sports High School (8512)</b>
<b>AMU REGION:</b>	<b>Northern Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Pittwater</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Northern Beaches</b>

8512 - Narrabeen Sports High School  
Site Plan (11998)



1:2,251



















Printed: 21-Sep-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0010 - Design L.S. - (48.47 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0013 - Design L.S. - (52.08 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0014 - Metal Technology L.S. - (63.41 SQM) - Teaching Space: 1	Student Space (29)	
B00A - R0015 - Metal Technology Bay - (41.52 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Welding Area - (9.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Metal Technology L.S. - (67.33 SQM) - Teaching Space: 1	Student Space (31)	
B00A - R0024 - Gymnasium - (739.61 SQM)	Student Space (343)	
B00A - R0028 - Student Canteen - (59.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R0031 - Movement - (13.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R0044 - Wood Technology L.S. - (195.46 SQM) - Teaching Space: 1	Student Space (90)	
B00A - R0046 - T.A.S. Outdoor Area - (105.77 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Food Technology L.S. - (98.95 SQM) - Teaching Space: 1	Student Space (45)	
B00A - R1003 - Preparation - Materials - (11.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R1006 - Food Technology L.S. - (100.17 SQM) - Teaching Space: 1	Student Space (46)	
B00A - R1010 - Staff Study - (12.89 SQM)	Office (3)	
B00A - R1014 - Movement - (7.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R1019 - Music Learning Space - (68.29 SQM) - Teaching Space: 1	Student Space (31)	
B00A - R1020 - Music Learning Space - (92.51 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R1025 - Movement - (5.9 SQM)	Not Applicable	Circulation or storage space.
B00A - R1036 - Movement - (132.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R1042 - Seminar - (30.53 SQM)	Office (7)	
B00A - R1043 - Staff Study - (38.73 SQM)	Office (9)	
B00A - R1045 - Design L.S. - (81.24 SQM) - Teaching Space: 1	Student Space (37)	
B00A - R1047 - Computer Learning Space - (79.22 SQM) - Teaching Space: 1	Student Space (36)	
B00A - R1049 - Staff Study - (53.13 SQM)	Office (13)	
B00B - R0004 - Staff Study - (25.17 SQM)	Office (6)	
B00B - R0010 - Movement Studio - (90.84 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Laboratory L.S. - (90.47 SQM) - Teaching Space: 1	Student Space (41)	
B00B - R0012 - Preparation - Science - (47.64 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Laboratory L.S. - (90.75 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0017 - Fitness Laboratory - (31.17 SQM)	Student Space (14)	
B00B - R0022 - Fitness Laboratory - (86.03 SQM)	Student Space (39)	
B00B - R1007 - Laboratory L.S. - (91.24 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R1009 - Preparation - Science - (47.82 SQM)	Not Applicable	Circulation or storage space.
B00B - R1010 - Laboratory L.S. - (91.14 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R1011 - Laboratory L.S. - (90.86 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R1014 - Laboratory L.S. - (90.76 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R1020 - Preparation - Science - (46.34 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Computer Learning Space - (52.08 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0002 - Computer Learning Space - (51.21 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R0003 - General Learning Space - (51.72 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R0004 - General Learning Space - (55.26 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R0008 - General Learning Space - (49.19 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R0009 - General Learning Space - (46.37 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0010 - Performance Workspace - (65.25 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R0011 - General Learning Space - (52.15 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0020 - General Learning Space - (51.36 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R0028 - Staff Study - (83.57 SQM)	Office (20)	
B00C - R1001 - General Learning Space - (51.94 SQM) - Teaching Space: 1	Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R1002 - General Learning Space - (51.14 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R1003 - General Learning Space - (51.86 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1004 - General Learning Space - (65.49 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R1005 - General Learning Space - (50.57 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R1009 - Staff Study - (25.14 SQM)	Office (6)	
B00C - R1010 - General Learning Space - (48.84 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R1011 - Music Learning Space - (46.17 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R1012 - General Learning Space - (64.74 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R1013 - General Learning Space - (51.86 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1022 - General Learning Space - (51.07 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R1023 - General Learning Space - (52.15 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1029 - Staff Study - (51.42 SQM)	Office (12)	
B00D - R0003 - Audio Visual Workroom - (44.21 SQM)	Student Space (20)	
B00D - R0006 - Main Entry - (17.79 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Main Area - (294.14 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Seminar - (13.64 SQM)	Office (3)	
B00D - R1002 - Seminar - (10.35 SQM)	Office (2)	
B00D - R1003 - Seminar - (10.03 SQM)	Office (2)	
B00D - R1007 - Senior Study - (136.67 SQM)	Office (34)	
B00D - R1010 - Study Space - (76.81 SQM)	Not Applicable	Circulation or storage space.
B00D - R1011 - Movement - (11.73 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - General Assistants - (11.73 SQM)	Office (2)	
B00E - R0003 - Public Reception - (25.82 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Administration - Clerical - (34.05 SQM)	Office (8)	
B00E - R0005 - Administration - Executive - (12.64 SQM)	Office (3)	
B00E - R0006 - Interview/Office - Type 1 - (12.64 SQM)	Office (3)	
B00E - R0007 - Interview/Office - Type 1 - (12.71 SQM)	Office (3)	
B00E - R0008 - Interview/Office - Type 1 - (12.68 SQM)	Office (3)	
B00E - R0010 - Clinic - (12.64 SQM)	Office (3)	
B00E - R0012 - Deputy Principal Office - (16.22 SQM)	Office (4)	
B00E - R0022 - Principal Office - (25.89 SQM)	Office (6)	
B00E - R0027 - Movement - (200.35 SQM)	Not Applicable	Circulation or storage space.
B00E - R0029 - Administration - Clerical - (9.23 SQM)	Office (2)	
B00E - R0030 - Leading Teacher - (18.48 SQM)	Office (4)	
B00E - R0034 - Commonroom - (110.5 SQM)	Office (27)	
B00E - R0035 - Staff Kitchen - (20.9 SQM)	Office (5)	
B00E - R1008 - General Learning Space - (52.51 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1010 - General Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1011 - General Learning Space - (52.37 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1017 - General Learning Space - (52.65 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1022 - Movement - (154.85 SQM)	Not Applicable	Circulation or storage space.
B00E - R1024 - Seminar/Study - (12.54 SQM)	Office (3)	
B00E - R1025 - Seminar/Study - (12.5 SQM)	Office (3)	
B00E - R1030 - Senior Study - (22.55 SQM)	Office (5)	
B00E - R1032 - General Learning Space - (81.44 SQM) - Teaching Space: 1	Student Space (37)	
B00E - R1033 - Staff Study - (56.15 SQM)	Office (14)	
B00E - R2002 - General Learning Space - (51.92 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R2005 - Senior Study - (52.51 SQM)	Office (13)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R2007 - General Learning Space - (52.58 SQM) - Teaching Space: 1	 Student Space (24)	
B00E - R2009 - Computer Learning Space - (51.78 SQM) - Teaching Space: 1	 Student Space (24)	
B00E - R2013 - General Learning Space - (51.92 SQM) - Teaching Space: 1	 Student Space (24)	
B00E - R2014 - General Learning Space - (52 SQM) - Teaching Space: 1	 Student Space (24)	
B00E - R2015 - Senior Study - (40.24 SQM)	 Office (10)	
B00E - R2017 - General Learning Space - (52.58 SQM) - Teaching Space: 1	 Student Space (24)	
B00E - R2020 - Movement - (158.79 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Art Learning Space - (91.73 SQM) - Teaching Space: 1	 Student Space (42)	
B00F - R0008 - Staff Study - (18.82 SQM)	 Office (4)	
B00F - R0010 - Art Learning Space - (91.53 SQM) - Teaching Space: 1	 Student Space (42)	
B00F - R1001 - Art Learning Space - (91.52 SQM) - Teaching Space: 1	 Student Space (42)	
B00F - R1005 - Art Learning Space - (91.53 SQM) - Teaching Space: 1	 Student Space (42)	
B00F - R1013 - Multi Media Workshop - (27.97 SQM)	Not Applicable	Circulation or storage space.
B00F - R1015 - Dark Room - (16.35 SQM)	 Office (4)	
B00G - M0001 - Movement - (18.6 SQM)	Not Applicable	Circulation or storage space.
B00G - M0002 - Movement - (13.16 SQM)	Not Applicable	Circulation or storage space.
B00G - M0003 - Movement - (9.65 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Staff Kitchen - (9.64 SQM)	 Office (2)	
B00G - R0008 - Multi-Purpose Space - (394.67 SQM)	 Student Space (183)	
B00G - R0031 - Stage - (108.93 SQM)	Not Applicable	Circulation or storage space.
OS 600 11026 - OS 600 11026 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 11552 - OS 600 11552 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 18214 - OS 600 18214 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 19772 - OS 600 19772 - Learning Unit - Small - (57 SQM)	 Student Space (26)	