

VENTILATION AUDIT REPORT

SCHOOL:	Narrabri Public School (2708)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Barwon
LOCAL GOVERNMENT AREA:	Narrabri

2708 - Narrabri Public School
Site Plan (13102)



1:831

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0020 - Interview - (11.91 SQM)	Office (2)	
B00B - R0021 - Home Base - (56.11 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0023 - Practical Activities - 1hb - (19.56 SQM)	Student Space (9)	
B00B - R0024 - Home Base - (57.13 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0025 - Practical Activities - 1hb - (21.34 SQM)	Student Space (9)	
B00B - R0028 - Home Base - (62.61 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R0029 - Home Base - (55.07 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0030 - Practical Activities - 1hb - (18.67 SQM)	Student Space (8)	
B00B - R0033 - Movement - (125.48 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Interview - (16.37 SQM)	Office (4)	
B00C - R0007 - Movement - (7.46 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Special Programs Room - (31.26 SQM)	Student Space (14)	
B00C - R0011 - Movement - (96.25 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Home Base - (45.16 SQM) - Teaching Space: 1	Student Space (20)	
B00C - R1001 - Movement - (78.42 SQM)	Not Applicable	Circulation or storage space.
B00C - R1003 - Home Base - (57.14 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R1005 - Practical Activities - 1hb - (18.98 SQM)	Student Space (8)	
B00C - R1007 - Home Base - (57.21 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R1008 - Home Base - (57.21 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R1010 - Practical Activities - 1hb - (18.98 SQM)	Student Space (8)	
B00C - R1012 - Home Base - (57.21 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R1013 - Movement - (11.7 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Home Base - (56.11 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0003 - Practical Activities - 1hb - (18.71 SQM)	Student Space (8)	
B00D - R0006 - Home Base - (56.1 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0007 - Home Base - (56.1 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0009 - Practical Activities - 1hb - (19.33 SQM)	Student Space (8)	
B00D - R0011 - Home Base - (56.26 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0012 - Movement - (66.05 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (58.08 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Practical Activities - 1hb - (19.72 SQM)	Student Space (9)	
B00E - R0003 - Home Base - (58.18 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0005 - Home Base - (62.37 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0006 - Practical Activities - 1hb - (19.72 SQM)	Student Space (9)	
B00E - R0008 - Home Base - (57 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0009 - Practical Activities - 1hb - (10.54 SQM)	Student Space (4)	
B00E - R0011 - Movement - (58.09 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (45.65 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Practical Activities - 1hb - (20.25 SQM)	Student Space (9)	
B00F - R0003 - Home Base - (71.53 SQM) - Teaching Space: 1	Student Space (33)	
B00F - R0005 - Home Base - (71.54 SQM) - Teaching Space: 1	Student Space (33)	
B00F - R0006 - Practical Activities - 1hb - (20.13 SQM)	Student Space (9)	
B00F - R0008 - Movement - (47.69 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Movement - (82.2 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Special Programs Room - (44.72 SQM)	Student Space (20)	
B00G - R0009 - Reading Area - (221.36 SQM)	Student Space (102)	
B00G - R0010 - Movement - (31.45 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Movement - (17.7 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0004 - Movement - (7.2 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Raised Platform - (51.84 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Movement - (7.18 SQM)	Not Applicable	Circulation or storage space.
B00H - R0014 - Communal Space - (187.43 SQM)	● Student Space (86)	
B00H - R0015 - Movement - (25.18 SQM)	Not Applicable	Circulation or storage space.
B00H - R0017 - Canteen - (43.79 SQM)	Not Applicable	Circulation or storage space.
B00H - R0023 - Movement - (96.45 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Movement - (15.18 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Practical Activities - 1hb - (18.73 SQM)	● Student Space (8)	
B00L - R0004 - Home Base - (60.94 SQM) - Teaching Space: 1	● Student Space (28)	
B00L - R0005 - Withdrawal Space - 2hb - (11.55 SQM)	● Student Space (5)	
B00L - R0006 - Home Base - (48.68 SQM) - Teaching Space: 1	● Student Space (22)	
B00L - R0007 - Practical Activities - 1hb - (13.69 SQM)	● Student Space (6)	
B00N - R0001 - Entry Vestibule - (26.05 SQM)	Not Applicable	Circulation or storage space.
B00N - R0002 - Clerical Office - (14.2 SQM)	● Office (3)	
B00N - R0003 - Deputy Principal - (12.81 SQM)	● Office (3)	
B00N - R0004 - Clerical Office - (20.23 SQM)	● Office (5)	
B00N - R0005 - Staff Room Annexe - (28.82 SQM)	● Office (7)	
B00N - R0006 - Staff Room - (61.16 SQM)	● Office (15)	
B00N - R0012 - Sick Bay - (8.53 SQM)	● Student Space (3)	
B00N - R0013 - Movement - (14.02 SQM)	Not Applicable	Circulation or storage space.
B00N - R0014 - Principal - (17.44 SQM)	● Office (4)	
B00N - R0015 - Deputy Principal - (12.84 SQM)	● Office (3)	
B00N - R0016 - Interview/Office - Type 3 - (16.53 SQM)	● Office (4)	
B00N - R0021 - Movement - (10.96 SQM)	Not Applicable	Circulation or storage space.
OS 502 12562 - OS 502 12562 - Admin Staff/Principal/Clerk/Dup/Clinic - (152 SQM)	● Office (38)	