
VENTILATION AUDIT REPORT



SCHOOL:	Narrandera East Infants School (4214)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Cootamundra
LOCAL GOVERNMENT AREA:	Narrandera

4214 - Narrandera East Infants School Site Plan (11856)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
0	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces. The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Staff Room - (17.39 SQM)	Office (4)	
B00A - R0003 - Principal - (15.99 SQM)	Office (3)	
B00A - R0004 - Entry Vestibule - (20.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Movement - (66.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Home Base - (65.76 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R0011 - Home Base - (57.67 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0013 - Home Base - (57.51 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0019 - Movement - (9.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Clerical Office - (19.64 SQM)	Office (4)	
B00A - R0024 - Staff Room - (33.23 SQM)	Office (8)	
B00B - R0006 - Movement - (35.66 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Movement - (10.15 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Canteen - (24.46 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Reading Area - (91.56 SQM)	Student Space (42)	
OS 531 12456 - OS 531 12456 - Library - (76 SQM)	Student Space (35)	