

VENTILATION AUDIT REPORT

SCHOOL:	Narranga Public School (4404)
AMU REGION:	North Coast
STATE ELECTORATE:	Coffs Harbour
LOCAL GOVERNMENT AREA:	Coffs Harbour

4404 - Narranga Public School
Site Plan (11213)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (57.38 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0003 - Movement - (19.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Home Base - (57.22 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0006 - Home Base - (57.14 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0008 - Movement - (19.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Home Base - (56.99 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0014 - Movement - (25.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Entry Vestibule - (17.09 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Movement - (7.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Staff Room - (56.93 SQM)	● Office (14)	
B00A - R0018 - Clerical Office - (14.19 SQM)	● Office (3)	
B00A - R0019 - Duplicating Workroom - (14.19 SQM)	● Office (3)	
B00A - R0022 - Movement - (19.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Deputy Principal - (14.08 SQM)	● Office (3)	
B00A - R0024 - Interview - (9.38 SQM)	● Office (2)	
B00A - R0025 - Principal - (16.41 SQM)	● Office (4)	
B00A - R0026 - Clerical Office - (13.87 SQM)	● Office (3)	
B00A - R0029 - Sick Bay - (12.93 SQM)	● Student Space (5)	
B00B - R0001 - Home Base - (57.22 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0003 - Movement - (19.19 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Home Base - (57.14 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0006 - Staff Room Annexe - (15.02 SQM)	● Office (3)	
B00B - R0007 - Entry Vestibule - (7.12 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Movement - (8.57 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Staff Room - (14.27 SQM)	● Office (3)	
B00B - R0015 - Movement - (9.15 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Home Base - (51.18 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R0018 - Practical Activities - 1hb - (5.79 SQM)	● Student Space (2)	
B00B - R0019 - Home Base - (85.51 SQM) - Teaching Space: 1	● Student Space (39)	
B00B - R0022 - Practical Activities - 1hb - (6.66 SQM)	● Student Space (3)	
B00C - R0005 - Practical Activities - 1hb - (7.03 SQM)	● Student Space (3)	
B00C - R0008 - Practical Activities - 1hb - (7.12 SQM)	● Student Space (3)	
B00C - R0012 - Practical Activities - 1hb - (19.13 SQM)	● Student Space (8)	
B00C - R0013 - Home Base - (60.15 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0015 - Withdrawal Space - 1hb - (9.58 SQM)	● Student Space (4)	
B00C - R0017 - Home Base - (68.18 SQM) - Teaching Space: 1	● Student Space (31)	
B00C - R0018 - Home Base - (66.91 SQM) - Teaching Space: 1	● Student Space (31)	
B00D - R0001 - Home Base - (57.31 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0003 - Movement - (14.72 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Home Base - (56.92 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0006 - Home Base - (56.92 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0009 - Movement - (7.04 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Reading Area - (157.32 SQM)	● Student Space (72)	
B00F - R0007 - Movement - (32 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Withdrawal Space - 1hb - (16.08 SQM)	● Student Space (7)	
B00F - R0009 - Withdrawal Space - 1hb - (16.09 SQM)	● Student Space (7)	
B00F - R0010 - Withdrawal - M - (7.55 SQM)	● Student Space (3)	
B00F - R0011 - Withdrawal - M - (10.54 SQM)	● Student Space (4)	
B00G - R0001 - Special Programs Room - (63.55 SQM)	● Student Space (29)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00L - R0001 - Movement - (38.55 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Practical Activities - 1hb - (19.43 SQM)	● Student Space (9)	
B00L - R0004 - Home Base - (59.31 SQM) - Teaching Space: 1	● Student Space (27)	
B00L - R0005 - Withdrawal Space - 2hb - (11.38 SQM)	● Student Space (5)	
B00L - R0006 - Home Base - (59.31 SQM) - Teaching Space: 1	● Student Space (27)	
B00L - R0008 - Practical Activities - 1hb - (19.44 SQM)	● Student Space (9)	
B00M - R0001 - Movement - (38.55 SQM)	Not Applicable	Circulation or storage space.
B00M - R0002 - Practical Activities - 1hb - (19.43 SQM)	● Student Space (9)	
B00M - R0004 - Home Base - (59.31 SQM) - Teaching Space: 1	● Student Space (27)	
B00M - R0005 - Withdrawal Space - 2hb - (11.38 SQM)	● Student Space (5)	
B00M - R0006 - Home Base - (59.31 SQM) - Teaching Space: 1	● Student Space (27)	
B00M - R0008 - Practical Activities - 1hb - (19.44 SQM)	● Student Space (9)	
B00N - R0001 - Canteen - (44.04 SQM)	Not Applicable	Circulation or storage space.
B00N - R0009 - Movement - (12.53 SQM)	Not Applicable	Circulation or storage space.
B00N - R0010 - Communal Space - (211.72 SQM)	● Student Space (98)	
B00N - R0011 - Raised Platform - (59.34 SQM)	Not Applicable	Circulation or storage space.
B00N - R0012 - Movement - (12.88 SQM)	Not Applicable	Circulation or storage space.
B00O - R0002 - Practical Activities - 1hb - (19.19 SQM)	● Student Space (8)	
B00O - R0004 - Home Base - (61.35 SQM) - Teaching Space: 1	● Student Space (28)	
B00O - R0005 - Withdrawal Space - 2hb - (11.77 SQM)	● Student Space (5)	
B00O - R0006 - Home Base - (60.84 SQM) - Teaching Space: 1	● Student Space (28)	
B00O - R0007 - Practical Activities - 1hb - (19.19 SQM)	● Student Space (8)	
B00O - R0010 - Home Base - (60.84 SQM) - Teaching Space: 1	● Student Space (28)	
B00O - R0011 - Practical Activities - 1hb - (19.19 SQM)	● Student Space (8)	
B00O - R0012 - Withdrawal Space - 2hb - (11.77 SQM)	● Student Space (5)	
B00O - R0013 - Home Base - (60.84 SQM) - Teaching Space: 1	● Student Space (28)	
B00O - R0014 - Practical Activities - 1hb - (19.19 SQM)	● Student Space (8)	
B00O - R0018 - Home Base - (60.84 SQM) - Teaching Space: 1	● Student Space (28)	
B00O - R0019 - Practical Activities - 1hb - (19.19 SQM)	● Student Space (8)	
B00O - R0020 - Withdrawal Space - 2hb - (11.77 SQM)	● Student Space (5)	
B00O - R0021 - Home Base - (61.35 SQM) - Teaching Space: 1	● Student Space (28)	
B00O - R0022 - Practical Activities - 1hb - (19.19 SQM)	● Student Space (8)	
NS 120 13821 - NS 120 13821 - Learning Unit Primary Single - PWD - (76 SQM)	● Student Space (35)	
OS 602 11560 - OS 602 11560 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14412 - OS 602 14412 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 19826 - OS 602 19826 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	