

VENTILATION AUDIT REPORT

SCHOOL:	Narwee Public School (3875)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Oatley
LOCAL GOVERNMENT AREA:	Canterbury-Bankstown

3875 - Narwee Public School
Site Plan (12080)














1:793

Printed: 23-Dec-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0005 - Deputy Principal - (15.3 SQM)	Office (3)	
B00A - R0007 - Movement - (8.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Staff Room - (49.89 SQM)	Office (12)	
B00A - R0009 - Interview - (14.46 SQM)	Office (3)	
B00A - R0010 - Principal - (16.23 SQM)	Office (4)	
B00A - R0012 - Movement - (7.33 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Home Base - (50.56 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0021 - Practical Activities - 1hb - (13.23 SQM)	Student Space (6)	
B00A - R0023 - Movement - (82.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Movement - (15.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Clerical/Printing - (12.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Clerical Office - (29.16 SQM)	Office (7)	
B00A - R0032 - Entry Vestibule - (19.19 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Practical Activities - 1hb - (10.86 SQM)	Student Space (5)	
B00B - R0005 - Home Base - (53.68 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0006 - Home Base - (53.6 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0007 - Practical Activities - 1hb - (10.76 SQM)	Student Space (4)	
B00B - R0008 - Practical Activities - 1hb - (10.96 SQM)	Student Space (5)	
B00B - R0009 - Home Base - (53.75 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0010 - Home Base - (53.68 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0011 - Practical Activities - 1hb - (9.13 SQM)	Student Space (4)	
B00B - R0016 - Movement - (36.14 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Canteen - (20.11 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Movement - (103.01 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Practical Activities - 1hb - (12.44 SQM)	Student Space (5)	
B00D - R0006 - Staff Room Annexe - (9.31 SQM)	Office (2)	
B00D - R0007 - Practical Activities - 1hb - (12.72 SQM)	Student Space (5)	
B00D - R0008 - Home Base - (53.67 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0009 - Home Base - (53.6 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0010 - Practical Activities - 1hb - (12.72 SQM)	Student Space (5)	
B00D - R0011 - Practical Activities - 1hb - (9.27 SQM)	Student Space (4)	
B00D - R0012 - Home Base - (53.67 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0013 - Home Base - (53.74 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0014 - Movement - (114.24 SQM)	Not Applicable	Circulation or storage space.
B00D - R0015 - Movement - (68.42 SQM)	Not Applicable	Circulation or storage space.
B00D - R0017 - Movement - (46.49 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (32.77 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Movement - (58.99 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Home Base - (64.02 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R0004 - Practical Activities - 1hb - (14.88 SQM)	Student Space (6)	
B00E - R0007 - Practical Activities - 1hb - (14.88 SQM)	Student Space (6)	
B00E - R0008 - Home Base - (52.49 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0009 - Home Base - (52.29 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0010 - Practical Activities - 1hb - (12.37 SQM)	Student Space (5)	
B00F - R0015 - Entry Vestibule - (28.11 SQM)	Not Applicable	Circulation or storage space.
B00F - R0021 - Clerical Office/Workroom - (7.77 SQM)	Office (1)	
B00H - R0003 - Raised Platform - (47.36 SQM)	Not Applicable	Circulation or storage space.
B00H - R0007 - Movement - (6.14 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Communal Space - (217.8 SQM)	Student Space (101)	
B00H - R0009 - Movement - (5.02 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0011 - Movement - (6.25 SQM)	Not Applicable	Circulation or storage space.
B00H - R0012 - Movement - (41.01 SQM)	Not Applicable	Circulation or storage space.
B00H - R9002 - Withdrawal Space - 1hb - (48.14 SQM)	 Student Space (22)	
B00H - R9003 - Staff Kitchen - (9.37 SQM)	 Office (2)	
B00I - R0001 - Movement - (54.56 SQM)	Not Applicable	Circulation or storage space.
B00I - R0003 - Reading Area - (156.1 SQM)	 Student Space (72)	
B00I - R0004 - Seminar/Study - (9.43 SQM)	 Office (2)	
B00I - R0005 - Reading Area - (9.43 SQM)	 Student Space (4)	
B00K - R0001 - Practical Activities - (18.97 SQM)	 Student Space (8)	
B00K - R0002 - Home Base - (60.69 SQM) - Teaching Space: 1	 Student Space (28)	
B00K - R0004 - Withdrawal Space - 2hb - (11.78 SQM)	 Student Space (5)	
B00K - R0005 - Practical Activities - (18.4 SQM)	 Student Space (8)	
B00K - R0006 - Home Base - (60.69 SQM) - Teaching Space: 1	 Student Space (28)	
B00K - R0009 - Movement - (5.05 SQM)	Not Applicable	Circulation or storage space.
B00K - R0010 - Special Programs Room - (33.28 SQM)	 Student Space (15)	