

VENTILATION AUDIT REPORT

SCHOOL:	Nashdale Public School (2714)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Orange
LOCAL GOVERNMENT AREA:	Cabonne

2714 - Nashdale Public School
Site Plan (11215)



1:454

Printed: 23-Jan-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Communal Space - (165.72 SQM)	● Student Space (76)	
B00C - R0001 - Home Base - (56.64 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0002 - Withdrawal Space - 1hb - (14.92 SQM)	● Student Space (6)	
B00C - R0005 - Movement - (6 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Principal - (12.97 SQM)	● Office (3)	
B00C - R0009 - Sick Bay - (5.53 SQM)	● Student Space (2)	
B00C - R0013 - Staff Kitchen - (9.39 SQM)	● Office (2)	
B00C - R0014 - Staff Room - (16.3 SQM)	● Office (4)	
B00C - R0015 - Clerical/Printing - (5.96 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - Clerical Office - (13.62 SQM)	● Office (3)	
B00C - R0017 - Movement - (6.55 SQM)	Not Applicable	Circulation or storage space.
B00C - R0018 - Entry Vestibule - (9.66 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Special Programs Room - (33.96 SQM)	● Student Space (15)	
B00D - R0003 - Movement - (12.84 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Home Base - (48.34 SQM) - Teaching Space: 1	● Student Space (22)	
B00E - R0005 - Entry Vestibule - (10.1 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Home Base - (64.01 SQM) - Teaching Space: 1	● Student Space (29)	
B00H - R0002 - Reading Area - (92.72 SQM)	● Student Space (43)	
B00I - R0002 - Practical Activities - 1hb - (21.61 SQM)	● Student Space (10)	
B00I - R0004 - Home Base - (63.97 SQM) - Teaching Space: 1	● Student Space (29)	
B00I - R0005 - Withdrawal Space - 2hb - (10.83 SQM)	● Student Space (5)	
B00I - R0006 - Home Base - (63.97 SQM) - Teaching Space: 1	● Student Space (29)	
B00I - R0008 - Practical Activities - 1hb - (21.61 SQM)	● Student Space (10)	
OS 602 15901 - OS 602 15901 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	