


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Nemingha Public School (2725)</b>
<b>AMU REGION:</b>	<b>North Western NSW</b>
<b>STATE ELECTORATE:</b>	<b>Tamworth</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Tamworth</b>

2725 - Nemingha Public School  
Site Plan (13605)



1:982

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Movement - (39.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Home Base - (146.4 SQM) - Teaching Space: 1	● Student Space (67)	
B00A - R0011 - Movement - (45.61 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Reading Area - (77.74 SQM)	● Student Space (36)	
B00B - R0004 - Special Programs Room - (12.4 SQM)	● Student Space (5)	
B00B - R0005 - Special Programs Room - (32.69 SQM)	● Student Space (15)	
B00B - R0009 - Movement - (30.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Movement - (114.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Canteen - (16.11 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Movement - (65.56 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Movement - (6.21 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Withdrawal Space - 1hb - (11.34 SQM)	● Student Space (5)	
B00C - R0009 - Movement - (92.48 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Practical Activities - 1hb - (16.81 SQM)	● Student Space (7)	
B00C - R0015 - Home Base - (58.85 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0016 - Home Base - (58.77 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0017 - Practical Activities - 1hb - (16.92 SQM)	● Student Space (7)	
B00C - R0020 - Practical Activities - 1hb - (21.48 SQM)	● Student Space (9)	
B00C - R0021 - Home Base - (61.84 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R0004 - Withdrawal Space - 1hb - (11.32 SQM)	● Student Space (5)	
B00D - R0010 - Movement - (97.35 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Practical Activities - 1hb - (17.09 SQM)	● Student Space (7)	
B00D - R0014 - Home Base - (58.61 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0015 - Home Base - (58.61 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0016 - Practical Activities - 1hb - (17.4 SQM)	● Student Space (8)	
B00D - R0019 - Home Base - (61.64 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R0020 - Practical Activities - 1hb - (21.57 SQM)	● Student Space (10)	
B00E - R0004 - Sick Bay - (9.01 SQM)	● Student Space (4)	
B00E - R0009 - Staff Room Annexe - (13.01 SQM)	● Office (3)	
B00E - R0010 - Staff Room - (46.93 SQM)	● Office (11)	
B00E - R0011 - Movement - (9.97 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Movement - (47.68 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Deputy Principal - (14.93 SQM)	● Office (3)	
B00E - R0017 - Principal - (17.2 SQM)	● Office (4)	
B00E - R0018 - Interview - (12.46 SQM)	● Office (3)	
B00E - R0019 - Duplicating Workroom - (20.4 SQM)	● Office (5)	
B00E - R0020 - Clerical Office - (17.68 SQM)	● Office (4)	
B00E - R0021 - Movement - (32.48 SQM)	Not Applicable	Circulation or storage space.
B00E - R0029 - Movement - (15.31 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Communal Space - (145.49 SQM)	● Student Space (67)	
B00F - R0002 - Raised Platform - (60.15 SQM)	Not Applicable	Circulation or storage space.
B00F - R0016 - Movement - (6.18 SQM)	Not Applicable	Circulation or storage space.
B00F - R0017 - Movement - (13.01 SQM)	Not Applicable	Circulation or storage space.
OS 602 12009 - OS 602 12009 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 13685 - OS 603 13685 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	