

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Neutral Bay Public School (2730)</b>
<b>AMU REGION:</b>	<b>Northern Sydney</b>
<b>STATE ELECTORATE:</b>	<b>North Shore</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>North Sydney</b>

2730 - Neutral Bay Public School  
Site Plan (11220)














## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Movement - (5.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Special Programs Room - (35.24 SQM)	● Student Space (16)	
B00A - R0005 - Movement - (13.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Movement - (20.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Movement - (6.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Principal - (15.12 SQM)	● Office (3)	
B00A - R0012 - Duplicating Workroom - (23.74 SQM)	● Office (5)	
B00A - R0017 - Canteen - (32.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Movement - (28.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Staff Room - (66.73 SQM)	● Office (16)	
B00A - R0021 - Clerical Office - (21.43 SQM)	● Office (5)	
B00A - R0022 - Movement - (10.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Movement - (8.01 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Clerical Office/Workroom - (19.91 SQM)	● Office (4)	
B00A - R0029 - Home Base - (50.08 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R0032 - Movement - (80.4 SQM)	Not Applicable	Circulation or storage space.
B00A - R0033 - Movement - (21.98 SQM)	Not Applicable	Circulation or storage space.
B00A - R0035 - Home Base - (46.98 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0041 - Home Base - (45.15 SQM) - Teaching Space: 1	● Student Space (20)	
B00A - R0042 - Home Base - (42.32 SQM) - Teaching Space: 1	● Student Space (19)	
B00A - R0045 - Home Base - (56.39 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0047 - Practical Activities - 1hb - (10.06 SQM)	● Student Space (4)	
B00A - R0050 - Sick Bay - (9.09 SQM)	● Student Space (4)	
B00A - R0051 - Home Base - (54.4 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R0053 - Practical Activities - 1hb - (8.91 SQM)	● Student Space (4)	
B00A - R0055 - Deputy Principal - (30.96 SQM)	● Office (7)	
B00A - R0056 - Staff Kitchen - (16.7 SQM)	● Office (4)	
B00A - R1001 - Home Base - (47.25 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R1003 - Special Programs Room - (40.26 SQM)	● Student Space (18)	
B00A - R1005 - Movement - (57.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R1008 - Home Base - (49.74 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1013 - Home Base - (54.65 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R1014 - Home Base - (51.79 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1017 - Practical Activities - 1hb - (10.12 SQM)	● Student Space (4)	
B00A - R1019 - Practical Activities - 1hb - (7.93 SQM)	● Student Space (3)	
B00A - R1021 - Movement - (25.59 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Home Base - (47.93 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R0003 - Home Base - (47.92 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R0009 - Movement - (13.02 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Movement - (16.23 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Home Base - (84.85 SQM) - Teaching Space: 1	● Student Space (39)	
B00B - R0025 - Home Base - (44.35 SQM) - Teaching Space: 1	● Student Space (20)	
B00B - R1001 - Home Base - (50.08 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1002 - Home Base - (49.92 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1003 - Home Base - (49.83 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1004 - Movement - (5.47 SQM)	Not Applicable	Circulation or storage space.
B00B - R1007 - Movement - (49.23 SQM)	Not Applicable	Circulation or storage space.
B00B - R1010 - Withdrawal Space - 1hb - (13.49 SQM)	● Student Space (6)	
B00B - R1017 - Home Base - (39.79 SQM) - Teaching Space: 1	● Student Space (18)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1018 - Home Base - (36.03 SQM) - Teaching Space: 1	Student Space (16)	
B00C - R0009 - Communal Space - (210.62 SQM)	Student Space (97)	
B00C - R0018 - Communal Space - (51.82 SQM)	Student Space (24)	
B00C - R0020 - Movement - (49.81 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Movement - (7.17 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Movement - (7.17 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Special Programs Room - (107.38 SQM)	Student Space (49)	
B00J - R0001 - Home Base - (64.51 SQM) - Teaching Space: 1	Student Space (29)	
B00J - R0002 - Home Base - (61.24 SQM) - Teaching Space: 1	Student Space (28)	
B00J - R0003 - Home Base - (61.15 SQM) - Teaching Space: 1	Student Space (28)	
B00J - R0004 - Home Base - (64.37 SQM) - Teaching Space: 1	Student Space (29)	
B00J - R0006 - Practical Activities - 1hb - (19.21 SQM)	Student Space (8)	
B00J - R0007 - Withdrawal Space - 2hb - (11.71 SQM)	Student Space (5)	
B00J - R0008 - Practical Activities - 1hb - (19.06 SQM)	Student Space (8)	
B00J - R0011 - Practical Activities - 1hb - (19.14 SQM)	Student Space (8)	
B00J - R0012 - Withdrawal Space - 2hb - (11.71 SQM)	Student Space (5)	
B00J - R0013 - Practical Activities - 1hb - (19.27 SQM)	Student Space (8)	
B00J - R1001 - Home Base - (64.51 SQM) - Teaching Space: 1	Student Space (29)	
B00J - R1002 - Home Base - (61.24 SQM) - Teaching Space: 1	Student Space (28)	
B00J - R1003 - Home Base - (61.15 SQM) - Teaching Space: 1	Student Space (28)	
B00J - R1004 - Home Base - (64.37 SQM) - Teaching Space: 1	Student Space (29)	
B00J - R1006 - Practical Activities - 1hb - (18.86 SQM)	Student Space (8)	
B00J - R1007 - Withdrawal Space - 2hb - (11.71 SQM)	Student Space (5)	
B00J - R1008 - Practical Activities - 1hb - (18.71 SQM)	Student Space (8)	
B00J - R1011 - Practical Activities - 1hb - (18.72 SQM)	Student Space (8)	
B00J - R1012 - Withdrawal Space - 2hb - (11.71 SQM)	Student Space (5)	
B00J - R1013 - Practical Activities - 1hb - (18.65 SQM)	Student Space (8)	
B00J - R2001 - Home Base - (64.51 SQM) - Teaching Space: 1	Student Space (29)	
B00J - R2002 - Home Base - (61.24 SQM) - Teaching Space: 1	Student Space (28)	
B00J - R2003 - Home Base - (61.15 SQM) - Teaching Space: 1	Student Space (28)	
B00J - R2004 - Home Base - (64.38 SQM) - Teaching Space: 1	Student Space (29)	
B00J - R2006 - Practical Activities - 1hb - (18.86 SQM)	Student Space (8)	
B00J - R2007 - Withdrawal Space - 2hb - (11.71 SQM)	Student Space (5)	
B00J - R2008 - Practical Activities - 1hb - (18.71 SQM)	Student Space (8)	
B00J - R2011 - Practical Activities - 1hb - (18.72 SQM)	Student Space (8)	
B00J - R2012 - Withdrawal Space - 2hb - (11.71 SQM)	Student Space (5)	
B00J - R2013 - Practical Activities - 1hb - (18.75 SQM)	Student Space (8)	
B00K - R0001 - Home Base - (59.2 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R0003 - Practical Activities - (19.36 SQM)	Student Space (8)	
B00K - R0004 - Withdrawal Space - 2hb - (10.74 SQM)	Student Space (4)	
B00K - R0005 - Home Base - (58.94 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R0006 - Practical Activities - (19.4 SQM)	Student Space (9)	
B00K - R0009 - Withdrawal Space - 1hb - (8.54 SQM)	Student Space (3)	
B00K - R0010 - Home Base - (57.25 SQM) - Teaching Space: 1	Student Space (26)	
B00K - R0011 - Practical Activities - (20.84 SQM)	Student Space (9)	
B00K - R0012 - Staff Kitchen - (5.89 SQM)	Office (1)	
B00K - R0016 - Staff Room - (21.98 SQM)	Office (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00K - R1001 - Home Base - (59.24 SQM) - Teaching Space: 1	 Student Space (27)	
B00K - R1003 - Practical Activities - (18.68 SQM)	 Student Space (8)	
B00K - R1004 - Withdrawal Space - 2hb - (10.86 SQM)	 Student Space (5)	
B00K - R1005 - Home Base - (58.79 SQM) - Teaching Space: 1	 Student Space (27)	
B00K - R1006 - Practical Activities - (19.57 SQM)	 Student Space (9)	
B00K - R1008 - Home Base - (57.35 SQM) - Teaching Space: 1	 Student Space (26)	
B00K - R1010 - Withdrawal Space - 1hb - (8.52 SQM)	 Student Space (3)	
B00K - R1011 - Practical Activities - (20.87 SQM)	 Student Space (9)	
OS 601 11199 - OS 601 11199 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 11835 - OS 601 11835 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 602 10646 - OS 602 10646 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	