


VENTILATION AUDIT REPORT

SCHOOL:	Neville Public School (2732)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Bathurst
LOCAL GOVERNMENT AREA:	Blayney

2732 - Neville Public School
Site Plan (12092)











1:801

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Clerical Office - (18.82 SQM)	 Office (4)	
B00A - R0002 - Movement - (22.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Movement - (15.4 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Reading Area - (15.15 SQM)	 Student Space (7)	
B00A - R0005 - Home Base - (31.03 SQM) - Teaching Space: 1	 Student Space (14)	
B00A - R0008 - Movement - (20.69 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Home Base - (30.83 SQM) - Teaching Space: 1	 Student Space (14)	
B00A - R0010 - Principal Office - (13.02 SQM)	 Office (3)	
B00A - R0011 - Staff Room - (13.05 SQM)	 Office (3)	
B00A - R0012 - Reading Area - (40.26 SQM)	 Student Space (18)	
B00D - R0001 - Home Base - (59.86 SQM) - Teaching Space: 1	 Student Space (27)	