

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>New Lambton Public School (2738)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Wallsend</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Newcastle</b>

2738 - New Lambton Public School  
Site Plan (11848)



1:559

Printed: 04-May-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (9.32 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Movement - (8.02 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Principal - (20.63 SQM)	Office (5)	
B00A - R0004 - Entry Vestibule - (12.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Movement - (11.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Clerical Office - (14.17 SQM)	Office (3)	
B00A - R0007 - Staff Room Annexe - (5.5 SQM)	Office (1)	
B00A - R0008 - Movement - (50.3 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Duplicating Workroom - (13.82 SQM)	Office (3)	
B00A - R0013 - Sick Bay - (10.71 SQM)	Student Space (4)	
B00A - R0014 - Deputy Principal - (13.15 SQM)	Office (3)	
B00A - R0016 - Staff Room - (119.57 SQM)	Office (29)	
B00A - R0017 - Staff Room Annexe - (13.38 SQM)	Office (3)	
B00A - R0018 - Staff Room Annexe - (13.03 SQM)	Office (3)	
B00A - R0021 - Movement - (6.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Movement - (29.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Movement - (18.89 SQM)	Not Applicable	Circulation or storage space.
B00A - R1002 - Reading Area - (234.87 SQM)	Student Space (108)	
B00A - R1003 - Seminar/Study - (14.1 SQM)	Office (3)	
B00A - R1004 - Seminar/Study - (13 SQM)	Office (3)	
B00A - R1008 - Movement - (22.28 SQM)	Not Applicable	Circulation or storage space.
B00A - R1009 - Movement - (11.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R1014 - Movement - (14.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R1015 - Movement - (11.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R9013 - Movement - (27.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R9017 - Canteen - (35.44 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (17.04 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Home Base - (59.01 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0006 - Home Base - (47.04 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0007 - Practical Activities - 1hb - (119.43 SQM)	Student Space (55)	
B00B - R0008 - Home Base - (47.08 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0009 - Home Base - (46.93 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0010 - Movement - (7.4 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Movement - (10.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R1004 - Home Base - (48.86 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R1007 - Home Base - (48.56 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R1008 - Practical Activities - 1hb - (121.45 SQM)	Student Space (56)	
B00B - R1009 - Home Base - (48.68 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R1010 - Home Base - (48.86 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R1011 - Movement - (6.48 SQM)	Not Applicable	Circulation or storage space.
B00B - R9001 - Movement - (13.41 SQM)	Not Applicable	Circulation or storage space.
B00B - R9003 - Special Programs Room - (18.74 SQM)	Student Space (8)	
B00B - R9005 - Special Programs Room - (58.01 SQM)	Student Space (26)	
B00C - R0001 - Home Base - (47.45 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R0002 - Movement - (21.17 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Interview - (7.32 SQM)	Office (1)	
B00C - R0005 - Movement - (10.27 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Home Base - (47.25 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0009 - Practical Activities - 1hb - (22.52 SQM)	Student Space (10)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0010 - Practical Activities - 1hb - (65.42 SQM)	● Student Space (30)	
B00C - R0011 - Movement - (31.92 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Home Base - (47.39 SQM) - Teaching Space: 1	● Student Space (21)	
B00C - R0013 - Movement - (21.36 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Movement - (9.76 SQM)	Not Applicable	Circulation or storage space.
B00C - R0018 - Home Base - (47.4 SQM) - Teaching Space: 1	● Student Space (21)	
B00C - R1001 - Home Base - (49.28 SQM) - Teaching Space: 1	● Student Space (22)	
B00C - R1002 - Movement - (88.33 SQM)	Not Applicable	Circulation or storage space.
B00C - R1004 - Withdrawal Space - 1hb - (21.56 SQM)	● Student Space (10)	
B00C - R1005 - Home Base - (48.48 SQM) - Teaching Space: 1	● Student Space (22)	
B00C - R1006 - Home Base - (48.62 SQM) - Teaching Space: 1	● Student Space (22)	
B00C - R1007 - Home Base - (49.28 SQM) - Teaching Space: 1	● Student Space (22)	
B00D - R0001 - Movement - (146.18 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Home Base - (53.07 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0003 - Home Base - (53.29 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0004 - Staff Room Annexe - (8.77 SQM)	● Office (2)	
B00D - R0006 - Home Base - (53.8 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0007 - Home Base - (53.29 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0008 - Home Base - (71.65 SQM) - Teaching Space: 1	● Student Space (33)	
B00D - R0009 - Home Base - (53.44 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0010 - Home Base - (53.29 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0012 - Home Base - (53.36 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0005 - Raised Platform - (38.76 SQM)	Not Applicable	Circulation or storage space.
OS 602 10010 - OS 602 10010 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11942 - OS 602 11942 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12597 - OS 602 12597 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12956 - OS 602 12956 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14413 - OS 602 14413 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	