


VENTILATION AUDIT REPORT

| | |
|-------------------------------|---------------------------------|
| SCHOOL: | Tirriwirri School (5770) |
| AMU REGION: | Southern NSW |
| STATE ELECTORATE: | Monaro |
| LOCAL GOVERNMENT AREA: | Queanbeyan-Palerang |

5770 - Tirriwirri School
Site Plan (12560)



1:1,857

Printed: 08-Mar-2021

Ventilation Audit Key

| Category | Description |
|---|--|
|  | Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings. |
|  | Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|-------------------------------|
| B00A - R0001 - Entry Vestibule - (14.17 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0002 - Interview/Office - Type 3 - (12.62 SQM) | Office (3) | |
| B00A - R0003 - Interview/Office - Type 3 - (16.51 SQM) | Office (4) | |
| B00A - R0004 - Principal - (16.76 SQM) | Office (4) | |
| B00A - R0005 - Staff Room - (53.63 SQM) | Office (13) | |
| B00A - R0012 - Movement - (10.31 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0014 - Clerical/Printing - (8.29 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0016 - Sick Bay - (6.1 SQM) | Student Space (2) | |
| B00A - R0017 - Clerical Office - (41.82 SQM) | Office (10) | |
| B00A - R0018 - Movement - (12.75 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0021 - Staff Kitchen - (24.5 SQM) | Office (6) | |
| B00B - R0002 - Canteen - (20.87 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0011 - Communal Space - (69.96 SQM) | Student Space (32) | |
| B00B - R0013 - Reading Area - (45.74 SQM) | Student Space (21) | |
| B00B - R0014 - Canteen - (36.28 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0001 - Practical Activities - (29.7 SQM) | Student Space (13) | |
| B00C - R0002 - Isolation Space - (14.84 SQM) | Office (3) | |
| B00C - R0003 - Staff Room - (13.37 SQM) | Office (3) | |
| B00C - R0004 - Isolation Space - (13.65 SQM) | Office (3) | |
| B00C - R0005 - Movement - (75.43 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0007 - Home Base - (53.9 SQM) - Teaching Space: 1 | Student Space (25) | |
| B00C - R0008 - Withdrawal Space - 1hb - (9.41 SQM) | Student Space (4) | |
| B00C - R0011 - Staff Room - (24.52 SQM) | Office (6) | |
| B00C - R0012 - Withdrawal Space - 1hb - (9.31 SQM) | Student Space (4) | |
| B00C - R0013 - Home Base - (53.9 SQM) - Teaching Space: 1 | Student Space (25) | |
| B00C - R0019 - Home Base - (36.58 SQM) - Teaching Space: 1 | Student Space (16) | |
| B00C - R0020 - Withdrawal Space - 1hb - (9.41 SQM) | Student Space (4) | |
| B00C - R0023 - Home Base - (53.84 SQM) - Teaching Space: 1 | Student Space (24) | |
| B00C - R0025 - Practical Activities - (17.03 SQM) | Student Space (7) | |
| B00C - R0026 - Staff Room - (24.92 SQM) | Office (6) | |
| B00C - R0028 - Withdrawal Space - 1hb - (9.61 SQM) | Student Space (4) | |
| B00C - R0029 - Home Base - (53.84 SQM) - Teaching Space: 1 | Student Space (24) | |
| B00D - R0001 - Movement - (27.71 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0002 - Breakout Area - (62.57 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0003 - Staff Room - (10.07 SQM) | Office (2) | |
| B00D - R0006 - Home Base - (50.11 SQM) - Teaching Space: 1 | Student Space (23) | |
| B00D - R0008 - Withdrawal Space - 1hb - (10.26 SQM) | Student Space (4) | |
| B00D - R0010 - Staff Room - (20.88 SQM) | Office (5) | |
| B00D - R0012 - Isolation Space - (8.76 SQM) | Office (2) | |
| B00D - R0014 - Isolation Space - (14.36 SQM) | Office (3) | |
| B00D - R0015 - Isolation Space - (12.13 SQM) | Office (3) | |
| B00D - R0021 - Home Base - (56.28 SQM) - Teaching Space: 1 | Student Space (26) | |
| B00D - R0022 - Withdrawal Space - 1hb - (9.23 SQM) | Student Space (4) | |
| B00D - R0025 - Staff Room - (22.38 SQM) | Office (5) | |
| B00D - R0027 - Withdrawal Space - 1hb - (9.19 SQM) | Student Space (4) | |
| B00D - R0028 - Home Base - (56.22 SQM) - Teaching Space: 1 | Student Space (26) | |