

VENTILATION AUDIT REPORT

SCHOOL:	Newbridge Heights Public School (4499)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Holsworthy
LOCAL GOVERNMENT AREA:	Liverpool

4499 - Newbridge Heights Public School
Site Plan (11159)



1:976

Printed: 01-May-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B006 - R0001 - Practical Activities - 1hb - (22.78 SQM)	● Student Space (10)	
B006 - R0002 - Movement - (25.54 SQM)	Not Applicable	Circulation or storage space.
B006 - R0006 - Movement - (78.83 SQM)	Not Applicable	Circulation or storage space.
B006 - R0007 - Withdrawal Space - 1hb - (12.47 SQM)	● Student Space (5)	
B006 - R0009 - Home Base - (80.08 SQM) - Teaching Space: 1	● Student Space (37)	
B006 - R0010 - Practical Activities - 1hb - (16.25 SQM)	● Student Space (7)	
B006 - R0016 - Movement - (5.63 SQM)	Not Applicable	Circulation or storage space.
B006 - R0017 - Practical Activities - 1hb - (16.46 SQM)	● Student Space (7)	
B006 - R0018 - Home Base - (83.19 SQM) - Teaching Space: 1	● Student Space (38)	
B006 - R0024 - Home Base - (75.57 SQM) - Teaching Space: 1	● Student Space (35)	
B006 - R0025 - Home Base - (75.54 SQM) - Teaching Space: 1	● Student Space (35)	
B00A - R0001 - Practical Activities - 1hb - (22.43 SQM)	● Student Space (10)	
B00A - R0003 - Home Base - (63.25 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0004 - Movement - (6.68 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Withdrawal Space - 1hb - (12.38 SQM)	● Student Space (5)	
B00A - R0007 - Home Base - (63.25 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0009 - Movement - (14.16 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Home Base - (63.25 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0013 - Withdrawal Space - 1hb - (12.43 SQM)	● Student Space (5)	
B00A - R0014 - Home Base - (63.25 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0016 - Movement - (6.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Movement - (12.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Practical Activities - 1hb - (21.38 SQM)	● Student Space (9)	
B00A - R0023 - Practical Activities - 1hb - (13.56 SQM)	● Student Space (6)	
B00A - R0026 - Movement - (50.27 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Clerical Office/Workroom - (30.9 SQM)	● Office (7)	
B00B - R0003 - Clerical Office - (19.58 SQM)	● Office (4)	
B00B - R0004 - Principal - (19.91 SQM)	● Office (4)	
B00B - R0006 - Staff Room - (71.35 SQM)	● Office (17)	
B00B - R0008 - Deputy Principal - (14.1 SQM)	● Office (3)	
B00B - R0010 - Deputy Principal - (13.83 SQM)	● Office (3)	
B00B - R0011 - Deputy Principal - (13.74 SQM)	● Office (3)	
B00B - R0012 - Sick Bay - (9.01 SQM)	● Student Space (4)	
B00B - R0016 - Movement - (27.37 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Entry Vestibule - (40.47 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Movement - (6.23 SQM)	Not Applicable	Circulation or storage space.
B00B - R0019 - Movement - (83.39 SQM)	Not Applicable	Circulation or storage space.
B00B - R0020 - Movement - (75.14 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (46.41 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Movement - (217.4 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Raised Platform - (36.61 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Communal Space - (272.64 SQM)	● Student Space (126)	
B00C - R0017 - Canteen - (45.39 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Movement - (32.01 SQM)	Not Applicable	Circulation or storage space.
B00D - M0001 - Withdrawal Space - 1hb - (14.09 SQM)	● Student Space (6)	
B00D - R0002 - Practical Activities - 1hb - (17.11 SQM)	● Student Space (7)	
B00D - R0003 - Movement - (25.07 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Practical Activities - 1hb - (16.53 SQM)	● Student Space (7)	
B00D - R0008 - Withdrawal Space - 1hb - (13.94 SQM)	● Student Space (6)	
B00D - R0010 - Withdrawal Space - 1hb - (30.42 SQM)	● Student Space (14)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0013 - Practical Activities - 1hb - (13.43 SQM)	Student Space (6)	
B00D - R0014 - Movement - (13.15 SQM)	Not Applicable	Circulation or storage space.
B00D - R0016 - Home Base - (63.18 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R0017 - Movement - (7.28 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Withdrawal Space - 1hb - (12.6 SQM)	Student Space (5)	
B00D - R0019 - Home Base - (63.21 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R0021 - Movement - (14.53 SQM)	Not Applicable	Circulation or storage space.
B00D - R0022 - Home Base - (63.21 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R0025 - Withdrawal Space - 1hb - (12.59 SQM)	Student Space (5)	
B00D - R0026 - Movement - (6.98 SQM)	Not Applicable	Circulation or storage space.
B00D - R0027 - Home Base - (63.21 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R0029 - Movement - (52.64 SQM)	Not Applicable	Circulation or storage space.
B00F - M0001 - Seminar/Study - (14.71 SQM)	Office (3)	
B00F - R0007 - Reading Area - (262.2 SQM)	Student Space (121)	
B00F - R0008 - Movement - (140.44 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Movement - (22.64 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Movement - (7.42 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Movement - (21.59 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Practical Activities - 1hb - (16.03 SQM)	Student Space (7)	
B00G - R0007 - Home Base - (63.22 SQM) - Teaching Space: 1	Student Space (29)	
B00G - R0008 - Movement - (7.28 SQM)	Not Applicable	Circulation or storage space.
B00G - R0009 - Withdrawal Space - 1hb - (12.59 SQM)	Student Space (5)	
B00G - R0012 - Home Base - (63.22 SQM) - Teaching Space: 1	Student Space (29)	
B00G - R0013 - Movement - (14.54 SQM)	Not Applicable	Circulation or storage space.
B00G - R0014 - Home Base - (63.22 SQM) - Teaching Space: 1	Student Space (29)	
B00G - R0017 - Withdrawal Space - 1hb - (12.59 SQM)	Student Space (5)	
B00G - R0018 - Movement - (6.98 SQM)	Not Applicable	Circulation or storage space.
B00G - R0019 - Home Base - (63.22 SQM) - Teaching Space: 1	Student Space (29)	
B00G - R0022 - Practical Activities - 1hb - (14.42 SQM)	Student Space (6)	
B00G - R0027 - Movement - (7.13 SQM)	Not Applicable	Circulation or storage space.
B00G - R0028 - Practical Activities - 1hb - (14.56 SQM)	Student Space (6)	
B00G - R0029 - Seminar/Study - (13.94 SQM)	Office (3)	
B00G - R0031 - Special Programs Room - (35.78 SQM)	Student Space (16)	
B00G - R0033 - Movement - (59.75 SQM)	Not Applicable	Circulation or storage space.
B00H - M0003 - Withdrawal Space - 1hb - (13.18 SQM)	Student Space (6)	
B00H - R0001 - Movement - (7.28 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Home Base - (63.22 SQM) - Teaching Space: 1	Student Space (29)	
B00H - R0004 - Withdrawal Space - 1hb - (12.59 SQM)	Student Space (5)	
B00H - R0005 - Home Base - (63.22 SQM) - Teaching Space: 1	Student Space (29)	
B00H - R0007 - Movement - (14.53 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Home Base - (63.22 SQM) - Teaching Space: 1	Student Space (29)	
B00H - R0010 - Withdrawal Space - 1hb - (12.59 SQM)	Student Space (5)	
B00H - R0011 - Home Base - (63.22 SQM) - Teaching Space: 1	Student Space (29)	
B00H - R0013 - Movement - (14.54 SQM)	Not Applicable	Circulation or storage space.
B00H - R0014 - Home Base - (62.68 SQM) - Teaching Space: 1	Student Space (29)	
B00H - R0018 - Practical Activities - 1hb - (29.95 SQM)	Student Space (13)	
B00H - R0020 - Movement - (5.62 SQM)	Not Applicable	Circulation or storage space.
B00H - R0024 - Practical Activities - 1hb - (13.45 SQM)	Student Space (6)	
B00H - R0025 - Withdrawal Space - 1hb - (14.69 SQM)	Student Space (6)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0027 - Special Programs Room - (45.62 SQM)	● Student Space (21)	
B00H - R0028 - Movement - (21.6 SQM)	Not Applicable	Circulation or storage space.
B00H - R0029 - Movement - (7.42 SQM)	Not Applicable	Circulation or storage space.
B00H - R0032 - Practical Activities - 1hb - (16.02 SQM)	● Student Space (7)	
B00H - R0035 - Movement - (73.37 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Practical Activities - 1hb - (19.18 SQM)	● Student Space (8)	
B00I - R0002 - Home Base - (60.63 SQM) - Teaching Space: 1	● Student Space (28)	
B00I - R0004 - Withdrawal Space - 2hb - (11.78 SQM)	● Student Space (5)	
B00I - R0005 - Practical Activities - 1hb - (19.78 SQM)	● Student Space (9)	
B00I - R0006 - Home Base - (60.57 SQM) - Teaching Space: 1	● Student Space (28)	
B00J - R0001 - Practical Activities - 1hb - (17.53 SQM)	● Student Space (8)	
B00J - R0002 - Home Base - (60.69 SQM) - Teaching Space: 1	● Student Space (28)	
B00J - R0004 - Withdrawal Space - 1hb - (7.68 SQM)	● Student Space (3)	
B00J - R0006 - Movement - (6.28 SQM)	Not Applicable	Circulation or storage space.
B00J - R0007 - Special Programs Room - Type 2 - (33.25 SQM)	● Student Space (15)	
B00J - R0010 - Movement - (6.28 SQM)	Not Applicable	Circulation or storage space.
B00J - R0011 - Special Programs Room - Type 2 - (33.19 SQM)	● Student Space (15)	
OH 060 17043 - OH 060 17043 - OSHC Hub 60 - (190 SQM)	● Student Space (88)	
OS 602 11400 - OS 602 11400 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 606 19140 - OS 606 19140 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	