

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Newcastle Middle School (5701)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Wallsend</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Newcastle</b>

5701 - Newcastle Middle School  
Site Plan (10496)



1:687

Printed: 31-Oct-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Principal - (13.64 SQM)	Office (3)	
B00A - R0003 - Entry Vestibule - (14.69 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Clerical Office/Workroom - (17.31 SQM)	Office (4)	
B00A - R0005 - Movement - (12.7 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Movement - (28.79 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Commonroom - (30.66 SQM)	Office (7)	
B00B - R0004 - Practical Activities - S - 1hb - (21.9 SQM)	Student Space (10)	
B00B - R0005 - Practical Activities - S - 1hb - (19.71 SQM)	Student Space (9)	
B00B - R0006 - Home Base - S - (33.58 SQM) - Teaching Space: 1	Student Space (15)	
B00B - R0009 - Practical Activities - S - 1hb - (41.61 SQM)	Student Space (19)	
B00B - R0010 - Home Base - S - (29.85 SQM) - Teaching Space: 1	Student Space (13)	
B00B - R0012 - Movement - (27.66 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Movement - (10.03 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Hydrotherapy - Spa - (156.07 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Movement - (23.08 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Home Base - S - (49.21 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0007 - Practical Activities - S - 1hb - (29.16 SQM)	Student Space (13)	
B00I - R0001 - Withdrawal - P - (19.78 SQM)	Student Space (9)	
B00I - R0002 - Movement - (6.87 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Hydrotherapy - Spa - (16.7 SQM)	Not Applicable	Circulation or storage space.
B00M - R0002 - Reading Area - (64.93 SQM)	Student Space (30)	
NS 120 12684 - NS 120 12684 - Learning Unit Primary Single - PWD - (76 SQM)	Student Space (35)	
OS 601 12700 - OS 601 12700 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 17802 - OS 601 17802 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 602 14420 - OS 602 14420 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 621 15092 - OS 621 15092 - Learning Unit Single - PWD - (95 SQM)	Student Space (44)	
OS 621 15399 - OS 621 15399 - Learning Unit Single - PWD - (95 SQM)	Student Space (44)	