


VENTILATION AUDIT REPORT

SCHOOL:	Newling Public School (4478)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Northern Tablelands
LOCAL GOVERNMENT AREA:	Armidale

4478 - Newling Public School
Site Plan (11221)








1:1,162

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0001 - Movement - (31.19 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Canteen - (20.15 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Movement - (21.74 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Movement - (6.83 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Home Base - (71.69 SQM) - Teaching Space: 1	● Student Space (33)	
B00C - R0010 - Practical Activities - 1hb - (27.33 SQM)	● Student Space (12)	
B00C - R0011 - Movement - (5.45 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Movement - (9.54 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Withdrawal Space - 1hb - (22.17 SQM)	● Student Space (10)	
B00C - R0014 - Withdrawal Space - 1hb - (19.76 SQM)	● Student Space (9)	
B00C - R0017 - Sick Bay - (15.39 SQM)	● Student Space (7)	
B00C - R0018 - Clerical Office - (28.75 SQM)	● Office (7)	
B00C - R0019 - Duplicating Workroom - (12.67 SQM)	● Office (3)	
B00C - R0024 - Movement - (9.68 SQM)	Not Applicable	Circulation or storage space.
B00C - R0025 - Movement - (9.42 SQM)	Not Applicable	Circulation or storage space.
B00C - R0027 - Entry Vestibule - (29.38 SQM)	Not Applicable	Circulation or storage space.
B00C - R0028 - Movement - (56.41 SQM)	Not Applicable	Circulation or storage space.
B00C - R0030 - Interview - (19.45 SQM)	● Office (4)	
B00C - R0031 - Principal - (19.21 SQM)	● Office (4)	
B00C - R0034 - Movement - (21.62 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Movement - (35.74 SQM)	Not Applicable	Circulation or storage space.
B00C - R1002 - Home Base - (73.09 SQM) - Teaching Space: 1	● Student Space (33)	
B00C - R1004 - Withdrawal Space - 1hb - (47.87 SQM)	● Student Space (22)	
B00C - R1006 - Home Base - (59.83 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R1007 - Movement - (17.61 SQM)	Not Applicable	Circulation or storage space.
B00C - R1011 - Home Base - (89.44 SQM) - Teaching Space: 1	● Student Space (41)	
B00C - R1012 - Staff Room - (58.41 SQM)	● Office (14)	
B00D - R0005 - Practical Activities - M - 1hb - (16.84 SQM)	● Student Space (7)	
B00D - R0006 - Withdrawal - M - (32.76 SQM)	● Student Space (15)	
B00D - R0010 - Movement - (7.68 SQM)	Not Applicable	Circulation or storage space.
B00D - R0013 - Home Base - (70.74 SQM) - Teaching Space: 1	● Student Space (32)	
B00D - R0015 - Practical Activities - 1hb - (21.17 SQM)	● Student Space (9)	
B00D - R0020 - Movement - (25.34 SQM)	Not Applicable	Circulation or storage space.
B00D - R0022 - Clerical Office/Workroom - (18.85 SQM)	● Office (4)	
B00D - R0023 - Special Programs Room - (31.76 SQM)	● Student Space (14)	
B00D - R0024 - Special Programs Room - (8.3 SQM)	● Student Space (3)	
B00D - R0026 - Movement - (9.73 SQM)	Not Applicable	Circulation or storage space.
B00D - R0027 - Reading Area - (84.93 SQM)	● Student Space (39)	
B00D - R0029 - Movement - (26.56 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (38.58 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Practical Activities - 1hb - (19.82 SQM)	● Student Space (9)	
B00E - R0004 - Home Base - (62.66 SQM) - Teaching Space: 1	● Student Space (29)	
B00E - R0005 - Withdrawal Space - 2hb - (11.01 SQM)	● Student Space (5)	
B00E - R0006 - Practical Activities - 1hb - (19.37 SQM)	● Student Space (8)	
B00E - R0008 - Home Base - (62.77 SQM) - Teaching Space: 1	● Student Space (29)	
B00E - R0009 - Movement - (30.98 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Raised Platform - (36.64 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Communal Space - (159.44 SQM)	● Student Space (73)	
B00F - R0012 - Movement - (11 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Practical Activities - 1hb - (18.91 SQM)	● Student Space (8)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0005 - Home Base - (61.02 SQM) - Teaching Space: 1	 Student Space (28)	
B00H - R0007 - Withdrawal Space - 2hb - (11.6 SQM)	 Student Space (5)	
B00H - R0008 - Home Base - (60.09 SQM) - Teaching Space: 1	 Student Space (27)	
B00H - R0010 - Practical Activities - 1hb - (18.91 SQM)	 Student Space (8)	
B00H - R0011 - Special Programs Room - (38.41 SQM)	 Student Space (17)	