

VENTILATION AUDIT REPORT

SCHOOL:	Niland School (5643)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Mount Druitt
LOCAL GOVERNMENT AREA:	Blacktown









5643 - Niland School
Site Plan (10550)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Movement - (22.37 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Interview - (12.63 SQM)	Office (3)	
B00A - R0005 - Withdrawal - M - (12.63 SQM)	Student Space (5)	
B00A - R0006 - Staff Room Annexe - (12.56 SQM)	Office (3)	
B00A - R0010 - Staff Room Annexe - (12.6 SQM)	Office (3)	
B00A - R0011 - Principal - (17.21 SQM)	Office (4)	
B00A - R0012 - Movement - (33.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Entry Vestibule - (21.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Movement - (15.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Special Programs Room - (19.5 SQM)	Student Space (9)	
B00A - R0016 - Deputy Principal - (16.88 SQM)	Office (4)	
B00A - R0017 - Clerical Office/Workroom - (14.83 SQM)	Office (3)	
B00A - R0018 - Duplicating Workroom - (14.32 SQM)	Office (3)	
B00A - R0019 - Sick Bay - (8.94 SQM)	Student Space (4)	
B00A - R0023 - Staff Room - (86.59 SQM)	Office (21)	
B00B - R0006 - Canteen - (30.24 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Movement - (10.18 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Communal Space - (167.01 SQM)	Student Space (77)	
B00B - R0016 - Raised Platform - (36.54 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Movement - (25.8 SQM)	Not Applicable	Circulation or storage space.
B00B - R0020 - Movement - (61.44 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Movement - (45.48 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (131.41 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Movement - (122.09 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Reading Area - (106.74 SQM)	Student Space (49)	
B00C - R0009 - Special Programs Room - (74.88 SQM)	Student Space (34)	
B00D - R0001 - Movement - (15.39 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Materials Technology L.S. - (90.8 SQM) - Teaching Space: 1	Student Space (42)	
B00D - R0007 - Food Technology L.S. - (79.49 SQM) - Teaching Space: 1	Student Space (36)	
B00D - R0008 - Movement - (13.09 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Movement - (53.87 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Practical Activities - 1hb - (14.1 SQM)	Student Space (6)	
B00E - R0007 - Home Base - M - (50.42 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R0010 - Practical Activities - M - 1hb - (14.1 SQM)	Student Space (6)	
B00E - R0011 - Home Base - M - (51.82 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0012 - Home Base - M - (47.27 SQM) - Teaching Space: 1	Student Space (21)	
B00E - R0013 - Practical Activities - M - 1hb - (14.16 SQM)	Student Space (6)	
B00E - R0015 - Movement - (74.03 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (80.75 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Home Base - M - (41.14 SQM) - Teaching Space: 1	Student Space (19)	
B00F - R0008 - Movement - (7.38 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Practical Activities - M - 1hb - (10.73 SQM)	Student Space (4)	
B00F - R0010 - Home Base - M - (41.31 SQM) - Teaching Space: 1	Student Space (19)	
B00F - R0012 - Movement - (6.9 SQM)	Not Applicable	Circulation or storage space.
B00F - R0014 - Home Base - M - (41.12 SQM) - Teaching Space: 1	Student Space (19)	
B00F - R0015 - Movement - (6.9 SQM)	Not Applicable	Circulation or storage space.
B00F - R0016 - Practical Activities - M - 1hb - (10.99 SQM)	Student Space (5)	
B00F - R0017 - Home Base - M - (41.11 SQM) - Teaching Space: 1	Student Space (19)	
B00F - R0019 - Movement - (6.9 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0001 - Movement - (71.95 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Practical Activities - M - 1hb - (14.94 SQM)	 Student Space (6)	
B00G - R0004 - Home Base - M - (72.63 SQM) - Teaching Space: 1	 Student Space (33)	
B00G - R0005 - Home Base - M - (51.48 SQM) - Teaching Space: 1	 Student Space (23)	
B00G - R0006 - Practical Activities - M - 1hb - (13.51 SQM)	 Student Space (6)	
B00G - R0011 - Practical Activities - M - 1hb - (13.59 SQM)	 Student Space (6)	
B00G - R0012 - Home Base - M - (51.46 SQM) - Teaching Space: 1	 Student Space (23)	
B00G - R0013 - Movement - (10 SQM)	Not Applicable	Circulation or storage space.
B00G - R0014 - Home Base - M - (51.31 SQM) - Teaching Space: 1	 Student Space (23)	
B00G - R0015 - Practical Activities - M - 1hb - (13.85 SQM)	 Student Space (6)	
B00G - R0017 - Movement - (10 SQM)	Not Applicable	Circulation or storage space.